

Rocky Mountain Power

Docket No. 06-035-148

Status Report of Dealings with Mr. Tim Vetere (and/or Green River Ranches, LLC)

April 29, 2009 through June 26, 2009

April 29, 2009: Nancy Stark, Green River Ranches, LLC emails Debra Dull of Rocky Mountain Power, asking for a point of clarification concerning a request for 30 horsepower at 6550 North Hastings Lane. Nancy stated a request had been submitted to Rocky Mountain Power several years ago.

April 29, 2009: Debra Dull sent a reply email to Nancy Stark explaining that the request for a 30 horsepower pump at 6550 North Hastings was showing in the queue records; however, there were other customer requests in the queue that pre-dated the 30 horsepower request. Those other customer requests would be accommodated first, according to their position in the queue. The email also stated that the other customer requests are also waiting for the summer of 2010 in service date of the new 138 KV substation.

May 8, 2009: Nancy Stark emailed Debra Dull stating the Rocky Mountain Power had not responded (for two business days) to phone calls and voice messages from Green River Ranches, LLC electrician Kevin Havey from KAP Electric. Nancy asked when Rocky Mountain Power would respond to Kevin.

May 10, 2009: Debra Dull called Jesse Barker at home (Sunday) to ask if he had been contacted by Kevin Havey or someone from Green River Ranches, LLC. Jesse stated that as of 3:30 PM on Friday, May 8, 2009 he had not heard from Kevin. Jesse agreed to call Kevin Monday morning, May 11, 2009, to schedule a time for the crew to work on the interconnection for Green River Ranches, LLC.

May 11, 2009: Kevin Havey and Jesse Barker spoke on the telephone and scheduled a time for the interconnection. Kevin said he had planned on contacting Jesse, but had not had the opportunity to call him the previous week.

May 19, 2009: Debra Dull sent email to Nancy Stark informing Nancy that metering had been installed at both the 300 and 750 horsepower primary delivery points during the previous week. Kevin Havey had agreed to contact Rocky Mountain Power when he had completed the wiring for Green River Ranches, LLC. As of May 19, 2009 Rocky Mountain Power had not energized the power line because Kevin had not completed his wiring.

May 21, 2009, 10:02 AM: An email to Debra Dull was received from Cheryl Provard, Green River Ranches, LLC employee, listing voltages that Green River Ranches, LLC had taken on Monday, May 18, 2009 and again on Thursday, May 21, 2009.

May 21, 2009, 10:13 AM: An email to Debra Dull was received from Nancy Stark asking for someone to be sent to the farm because there was not sufficient power to run the pumps.

May 21, 2009, 2:26 PM: An email from Debra Dull to Nancy Stark and Cheryl Provard stated the Rocky Mountain Power local Green River lineman was actually at the farm site working with Kevin Havey when Nancy and Cheryl had sent the previous emails to Debra Dull. The voltage problem had been corrected.

There was a blown fuse on Long Street causing Mr Vetere's pump to single phase.

June 5, 2009: Nancy Stark sent an email to Debra Dull asking about the type and installation of a metering device that could record information so there will be no question if the power is not delivered to the Green River Ranches, LLC sites as contractually agreed.

June 5, 2009: Debra Dull and Rob Stewart telephoned Nancy Stark to discuss the email and get more detail for clarification on what Nancy Stark was asking. As the conversation progressed it was evident that the type of monitoring/metering device that Green River Ranches, LLC wanted was not something that Rocky Mountain Power could provide. Nancy stated she may call a local Price, UT engineering firm to discuss some type of monitoring/metering on the Green River Ranches, LLC side of the metering.

June 12, 2009: Debra Dull called Nancy Stark to inform her that fuses on the Green River Ranches, LLC side of the primary metering had failed. A lineman from Rocky Mountain Power had already been out to the site and verified that electricity was being delivered to the Rocky Mountain Power side of the meter, so the outage was on the Green River Ranches, LLC electrical system. Kevin Havey, Green River Ranches, LLC electrician, had requested Rocky Mountain Power's assistance. Because Kevin did not have the fuses he needed to repair the Green River Ranches, LLC system, Kevin asked if Rocky Mountain Power could provide him with fuses; the Rocky Mountain Power lineman nailed three fuses to the metering pole and informed Kevin they were there.

June 18, 2009, 4:08 PM: Nancy Stark sent an email to Debra Dull stating that no one had come to the farm with the fuses that we had discussed during our telephone conversation June 12, 2009. Nancy also stated that the farm had been out of power since around 1:00 PM. The email also stated that if Green River Ranches, LLC continued to have issues with the power it may result in substantial monetary damages to the Green River Ranches, LLC operation.

June 18, 2009, 6:06 PM: Debra Dull sent an email to Nancy Stark explaining that the fuses had been nailed to the pole on June 12, 2009 and Kevin Havey had been telephoned that afternoon and told they were there. The email also noted that leaving the three fuses was a courtesy to Kevin and Green River Ranches, LLC and not a practice that would be continued.

The email also explained that a lightning strike did occur on the 46 KV transmission line that fed the town of Green River and the entire community was out of power momentarily (less than 60 seconds). The Rocky Mountain Power lineman reported thunderstorms and heavy winds in the Green River area. At 4:30 PM a Rocky Mountain Power lineman went to the metering sites for Green River Ranches, LLC and verified that electricity was being delivered to the Green River Ranches, LLC meters. If Green River Ranches, LLC had experienced an outage beginning at 1:00 PM and was still out of power at the time of the email sent by Nancy Stark (4:08 PM), the suggestion was made that Green River Ranches, LLC notify their electrician.

June 26 2009: An email was received from Nancy Stark stating that on June 20, 2009 the electrical voltage spiked on the farm. The Green River Ranches, LLC electrician had indicated to Nancy Stark that the Rocky Mountain Power regulator was set too high and spiked when lightning hit it.

June 26, 2009: A Rocky Mountain Power lineman verified the settings on the regulator; the settings were within acceptable operating limits.