

07-035-93/Rocky Mountain Power  
July 8, 2008  
UIEC 20<sup>th</sup> Set Data Request 20.5

**UIEC Data Request 20.5**

**Class Cost of Service Allocation/Methodology & Procedures:**

With respect to the Company's response to UIEC Data Request 19.5, wherein the Company advised that a sample was designed in April of 2008 for the Utah Residential Class and Utah Commercial Class 23; and in June 2008 for the Utah Commercial Industrial Class 06, please provide a copy of the study and reports validating the method for designing each of the samples. Please explain how the number of samples to be taken was determined, how the location of those samples was determined, and how all other information necessary to support a conclusion that the study will produce results that are statistically reliable were determined.

**Response to UIEC Data Request 20.5**

Please refer to Attachments UIEC 20.5 -1 through UIEC 20.5 -3 for sample design documents.

**UTAH**

**07-035-93**

**GENERAL RATE CASE**

**ROCKY MOUNTAIN POWER**

**UIEC 20<sup>TH</sup> SET DATA REQUEST (1-11)**

**ATTACHMENT UIEC 20.5 –(1-3)**

**ON THE ENCLOSED CD**

Attach UIEC 20.5 -1.pdf

# Utah Residential Class (2008) Load Recorder Study Sampling Procedures

This paper describes the procedures used to develop the 2008 Utah Residential Class Study. This study will provide load data for use in support of cost studies and price filings before the Utah Public Service Commission, and for use in other studies of residential customer demand characteristics. The goal of this sample design is to provide relative precision of  $\pm 5\%$  at the 90% confidence level for an estimate of the average of the twelve monthly system peak hours, during twelve consecutive months.

Recorders will be placed in service effective no later than October 1<sup>st</sup>, 2008, and will be monitored on a continuous basis to insure no significant deviation from billing records.

## Sampling Plan for Utah

This sampling plans includes several steps:

1. Formalization of the sample parameters;
2. Specification of the target variable;
3. Choice of the stratification variable;
4. Choice of method for estimating kW;
5. Choice of the number of strata;
6. Construction of the strata boundaries
7. Allocation of sample points to each stratum;
8. Selection of primary sample sites;
9. Selection of alternate sample sites.

### Formalization of the sample parameters

This sample replaces the old Utah residential class sample, which was originally installed in 1991, and later refreshed in 1999. There is no secondary/primary voltage breakdown in the tariff and, accordingly, only one load sample is required to provide load estimates for this group.

### Specification of the target variable

Load studies in the state of Utah are used primarily to support cost allocation studies. Current cost study methods use the average demand at the hours of the PacifiCorp system peak for twelve consecutive months (12SYSPK), as well as estimates of distribution and individual customer maximum demands, each averaged over twelve consecutive months.

These study designs treat 12SYSPK as the target variable because it is, by far, the most important peak measure for allocation of demand related costs.

The current Utah residential class study was used to provide estimates of means and residual variances required in these sample designs. The range of sample data employed encompassed the twelve month period from January 2007 through December 2007. Billing data for the twelve months ending February 2008 were used to determine appropriate stratification.

### **Choice of the Stratification Variable**

A potential stratifying variable, according to Cochran, should meet three criteria<sup>1</sup>:

1. *The population is composed of institutions varying widely in size.*
2. *The principle variables to be measured are closely related to the sizes of the institutions.*
3. *A good measure of size is available for setting up the strata.*

Average monthly billing kWh (KWH\_MNTH), which is the average monthly energy registered over a twelve consecutive month period, was selected as the best available variable for this purpose. It is readily available for all customers in this class, with a range from 0 to 191,500 kWh for any given customer in this group.

### **Choice of Method for Estimating kW**

To estimate a peak demand for a population using MPU, the mean peak demand value from the sample is multiplied by the number of elements in the entire population. Use of the MPU method provides an unbiased estimate.

For ratio estimation, the ratio of the target variable (12SYSPK) over the auxiliary variable (KWH\_ANN) is calculated for the sample. This ratio is then multiplied by the total annual billed kWh for the population to get the estimated total group peak demand. Because energy usage and peak demand are correlated, a ratio estimate will have a smaller variance than a MPU estimate. However, a ratio estimate may be slightly biased.

With stratified sample designs, ratio estimators can be computed in two ways: separately for each stratum, or a combined ratio can be computed over all strata. Separate ratio estimation tends to result in smaller variance. However, the combined ratio method is more appropriate when stratum sample sizes are small, because the risk of bias is reduced.

Tables C.1 shows sample size needed for the Utah Residential Class study using a mean-per-unit method, assuming a three strata design, with optimal allocation utilizing the Tschprow/Neyman method. Table C.2 details the same information in a four strata schema. The design as presented in Table C.1 was selected for this sample.

---

<sup>1</sup> William G. Cochran, "Sampling Techniques", Third Edition, Wiley, pg.101

### Choice of the Number of Strata

As the number of strata increases, precision of the estimate of the total contribution to demand (kW) at system peak also increases. However, the increase in precision per additional stratum diminishes after a relatively small number of strata<sup>2</sup>. Desire for simplicity, and for a reasonable number of sites in each stratum lead to a preference for a small number of strata. If a minimum number of sites policy is followed (eg. 10 sites minimum per stratum), then the addition of strata can actually lead to more, rather than fewer, total sites. If such a policy is not followed, the result can be strata with so few records that confidence in sample estimates is at risk from unexpected data problems, variance estimates may not be sufficiently precise for future sample design purposes, and the sample may not be robust enough to be useful when analysis needs change.

A final decision on the number of strata requires actual cost comparison of potential stratification schemes to evaluate effectiveness versus cost. For this study, a three strata scheme was employed. The method described below was used to compare stratification approaches.

### Construction of Strata Boundaries

Various methods might be used for definition of strata boundaries. Cochran found the “cumulative square root of  $f$ ”<sup>3</sup> rule, as defined by Dalenius and Hodges (1959), to be superior in a comparative study of such methods applied to actual distributions exhibiting a range of skewness.

Steps in calculating strata boundaries under the “cumulative square root of  $f$ ” rule are as follows. First, tabulate frequencies of the stratifying variable. For these studies, average monthly energy (KWH\_MNTH) from customer billing records for the twelve months ending February 2008 were used. All Utah residential customers, whose end of year status was active, and whose total annual kWh consumption was greater than 250 kWh were included in this procedure, and in population figures for the sample design. Second, multiply the number of customers in each interval by the interval factor. Third, take the square root of these frequencies. Fourth, cumulatively sum the square roots. The resulting distribution of adjusted cumulative square roots of frequency is then partitioned into equal intervals by dividing by the number of strata. The final stratification scheme of three strata is presented in Table B.1, and shows the optimal boundaries resulting from

---

<sup>2</sup> William G. Cochran, “Sampling Techniques”, Third Edition, Wiley, Pg. 132

<sup>3</sup> William G. Cochran, “Sampling Techniques”, Third Edition, Wiley, Pgs. 129-130

the above procedure, after adjustments made to accommodate prior cost analysis requirements (if any).

### Allocation of Sample Points to Each Stratum

Once the stratum boundaries have been determined, sample points (i.e., load recorders) must be assigned to the strata. The Tschprow-Neyman allocation procedure<sup>4</sup> allocates an optimal sampling rate to each stratum. Optimal allocation techniques minimize the variance of the population estimates by increasing the sample proportion in the strata having larger variances. This produces a sampling rate for each stratum which is proportional to the standard deviation within the stratum. The analogous procedure for a ratio sampling plan is allocation in proportion to the square root of the residual variance.

Data for estimating the variance of the 12SYSPK measure for each stratum were available for customers included in the current Utah residential class load study. These data were used to provide estimates for the new Utah residential class sample design. For the mean-per-unit method, the variance within each stratum was the ordinary variance of the mean.

Minimum recorder allocations and data loss adjustments are required for each stratum to maintain adequate data in case of recorder failure and to provide data for analysis of load characteristics other than the primary target variable, should such analysis be necessary. Minimums ranging from 5 to 15 sites per stratum have been used in past studies. In the present studies, a minimum of 10 sites was used. A minimum on the high side was selected, despite improvements in data quality due to solid state recording equipment, because changing requirements for load research and other areas using this data may require unanticipated applications, and because overall sample efficiencies are bringing these studies in well below the budgeted number of sites, even with the 10 site minimum. The final allocation of recorders reflected an additional ten percent data loss adjustment per stratum over the optimal or minimum allocation.

Because of an existing, ready supply of the types of meters required for a load study such as this, the decision was made to substantially increase the number of sites to be installed vs. the sample design. The three strata design selected class for the installation of 158 recorders to meet design standards. This design was supplemented with an additional 12 recorders, which translates to  $\pm 4.64\%$  precision at the 90% confidence level.

---

<sup>4</sup> William G. Cochran, "Sampling Techniques", Third Edition, Wiley, pgs. 96-99

### Sample Selection

Systematic sample selections were used for each stratum to ensure a representative distribution. For practical reasons, inactive customers, customers with no kWh meter installed (usually certain types of lighting customers with very predictable demand and consumption, indicated by absence of a kWh meter number), and customers with very low consumption (<250 kWh total in the past 12 billing periods) were eliminated from the sampling frame. Eligible customers were then sorted by stratum and by average monthly billed energy (KWH\_MNTH) within stratum. The number of customers available in the sampling frame for each stratum was then divided by the number of recorders allocated to that stratum ( $N_h/n_h$ ), yielding the sampling interval size. A five digit random number between 0 and 1 was chosen for each stratum, and multiplied by the stratum interval size to obtain the starting selection point for each stratum (Table A). Beginning with this site, additional sites were selected at the given sampling intervals to obtain the desired number of sample sites. This procedure was repeated four times to provide a list of alternate selection sites.

The list of primary and alternate selection sites for this sample are contained in Appendix 1. This list was compared against current Utah profile metering installations to check for duplicates. Duplicates between the design and production systems were noted and updated in the Appendix.





Utah Residential Class Sample Parameters

Active Customers with kWh Meters  
For the 12 Months Ending February 2008

Stratum	1	2	3	4	5	6
Sampling Frame	351,800	254,648	53,961			
Sample	68	70	32			
Interval	5,173.53	3,637.83	1,686.28			
Random Starts						
Primary						
Random No. <sup>(1)</sup>	0.69548	0.18893	0.86783			
Start	3598	687	1463			
Alternate 1						
Random No. <sup>(1)</sup>	0.22927	0.83647	0.60988			
Start	1186	3043	1028			
Alternate 2						
Random No. <sup>(1)</sup>	0.37149	0.71481	0.21123			
Start	1922	2600	356			
Alternate 3						
Random No. <sup>(1)</sup>	0.19601	0.58823	0.98344			
Start	1014	2140	1658			
Alternate 4						
Random No. <sup>(1)</sup>	0.10190	0.69198	0.17559			
Start	527	2517	296			

<sup>(1)</sup> Random numbers from Excel's random function.

Table A

Utah Residential Class DH Worksheet  
Three Strata

Range	Customer Count	Interval $\mu$	Factor	$\mu f$	$\sqrt{\mu f}$	cum $\sqrt{\mu f}$	
0 to	250	45840	1	45840	214.1	214.1	
251 to	500	139998	1	139998	374.2	588.3	
501 to	750	165962	1	165962	407.4	995.7	351,800
751 to	1000	129682	1	129682	360.1	1,355.8	
1001 to	1250	81025	1	81025	284.6	1,640.4	
1251 to	1500	43941	1	43941	209.6	1,850.0	254,648
1501 to	1750	22773	1	22773	150.9	2,000.9	
1751 to	2000	12264	1	12264	110.7	2,111.7	
2001 to	2250	6856	1	6856	82.8	2,194.5	
2251 to	2500	3998	1	3998	63.2	2,257.7	
2501 to	2750	2343	1	2343	48.4	2,306.1	
2751 to	3000	1564	1	1564	39.5	2,345.7	
3001 to	3250	1026	1	1026	32.0	2,377.7	
3251 to	3500	678	1	678	26.0	2,403.7	
3501 to	3750	508	1	508	22.5	2,426.3	
3751 to	4000	337	1	337	18.4	2,444.6	
4001 to	4250	280	1	280	16.7	2,461.4	
4251 to	4500	213	1	213	14.6	2,476.0	
4501 to	4750	145	1	145	12.0	2,488.0	
4751 to	5000	138	1	138	11.7	2,499.7	
5001 to	5250	97	1	97	9.8	2,509.6	
5251 to	5500	74	1	74	8.6	2,518.2	
5501 to	5750	85	1	85	9.2	2,527.4	
5751 to	6000	54	1	54	7.3	2,534.8	
6001 to	6250	46	1	46	6.8	2,541.6	
6251 to	6500	48	1	48	6.9	2,548.5	
6501 to	6750	38	1	38	6.2	2,554.6	
6751 to	7000	33	1	33	5.7	2,560.4	
7001 to	7250	34	1	34	5.8	2,566.2	
7251 to	7500	23	1	23	4.8	2,571.0	
7501 to	7750	24	1	24	4.9	2,575.9	
7751 to	8000	25	1	25	5.0	2,580.9	
8001 to	8250	25	1	25	5.0	2,585.9	
8251 to	8500	11	1	11	3.3	2,589.2	
8501 to	8750	17	1	17	4.1	2,593.4	
8751 to	9000	11	1	11	3.3	2,596.7	
9001 to	9250	15	1	15	3.9	2,600.5	
9251 to	9500	11	1	11	3.3	2,603.9	
9501 to	9750	6	1	6	2.4	2,606.3	
9751 to	10000	12	1	12	3.5	2,609.8	
10001 to	12500	59	10	590	24.3	2,634.1	
12501 to	15000	33	10	330	18.2	2,652.2	
15001 to	17500	25	10	250	15.8	2,668.0	
17501 to	20000	6	10	60	7.7	2,675.8	
20001 to	22500	9	10	90	9.5	2,685.3	
22501 to	191500	17	676	11492	107.2	2,792.5	53,961
Total N		660,409					660,409

BOUNDARIES INDICATED FOR STRATA:

	3	4	5	6
1	930.8	698.1	558.5	465.4
2	1,861.6	1,396.2	1,117.0	930.8
3		2,094.4	1,675.5	1,396.2
4			2,234.0	1,861.6
5				2,327.1

SAMPLING ST/ Avg. kWh<sup>1</sup> Mean kW<sup>2</sup> St. Dev<sup>2</sup>

1	468.827	0.740	0.426
2	1,030.830	1.964	0.585
3	2,100.870	4.150	1.096
4			
5			
6			

<sup>1</sup> Billing records for March 2007 through February 2008

<sup>2</sup> Load Research data for January 2007 through December 2007

Table B.1

Utah Residential Class DH Worksheet  
Four Strata

Range	Customer Count	Interval	Factor	$f$	$\mu$	$\mu f$	$\sqrt{\mu f}$	cum $\sqrt{\mu f}$	
0 to	250	45840	1	45840		45840	214.1	214.1	
251 to	500	139998	1	139998		139998	374.2	588.3	185,838
501 to	750	165962	1	165962		165962	407.4	995.7	
751 to	1000	129682	1	129682		129682	360.1	1,355.8	295,644
1001 to	1250	81025	1	81025		81025	284.6	1,640.4	
1251 to	1500	43941	1	43941		43941	209.6	1,850.0	
1501 to	1750	22773	1	22773		22773	150.9	2,000.9	
1751 to	2000	12264	1	12264		12264	110.7	2,111.7	160,003
2001 to	2250	6856	1	6856		6856	82.8	2,194.5	
2251 to	2500	3998	1	3998		3998	63.2	2,257.7	
2501 to	2750	2343	1	2343		2343	48.4	2,306.1	
2751 to	3000	1564	1	1564		1564	39.5	2,345.7	
3001 to	3250	1026	1	1026		1026	32.0	2,377.7	
3251 to	3500	678	1	678		678	26.0	2,403.7	
3501 to	3750	508	1	508		508	22.5	2,426.3	
3751 to	4000	337	1	337		337	18.4	2,444.6	
4001 to	4250	280	1	280		280	16.7	2,461.4	
4251 to	4500	213	1	213		213	14.6	2,476.0	
4501 to	4750	145	1	145		145	12.0	2,488.0	
4751 to	5000	138	1	138		138	11.7	2,499.7	
5001 to	5250	97	1	97		97	9.8	2,509.6	
5251 to	5500	74	1	74		74	8.6	2,518.2	
5501 to	5750	85	1	85		85	9.2	2,527.4	
5751 to	6000	54	1	54		54	7.3	2,534.8	
6001 to	6250	46	1	46		46	6.8	2,541.6	
6251 to	6500	48	1	48		48	6.9	2,548.5	
6501 to	6750	38	1	38		38	6.2	2,554.6	
6751 to	7000	33	1	33		33	5.7	2,560.4	
7001 to	7250	34	1	34		34	5.8	2,566.2	
7251 to	7500	23	1	23		23	4.8	2,571.0	
7501 to	7750	24	1	24		24	4.9	2,575.9	
7751 to	8000	25	1	25		25	5.0	2,580.9	
8001 to	8250	25	1	25		25	5.0	2,585.9	
8251 to	8500	11	1	11		11	3.3	2,589.2	
8501 to	8750	17	1	17		17	4.1	2,593.4	
8751 to	9000	11	1	11		11	3.3	2,596.7	
9001 to	9250	15	1	15		15	3.9	2,600.5	
9251 to	9500	11	1	11		11	3.3	2,603.9	
9501 to	9750	6	1	6		6	2.4	2,606.3	
9751 to	10000	12	1	12		12	3.5	2,609.8	
10001 to	12500	59	10	590		590	24.3	2,634.1	
12501 to	15000	33	10	330		330	18.2	2,652.2	
15001 to	17500	25	10	250		250	15.8	2,668.0	
17501 to	20000	6	10	60		60	7.7	2,675.8	
20001 to	22500	9	10	90		90	9.5	2,685.3	
22501 to	191500	17	676	11492		11492	107.2	2,792.5	18,924
Total N		660,409							660,409

BOUNDARIES INDICATED FOR STRATA:

	3	4	5	6
1	930.8	698.1	558.5	465.4
2	1,861.6	1,396.2	1,117.0	930.8
3		2,094.4	1,675.5	1,396.2
4			2,234.0	1,861.6
5				2,327.1

SAMPLING ST/ Avg. kWh<sup>1</sup> Mean kW<sup>2</sup> St. Dev<sup>2</sup>

1	330.909	0.531	0.296
2	730.251	1.221	0.448
3	1,309.720	2.751	0.861
4	2,845.460	4.856	0.850
5			
6			

<sup>1</sup> Billing records for March 2007 through February 2008  
<sup>2</sup> Load Research data for January 2007 through December 2007

Table B.2

Utah Residential Class DH Worksheet

Five Strata

Range	Customer Count	Interval Factor	$\mu$	$\mu f$	$\sqrt{\mu f}$	cum $\sqrt{\mu f}$	
0 to 250	45840	1	125	45840	214.1	214.1	
251 to 500	139998	1	250	139998	374.2	588.3	185,838
501 to 750	165962	1	375	165962	407.4	995.7	165,962
751 to 1000	129682	1	500	129682	360.1	1,355.8	
1001 to 1250	81025	1	625	81025	284.6	1,640.4	210,707
1251 to 1500	43941	1	750	43941	209.6	1,850.0	
1501 to 1750	22773	1	875	22773	150.9	2,000.9	
1751 to 2000	12264	1	1000	12264	110.7	2,111.7	
2001 to 2250	6856	1	1125	6856	82.8	2,194.5	
2251 to 2500	3998	1	1250	3998	63.2	2,257.7	89,832
2501 to 2750	2343	1	1375	2343	48.4	2,306.1	
2751 to 3000	1564	1	1500	1564	39.5	2,345.7	
3001 to 3250	1026	1	1625	1026	32.0	2,377.7	
3251 to 3500	678	1	1750	678	26.0	2,403.7	
3501 to 3750	508	1	1875	508	22.5	2,426.3	
3751 to 4000	337	1	2000	337	18.4	2,444.6	
4001 to 4250	280	1	2125	280	16.7	2,461.4	
4251 to 4500	213	1	2250	213	14.6	2,476.0	
4501 to 4750	145	1	2375	145	12.0	2,488.0	
4751 to 5000	138	1	2500	138	11.7	2,499.7	
5001 to 5250	97	1	2625	97	9.8	2,509.6	
5251 to 5500	74	1	2750	74	8.6	2,518.2	
5501 to 5750	85	1	2875	85	9.2	2,527.4	
5751 to 6000	54	1	3000	54	7.3	2,534.8	
6001 to 6250	46	1	3125	46	6.8	2,541.6	
6251 to 6500	48	1	3250	48	6.9	2,548.5	
6501 to 6750	38	1	3375	38	6.2	2,554.6	
6751 to 7000	33	1	3500	33	5.7	2,560.4	
7001 to 7250	34	1	3625	34	5.8	2,566.2	
7251 to 7500	23	1	3750	23	4.8	2,571.0	
7501 to 7750	24	1	3875	24	4.9	2,575.9	
7751 to 8000	25	1	4000	25	5.0	2,580.9	
8001 to 8250	25	1	4125	25	5.0	2,585.9	
8251 to 8500	11	1	4250	11	3.3	2,589.2	
8501 to 8750	17	1	4375	17	4.1	2,593.4	
8751 to 9000	11	1	4500	11	3.3	2,596.7	
9001 to 9250	15	1	4625	15	3.9	2,600.5	
9251 to 9500	11	1	4750	11	3.3	2,603.9	
9501 to 9750	6	1	4875	6	2.4	2,606.3	
9751 to 10000	12	1	5000	12	3.5	2,609.8	
10001 to 12500	59	10	5000	590	24.3	2,634.1	
12501 to 15000	33	10	5000	330	18.2	2,652.2	
15001 to 17500	25	10	5000	250	15.8	2,668.0	
17501 to 20000	6	10	5000	60	7.7	2,675.8	
20001 to 22500	9	10	5000	90	9.5	2,685.3	
22501 to 191500	17	676	11492	17	107.2	2,792.5	8,070
Total N		660,409				660,409	

BOUNDARIES INDICATED FOR STRATA:

	3	4	5	6
1	930.8	698.1	558.5	465.4
2	1,861.6	1,396.2	1,117.0	930.8
3		2,094.4	1,675.5	1,396.2
4			2,234.0	1,861.6
5				2,327.1

SAMPLING ST#	Avg. kWh <sup>1</sup>	Mean kW <sup>2</sup>	St. Dev <sup>2</sup>
1	330.909	0.531	0.296
2	623.263	1.037	0.407
3	961.824	1.816	0.511
4	1,595.290	3.082	0.936
5	3,704.130	4.856	0.850
6			

1 Billing records for March 2007 through February 2008

2 Load Research data for January 2007 through December 2007

Table B.3

Utah Residential Class DH Worksheet  
Six Strata

Range	Customer Count	Interval $\mu$	Interval Factor	$f$	$\mu f$	$\sqrt{\mu f}$	cum $\sqrt{\mu f}$	
0 to	250	45840	1	45840	214.1	214.1		
251 to	500	139998	1	139998	374.2	588.3	185,838	
501 to	750	165962	1	165962	407.4	995.7	165,962	
751 to	1000	129682	1	129682	360.1	1,355.8	129,682	
1001 to	1250	81025	1	81025	284.6	1,640.4		
1251 to	1500	43941	1	43941	209.6	1,850.0	124,966	
1501 to	1750	22773	1	22773	150.9	2,000.9		
1751 to	2000	12264	1	12264	110.7	2,111.7		
2001 to	2250	6856	1	6856	82.8	2,194.5		
2251 to	2500	3998	1	3998	63.2	2,257.7		
2501 to	2750	2343	1	2343	48.4	2,306.1		
2751 to	3000	1564	1	1564	39.5	2,345.7	49,798	
3001 to	3250	1026	1	1026	32.0	2,377.7		
3251 to	3500	678	1	678	26.0	2,403.7		
3501 to	3750	508	1	508	22.5	2,426.3		
3751 to	4000	337	1	337	18.4	2,444.6		
4001 to	4250	280	1	280	16.7	2,461.4		
4251 to	4500	213	1	213	14.6	2,476.0		
4501 to	4750	145	1	145	12.0	2,488.0		
4751 to	5000	138	1	138	11.7	2,499.7		
5001 to	5250	97	1	97	9.8	2,509.6		
5251 to	5500	74	1	74	8.6	2,518.2		
5501 to	5750	85	1	85	9.2	2,527.4		
5751 to	6000	54	1	54	7.3	2,534.8		
6001 to	6250	46	1	46	6.8	2,541.6		
6251 to	6500	48	1	48	6.9	2,548.5		
6501 to	6750	38	1	38	6.2	2,554.6		
6751 to	7000	33	1	33	5.7	2,560.4		
7001 to	7250	34	1	34	5.8	2,566.2		
7251 to	7500	23	1	23	4.8	2,571.0		
7501 to	7750	24	1	24	4.9	2,575.9		
7751 to	8000	25	1	25	5.0	2,580.9		
8001 to	8250	25	1	25	5.0	2,585.9		
8251 to	8500	11	1	11	3.3	2,589.2		
8501 to	8750	17	1	17	4.1	2,593.4		
8751 to	9000	11	1	11	3.3	2,596.7		
9001 to	9250	15	1	15	3.9	2,600.5		
9251 to	9500	11	1	11	3.3	2,603.9		
9501 to	9750	6	1	6	2.4	2,606.3		
9751 to	10000	12	1	12	3.5	2,609.8		
10001 to	12500	59	10	590	24.3	2,634.1		
12501 to	15000	33	10	330	18.2	2,652.2		
15001 to	17500	25	10	250	15.8	2,668.0		
17501 to	20000	6	10	60	7.7	2,675.8		
20001 to	22500	9	10	90	9.5	2,685.3		
22501 to	191500	17	676	11492	107.2	2,792.5	4,163	
Total N		660,409					660,409	

BOUNDARIES INDICATED FOR STRATA:

	3	4	5	6
1	930.8	698.1	558.5	465.4
2	1,861.6	1,396.2	1,117.0	930.8
3		2,094.4	1,675.5	1,396.2
4			2,234.0	1,861.6
5				2,327.1

SAMPLING ST/ Avg. kWh<sup>1</sup> Mean kW<sup>2</sup> St. Dev<sup>2</sup>

1	330.909	0.531	0.296
2	623.263	1.037	0.407
3	867.171	1.536	0.330
4	1,200.660	2.372	0.473
5	1,889.330	3.885	0.959
6	4,631.280	5.475	0.769

<sup>1</sup> Billing records for March 2007 through February 2008

<sup>2</sup> Load Research data for January 2007 through December 2007

Table B.4

UTAH RESIDENTIAL CLASS LOAD STUDY DESIGN OPTION (2008)  
THREE STRATA, MEAN-PER-UNIT DESIGN

	a	b	c	d	e	f	g	h	i	j
	Sample Mean kW	Sample Mean kWh	2008 Pop N	Variance of Mean	Standard Deviation	Wtd. Devtms. c <sup>2</sup> e	Proprt. row f/ sum f	Optimal Allocation g <sup>2</sup> h total	Optimal with Attrition	Final with Attrition
STRATUM 1	0.740	468.827	351,800	0.1815	0.426	149867	0.4186	60	60	68
STRATUM 2	1.964	1,030.830	254,648	0.3422	0.585	148969	0.4161	60	60	70
STRATUM 3	4.150	2,100.870	53,961	1.2012	1.096	59141	0.1652	24	24	32
EST POP MEAN (wtd by N)	1.491	818.882	660,409			357977	1.0000	144	144	170

EST POP MEAN (wtd by N)

144

144

1.0000

357977

660,409

818.882

1.491

RELATIVE PRECISION OF SAMPLE KW ESTIMATE

	TOTAL KW Optimal n (col. h)	TOTAL KW Adjusted n (cc Final (col. J)	MEAN KW Adj. n
Variance contributed by strata:			
1	380,614,019	380,614,019	0.000873
2	376,043,356	376,043,356	0.000862
3	152,005,761	152,005,761	0.000349
4			
Total Variance	908,663,136	908,663,136	0.002083
Standard Error	30144.03981	30144.03981	0.045644502

Desired Conf. Level (z two tailed)	90%	90%
	1.645	1.645

Conf. Interval	49586.94549	45630.6922	0.075085206
MPU Est of kW	984398.822	984398.822	1.4906

Relative Conf. Int.	5.04%	4.64%	5.04%

Sample Estimate	Adj Sample Estimate
144	170

UTAH RESIDENTIAL CLASS LOAD STUDY DESIGN OPTION (2008)  
 FOUR STRATA, MEAN-PER-UNIT DESIGN

	a	b	c	d	e	f	g	h	i	j
	Sample Mean kW	Sample Mean kWh	2008 Pop N	Variance of Mean	Standard Deviation	Wtd. Devfns. c*e	Propn. row f/ sum f	Optimal Allocation g*h total	Optimal with Attrition	Final with Attrition
STRATUM 1	0.531	330,909	185,838	0.0876	0.296	55008	0.1612	21	21	23
STRATUM 2	1.221	730,251	295,644	0.2007	0.448	132,449	0.3881	50	50	55
STRATUM 3	2.751	1,309,720	160,003	0.7413	0.861	137,763	0.4036	52	52	57
STRATUM 4	4.856	2,845,460	18,924	0.7225	0.850	16,085	0.0471	6	10	11
EST POP MEAN (wtd by N)	1.502	818,881	660,409			341,305	1.0000	129	133	146

Sample Estimate	129
Adj Sample Estimate	146

RELATIVE PRECISION OF SAMPLE KW ESTIMATE

	TOTAL KW Optimal n (col. h)	TOTAL KW Adjusted n (cc Final (col. j)	MEAN KW Adj. n
Variance contributed by strata:	151,277,171	151,277,171	0.000347
1	357,951,867	357,951,867	0.000821
2	372,007,086	372,007,086	0.000853
3	51,731,612	28,733,707	0.000066
4			
Total Variance	932,967,735	909,969,831	0.002086
Standard Error	30544.52054	30165.70621	0.045677309
Desired Conf. Level (z two tailed)	90% 1.645	90% 1.645	90% 1.645
Conf. Interval	50245.73629	49622.58671	0.075139174
MPU Est of KW	991724.499	991724.499	1.5017
Relative Conf. Int.	5.07%	5.00%	4.77%
			5.00%



UTAH RESIDENTIAL CLASS LOAD STUDY DESIGN OPTION (2008)  
 FIVE STRATA, MEAN-PER-UNIT DESIGN

	a	b	c	d	e	f	g	h	i	j
	Sample Mean kW	Sample Mean kWh	2008 Pop N	Variance of Mean	Standard Deviation	Wtd. Devns. c'e	Proprtn. row // sum f	Optimal Allocation g'h total	Optimal with Attrition	Final with Attrition
STRATUM 1	0.531	330,909	185,838	0.0876	0.296	55008	0.1713	20	20	22
STRATUM 2	1.037	623,263	165,962	0.1656	0.407	67547	0.2103	24	24	26
STRATUM 3	1.816	961,824	210,707	0.2611	0.511	107671	0.3352	38	38	42
STRATUM 4	3.082	1,595,290	89,832	0.8761	0.936	84083	0.2618	30	30	33
STRATUM 5	4.856	3,704,130	8,070	0.7225	0.850	6860	0.0214	2	10	11
EST POP MEAN (wtd by N)	1.468	818,882	660,409			321168	1.0000	114	122	134

Sample Estimate	114
Adj Sample Estimate	134

RELATIVE PRECISION OF SAMPLE KW ESTIMATE

	TOTAL KW Optimal n (col. h)	TOTAL KW Adjusted n (cc Final (col. j)	MEAN KW Adj. n
Variance contributed by strata:	159,239,984	144,072,721	0.000365
1	198,342,368	182,472,779	0.000455
2	313,270,625	282,702,270	0.000718
3	243,708,557	220,853,501	0.000559
4	47,041,079	5,221,604	0.000012
5	961,602,613	919,783,137	0.002109
Total Variance	31009.71804	28892.90797	0.045922946
Standard Error			
Desired Conf. Level (z two tailed)	90% 1.645	90% 1.645	90% 1.645
Conf. Interval	51010.98617	49889.43941	47528.8336
MPU Est of kW	969476.628	969476.628	969476.628
Relative Conf. Int.	5.26%	5.15%	4.90%
			5.15%

UTAH RESIDENTIAL CLASS LOAD STUDY DESIGN OPTION (2008)  
SIX STRATA, MEAN-PER-UNIT DESIGN

	a	b	c	d	e	f	g	h	i	j
	Sample Mean kW	Sample Mean kWh	2008 Pop N	Variance of Mean	Standard Deviation	Wtd. Devns. c <sup>e</sup>	Proprtn. row / sum f	Optimal Allocation g <sup>h</sup> total	Optimal with Attrition	Final with Attrition
STRATUM 1	0.531	330.909	185,838	0.0876	0.296	55008	0.1997	11	11	12
STRATUM 2	1.037	623.263	165,962	0.1656	0.407	67547	0.2453	14	14	15
STRATUM 3	1.536	867.171	129,682	0.1089	0.330	42795	0.1554	9	10	11
STRATUM 4	2.372	1,200.660	124,966	0.2237	0.473	59109	0.2146	12	12	13
STRATUM 5	3.885	1,889.330	49,798	0.9197	0.959	47756	0.1734	10	10	11
STRATUM 6	5.475	4,631.280	4,163	0.5914	0.769	3201	0.0116	1	10	11
EST POP MEAN (wtd by N)	1.488	818.881	660,409			275416	1.0000	57	67	73

Sample Estimate	57
Adj Sample Estimate	73


RELATIVE PRECISION OF SAMPLE KW ESTIMATE

	TOTAL KW Optimal n (col. h)	TOTAL KW Adjusted n (col. Final)	TOTAL KW (col. J)	MEAN KW Adj. n
Variance 1	302,570,624	302,570,624	275,062,723	0.000694
contributed 2	350,934,567	350,934,567	325,865,849	0.000805
by strata: 3	228,911,257	203,475,104	183,126,181	0.000467
4	317,593,517	317,593,517	291,125,061	0.000728
5	253,356,054	253,356,054	228,015,869	0.000581
6	#DIV/0!	1,136,000	1,022,154	0.000003
Total Variance	#DIV/0!	1,429,065,867	1,304,217,837	0.003277
Standard Error	#DIV/0!	37802.98754	36113.95627	0.057241781

Desired Conf. Level (z two tailed)	90%	90%	90%
	1.645	1.645	1.645

Conf. Interval	#DIV/0!	62185.9145	59407.45806	0.09416273
MPU Est of kW	982651.131	982651.131	982651.131	1.4879

Relative Conf. Int.	#DIV/0!	6.33%	6.05%	6.33%
---------------------	---------	-------	-------	-------



Utah Residential Class kWh Summary  
For the Twelve months Ended December2007

N	MIN	MEAN	MAX	SUM
660409	20.9167	818.882	191500	540796854.04

03APR08 12:42

Utah Residential Class Bill Frequency Worksheet  
Average Monthly kWh

STRATUM	n	KWH
0 - 250 kWh	45840	7509948.49
251 - 500 kWh	139998	53985586.66
501 - 750 kWh	165962	103437896.36
751 - 1000 kWh	129682	112456520.23
1001 - 1250 kWh	81025	90206547.53
1251 - 1500 kWh	43941	59835563.13
1501 - 1750 kWh	22773	36686977.15
1751 - 2000 kWh	12264	22830329.69
2001 - 2250 kWh	6856	14492072.30
2251 - 2500 kWh	3998	9463095.36
2501 - 2750 kWh	2343	6125608.02
2751 - 3000 kWh	1564	4486683.57
3001 - 3250 kWh	1026	3202038.35
3251 - 3500 kWh	678	2281935.09
3501 - 3750 kWh	508	1836899.27
3751 - 4000 kWh	337	1303927.13
4001 - 4250 kWh	280	1155249.81
4251 - 4500 kWh	213	932379.14
4501 - 4750 kWh	145	669736.20
4751 - 5000 kWh	138	673522.79
5001 - 5250 kWh	97	495987.23
5251 - 5500 kWh	74	397539.55
5501 - 5750 kWh	85	477757.11
5751 - 6000 kWh	54	317909.17
6001 - 6250 kWh	46	281581.05
6251 - 6500 kWh	48	305877.22
6501 - 6750 kWh	38	251518.36
6751 - 7000 kWh	33	227053.26
7001 - 7250 kWh	34	242173.67
7251 - 7500 kWh	23	169887.46
7501 - 7750 kWh	24	183252.58
7751 - 8000 kWh	25	196815.58
8001 - 8250 kWh	25	202818.18
8251 - 8500 kWh	11	92142.44
8501 - 8750 kWh	17	146845.17
8751 - 9000 kWh	11	97612.48
9001 - 9250 kWh	15	136756.35
9251 - 9500 kWh	11	103161.21
9501 - 9750 kWh	6	57812.95
9751 - 10000 kWh	12	119141.10
10001 - 12500 kWh	59	662486.64
12501 - 15000 kWh	33	450447.31
15001 - 17500 kWh	25	402011.56
17501 - 20000 kWh	6	112065.00
20001 - 22500 kWh	9	194625.69
GT 22501 kWh	17	899059.42

Utah Residential Class Billing Statistics  
Mean kWh - Three Strata

----- STRATUM=1 -----	
N	KWH_MEAN
351800	468.827

----- STRATUM=2 -----	
N	KWH_MEAN
254648	1030.83

----- STRATUM=3 -----	
N	KWH_MEAN
53961	2100.87

Utah Residential Class Billing Statistics  
Mean kWh - Four Strata

----- STRATUM=1 -----	
N	KWH_MEAN
185838	330.909
----- STRATUM=2 -----	
N	KWH_MEAN
295644	730.251
----- STRATUM=3 -----	
N	KWH_MEAN
160003	1309.72
----- STRATUM=4 -----	
N	KWH_MEAN
18924	2845.46

Utah Residential Class Billing Statistics  
Mean kWh - Five Strata

----- STRATUM=1 -----

N	KWH_MEAN
185838	330.909

----- STRATUM=2 -----

N	KWH_MEAN
165962	623.263

----- STRATUM=3 -----

N	KWH_MEAN
210707	961.824

----- STRATUM=4 -----

N	KWH_MEAN
89832	1595.29

----- STRATUM=5 -----

N	KWH_MEAN
8070	3704.13



Utah Residential Class Billing Statistics  
Mean kWh - Six Strata

----- STRATUM=1 -----	
N	KWH_MEAN
185838	330.909
----- STRATUM=2 -----	
N	KWH_MEAN
165962	623.263
----- STRATUM=3 -----	
N	KWH_MEAN
129682	867.171
----- STRATUM=4 -----	
N	KWH_MEAN
124966	1200.66
----- STRATUM=5 -----	
N	KWH_MEAN
49798	1889.33
----- STRATUM=6 -----	
N	KWH_MEAN
4163	4631.28

Utah Residential Class Eligible Sample Point Summary  
Annual kWh GT 250, Agreement Status=ACT

----- STRATUM=0 - 750 kWh -----

The MEANS Procedure

Analysis Variable : KWH\_MNTH Billed Usage

N	Mean
351800	468.8272641

----- STRATUM=751 - 1,500 kWh -----

Analysis Variable : KWH\_MNTH Billed Usage

N	Mean
254648	1030.83

----- STRATUM=GT 1,500 kWh -----

Analysis Variable : KWH\_MNTH Billed Usage

N	Mean
53961	2100.87

Attach UIEC 20.5 -2.pdf

# Utah Schedule 006 (2008) Load Recorder Study Sampling Procedures

This paper describes the procedures used to develop the 2008 Utah Schedule 006 sample. This study will provide load data for use in support of cost studies and price filings before the Utah Public Service Commission, and for use in other studies of schedule 006 customer demand characteristics. The goal of the sample design is to provide relative precision of  $\pm 10\%$  at the 90% confidence level for an estimate of the average of the system peak hours, during twelve consecutive months.

Recorders will be placed in service effective no later than December 31<sup>st</sup> 2008, and will be monitored on a continuous basis to insure no significant deviation from billing records.

## Sampling Plan for Utah

The sampling plan includes several steps:

1. Formalization of the sample parameters;
2. Specification of the target variable;
3. Choice of the stratification variable;
4. Choice of method for estimating kW;
5. Choice of the number of strata;
6. Construction of the strata boundaries
7. Allocation of sample points to each stratum;
8. Selection of primary sample sites;
9. Selection of alternate sample sites.

### **Formalization of the sample parameters**

This sample replaces the old Utah Schedule 006 sample, which has been in the field since 1991. There is no secondary/primary voltage breakdown in the tariff and, accordingly, only one load sample is required to provide load estimates for this group.

### **Specification of the target variable**

Load studies in the state of Utah are used primarily to support cost allocation studies. Current cost study methods use the average demand at the hours of the PacifiCorp system peak for twelve consecutive months (12SYSPK), as well as estimates of distribution and individual customer maximum demands, each averaged over twelve consecutive months.

These study designs treat 12SYSPK as the target variable because it is, by far, the most important peak measure for allocation of demand related costs.

The current Utah Schedule 006 study was used to provide estimates of means and residual variances required in these sample designs. Billing data for the 12 months ending April 2008 was used to determine appropriate stratification.

### **Choice of the Stratification Variable**

A potential stratifying variable, according to Cochran, should meet three criteria<sup>1</sup>:

1. *The population is composed of institutions varying widely in size.*
2. *The principle variables to be measured are closely related to the sizes of the institutions.*
3. *A good measure of size is available for setting up the strata.*

Peak monthly billing kW (KW\_MNTH), which is the maximum demand registered for a given year, was selected as the best available variable for this purpose. This is a fairly stable variable within the schedule 006, and will result in a minimum amount of strata migration among the sample customers. It is accessible for all schedule 006 customers and can range from 0 to 999 kW for this customer group.

### **Choice of Method for Estimating kW**

To estimate a peak demand for a population using MPU, the mean peak demand value from the sample is multiplied by the number of elements in the entire population. Use of the MPU method provides an unbiased estimate.

For ratio estimation, the ratio of the target variable (12SYSPK) over the auxiliary variable (KWH\_ANN) is calculated for the sample. This ratio is then multiplied by the total annual billed kWh for the population to get the estimated total group peak demand. Because energy usage and peak demand are correlated, a ratio estimate will have a smaller variance than a MPU estimate. However, a ratio estimate may be slightly biased.

With stratified sample designs, ratio estimators can be computed in two ways: separately for each stratum, or a combined ratio can be computed over all strata. Separate ratio estimation tends to result in smaller variance. However, the combined ratio method is more appropriate when stratum sample sizes are small, because the risk of bias is reduced.

Table C shows sample size needed for the Utah Schedule 006 study using a mean-per-unit method, assuming a three strata design. All sample designs assume optimal allocation utilizing the Tschprow/Neyman method. The design as presented in Table B was selected for this sample.

---

<sup>1</sup> William G. Cochran, "Sampling Techniques", Third Edition, Wiley, pg.101

### **Choice of the Number of Strata**

As the number of strata increases, precision of the estimate of the total contribution to demand (kW) at system peak also increases. However, the increase in precision per additional stratum diminishes after a relatively small number of strata<sup>2</sup>. Desire for simplicity and for a reasonable number of sites in each stratum lead to a preference for a small number of strata. If a minimum number of sites policy is followed (eg. 10 sites minimum per stratum), then the addition of strata can actually lead to more, rather than fewer, total sites. If such a policy is not followed, the result can be strata with so few recorders that confidence in sample estimates is at risk from unexpected data problems, variance estimates may not be sufficiently precise for future sample design purposes, and the sample may not be robust enough to be useful when analysis needs change.

A final decision on the number of strata requires actual cost comparison of potential stratification schemes to evaluate effectiveness versus cost. For this study, a three strata scheme was employed (Table B). The method described below was used to compare stratification approaches.

### **Construction of Strata Boundaries**

Various methods might be used for definition of strata boundaries. Cochran found the “cumulative square root of  $f$ ”<sup>3</sup> rule, as defined by Dalenius and Hodges (1959), to be superior in a comparative study of such methods applied to actual distributions exhibiting a range of skewness.

Steps in calculating strata boundaries under the “cumulative square root of  $f$ ” rule are as follows. First, tabulate frequencies of the stratifying variable. For these studies, peak monthly demand (KW\_MNTH) from customer billing records 12 months ending April 2008 were used. All Utah Schedule 006 customers, regardless of end of year status (active/inactive) or annual consumption were included in this procedure, and in population figures for the sample design. Second, multiply the number of customers in each interval by the interval factor. Third, take the square root of these frequencies. Fourth, cumulatively sum the square roots. The resulting distribution of adjusted cumulative square roots of frequency is then partitioned into equal intervals by dividing by the number of strata. The final stratification scheme of three strata is presented in Table B, and shows the optimal boundaries resulting from the above procedure, after adjustments made to accommodate prior cost analysis requirements.

---

<sup>2</sup> William G. Cochran, “Sampling Techniques”, Third Edition, Wiley, Pg. 132

<sup>3</sup> William G. Cochran, “Sampling Techniques”, Third Edition, Wiley, Pgs. 129-130

### **Allocation of Sample Points to Each Stratum**

Once the stratum boundaries have been determined, sample points (i.e., load recorders) must be assigned to the strata. The Tschprow-Neyman allocation procedure<sup>4</sup> allocates an optimal sampling rate to each stratum. Optimal allocation techniques minimize the variance of the population estimates by increasing the sample proportion in the strata having larger variances. This produces a sampling rate for each stratum which is proportional to the standard deviation within the stratum. The analogous procedure for a ratio sampling plan is allocation in proportion to the square root of the residual variance.

Data for estimating the variance of the 12SYSPK measure for each stratum were available for customers included in the current Utah Schedule 006 load study. These data were used to provide estimates for the new Utah Schedule 006 sample design. For the mean-per-unit method, the variance within each stratum was the ordinary variance of the mean.

Minimum recorder allocations and data loss adjustments are required for each stratum to maintain adequate data in case of recorder failure and to provide data for analysis of load characteristics other than the primary target variable, should such analysis be necessary. Minimums ranging from 5 to 15 sites per stratum have been used in past studies. In the present studies, a minimum of 10 sites was used. A minimum on the high side was selected, despite improvements in data quality due to solid state recording equipment, because changing requirements for load research and other areas using this data may require unanticipated applications, and because overall sample efficiencies are bringing these studies in well below the budgeted number of sites, even with the 10 site minimum. The final allocation of recorders reflected an additional twelve percent data loss adjustment per stratum over the optimal or minimum allocation.

The three strata design selected the installation of 83 recorders to meet PURPA design standards. This design was supplemented with an additional 25 recorders, which translates to  $\pm 8.83\%$  precision at the 90% confidence level.

### **Sample Selection**

Systematic sample selections were used for each stratum to ensure a representative distribution. For practical reasons, inactive customers, customers with no kWh meter installed (usually certain types of lighting customers with very predictable demand and consumption, indicated by absence of a kWh meter number), and customers with very

---

<sup>4</sup> William G. Cochran, "Sampling Techniques", Third Edition, Wiley, pgs. 96-99

low consumption (<250 kWh in the past 12 billing periods) were eliminated from the sampling frame. Eligible customers were then sorted by stratum and by peak monthly billed demand (KW\_MNTH) within stratum. The number of customers available in the sampling frame for each stratum was then divided by the number of recorders allocated to that stratum, yielding the sampling interval size. A five digit random number between 0 and 1 was chosen for each stratum, and multiplied by the stratum interval size to obtain the starting selection point for each stratum (Table A). Beginning with this site, additional sites were selected at the given intervals to obtain the desired number of sample sites. This procedure was repeated four times to provide a list of alternate selection sites.

The list of primary and alternate selection sites for this sample are contained in Appendix 1. This list was compared against current Utah profile metering installations to check for duplicates. Duplicates between the design and production systems were noted and updated in the Appendix.



Utah Schedule 006 Sample Parameters

Active Customers with kW Meters  
12 Months Ending April 2008 History

Stratum	1	2	3	4	5
Sampling Frame	9,349	4,140	1,232		
Sample	29	36	43		
Interval	322.38	115.00	28.65		
Random Starts					
Primary					
Random No. <sup>(1)</sup>	0.973457	0.190079	0.935239		
Start	314	22	27		
Alternate 1					
Random No. <sup>(1)</sup>	0.599504	0.937419	0.388758		
Start	193	108	11		
Alternate 2					
Random No. <sup>(1)</sup>	0.665786	0.251345	0.769783		
Start	215	29	22		
Alternate 3					
Random No. <sup>(1)</sup>	0.869928	0.226317	0.661234		
Start	280	26	19		
Alternate 4					
Random No. <sup>(1)</sup>	0.394018	0.896363	0.174696		
Start	127	103	5		

<sup>(1)</sup> Random numbers from Excel's random function.

Utah Schedule 006  
Three Strata  
Customer Interval  
Count Factor

Range	f	$\mu$	$\mu f$	$\sqrt{\mu f}$	cum $\sqrt{\mu f}$
0 to 5	238	1	238	15.4	15.4
6 to 10	183	1	183	13.5	29.0
11 to 15	247	1	247	15.7	44.7
16 to 20	318	1	318	17.8	62.5
21 to 25	428	1	428	20.7	83.2
26 to 30	890	1	890	29.8	113.0
31 to 35	1416	1	1416	37.6	150.7
36 to 40	1217	1	1217	34.9	185.5
41 to 45	1143	1	1143	33.8	219.3
46 to 50	987	1	987	31.4	250.8
51 to 55	800	1	800	28.3	279.0
56 to 60	591	1	591	24.3	303.4
61 to 65	468	1	468	21.6	325.0
66 to 70	423	1	423	20.6	345.6
71 to 75	328	1	328	18.1	363.7
76 to 80	315	1	315	17.7	381.4
81 to 85	273	1	273	16.5	397.9
86 to 90	252	1	252	15.9	413.8
91 to 95	225	1	225	15.0	428.8
96 to 100	222	1	222	14.9	443.7
101 to 110	378	2	756	27.5	471.2
111 to 120	273	2	546	23.4	494.6
121 to 130	238	2	476	21.8	516.4
131 to 140	237	2	474	21.8	538.2
141 to 150	178	2	356	18.9	557.0
151 to 160	178	2	356	18.9	575.9
161 to 170	156	2	312	17.7	593.6
171 to 180	148	2	296	17.2	610.8
181 to 190	120	2	240	15.5	626.3
191 to 200	119	2	238	15.4	641.7
201 to 225	277	5	1385	37.2	678.9
226 to 250	223	5	1115	33.4	712.3
251 to 275	176	5	880	29.7	742.0
276 to 300	150	5	750	27.4	769.3
301 to 325	115	5	575	24.0	793.3
326 to 350	105	5	525	22.9	816.2
351 to 375	101	5	505	22.5	838.7
376 to 400	67	5	335	18.3	857.0
401 to 450	107	10	1070	32.7	889.7
451 to 500	98	10	980	31.3	921.0
501 to 550	76	10	760	27.6	948.6
551 to 600	57	10	570	23.9	972.5
601 to 650	45	10	450	21.2	993.7
651 to 700	45	10	450	21.2	1,014.9
701 to 750	29	10	290	17.0	1,031.9
751 to 800	34	10	340	18.4	1,050.4
801 to 850	14	10	140	11.8	1,062.2
851 to 900	10	10	100	10.0	1,072.2
901 to 950	3	10	30	5.5	1,077.7
951 to 1000	0	10	0	0.0	1,077.7
Total N	14,721				14,721

BOUNDARIES INDICATED FOR STRATA:

	3	4	5	6
1	359.2	269.4	215.5	179.6
2	718.5	538.8	431.1	359.2
3		808.3	646.6	538.8
4			862.1	718.5
5				898.1

SAMPLING ST,	Avg. kWh <sup>1</sup>	Mean kW <sup>2</sup>	St. Dev <sup>2</sup>
1	7,963.3	19.9	16.6
2	45,274.7	75.8	47.4
3	162,858.9	402.4	180.5
4			
5			
6			

<sup>1</sup> Billing records for 12 months ending April 2008.

<sup>2</sup> Load Research data for 12 months ending December 2007.

Table B

UTAH SCHEDULE 006 LOAD STUDY DESIGN OPTION (2008)  
THREE STRATA, MEAN-PER-UNIT DESIGN

	a	b	c	d	e	f	g	h	i	j
	Sample Mean kW	Sample Mean kWh	2008 Pop N	Variance of Mean	Standard Deviation	Wtd. Devms. c'e	Proprt. row / sum f	Optimal Allocation g'h total	Optimal with Attrition	Final with Attrition
STRATUM 1	0 - 70 kW	19,2746	9,349	203,7063	14,2726	133434	0.2538	21	21	29
STRATUM 2	71 - 250 kW	86,8943	4,140	1825,8427	42,7299	176902	0.3365	28	28	36
STRATUM 3	GT 250 kW	330,8006	1,232	30575,8649	174,8596	215427	0.4097	34	34	43
EST POP MEAN (wtd by N)		64,3630	32,485	14,721		525763	1,0000	83	83	108

RELATIVE PRECISION OF SAMPLE KW ESTIMATE

	TOTAL KW Optimal n (col. h)	TOTAL KW Adjusted n (col. i Final (col. j	TOTAL KW MEAN KW Adj. n
Variance contributed by strata:	1 888,235,672	888,235,672	4,098770
	2 1,151,206,014	1,151,206,014	5,312249
	3 1,367,515,749	1,367,515,749	6,310412
	4		
Total Variance	3,406,957,435	3,406,957,435	15,721431
Standard Error	58369.14797	58369.14797	3,965026015
Desired Conf. Level (z two tailed)	90% 1.645	90% 1.645	90% 1.645
Conf. Interval	96017,24841	96017,24841	6,522467795
MPU Est of kW	947487.0757	947487.0757	64,3630
Relative Conf. Int.	10.13%	10.13%	8.83% 10.13%

Table C

UTAH SCHEDULE 006 LOAD STUDY DESIGN OPTION (2008)  
 FOUR STRATA, MEAN-PER-UNIT DESIGN

	a	b	c	d	e	f	g	h	i	j
	Sample Mean kW	Sample Mean kWh	2008 Pop N	Variance of Mean	Standard Deviation	Wtd. Devths. c*e	Proprtn. row ff sum f	Optimal Allocation g*h total	Optimal with Attrition	Final with Attrition
STRATUM 1	0 - 50 kW	15.2094	8,986	7,067	133,0257	11,5337	0.1798	11	11	12
STRATUM 2	51 - 140 kW	53.3991	25,098	5,023	460,2787	21,4541	0.2377	15	15	17
STRATUM 3	141 - 325 kW	145.5156	74,109	1,840	4908,6817	70,0620	0.2843	18	18	20
STRATUM 4	GT 325 kW	379.9563	192,577	791	29239,2990	170,9950	0.2983	19	19	21
EST POP MEAN (wtd by N)		64.1263	32,488	14,721		453444	1,0000	62	63	70

Sample Estimate	62
Adj Sample Estimate	70

RELATIVE PRECISION OF SAMPLE KW ESTIMATE

	TOTAL KW Optimal n (col. h)	TOTAL KW Adjusted n (col. Final)	TOTAL KW Final (col. J)	MEAN KW Adj. n
Variance contributed by strata:				
1	663,329,182	663,329,182	602,941,066	3,060938
2	827,028,314	827,028,314	723,360,777	3,816329
3	968,015,128	968,015,128	865,188,064	4,466913
4	991,946,469	991,946,469	890,438,993	4,577345
Total Variance	3,450,319,092	3,450,319,092	3,081,908,901	15,921524
Standard Error	58739.41685	58739.41685	55514.94304	3.990178443
Desired Conf. Level (z two tailed)	90% 1.645	90% 1.645	90% 1.645	90% 1.645
Conf. Interval	96626.34072	96626.34072	91322.0813	6.563843538
MPU Est of KW	944002.7944	944002.7944	944002.7944	64.1263
Relative Conf. Int.	10.24%	10.24%	9.67%	10.24%

Table C.2

Attach UIEC 20.5 -3.pdf

## Utah Schedule 023 (2008) Load Recorder Study Sampling Procedures

This paper describes the procedures used to develop the 2008 Utah Schedule 023 Load Study. This study will provide load data for use in support of cost studies and price filings before the Utah Public Service Commission, and for use in other studies of commercial customer demand characteristics. The goal of this sample design is to provide relative precision of  $\pm 10\%$  at the 90% confidence level for an estimate of the average of the twelve monthly system peak hours, during twelve consecutive months.

Recorders will be placed in service effective no later than October 1<sup>st</sup>, 2008, and will be monitored on a continuous basis to insure no significant deviation from billing records.

### Sampling Plan for Utah

This sampling plan includes several steps:

1. Formalization of the sample parameters;
2. Specification of the target variable;
3. Choice of the stratification variable;
4. Choice of method for estimating kW;
5. Choice of the number of strata;
6. Construction of the strata boundaries
7. Allocation of sample points to each stratum;
8. Selection of primary sample sites;
9. Selection of alternate sample sites.

#### **Formalization of the sample parameters**

This sample replaces the old Utah Commercial schedule 023 sample, which was originally installed in 1991, and later refreshed in 2003. There is no secondary/primary voltage breakdown in the tariff and, accordingly, only one load sample is required to provide load estimates for this group.

#### **Specification of the target variable**

Load studies in the state of Utah are used primarily to support cost allocation studies. Current cost study methods use the average demand at the hours of the PacifiCorp system peak for twelve consecutive months (12SYSPK), as well as estimates of distribution and individual customer maximum demands, each averaged over twelve consecutive months.

These study designs treat 12SYSPK as the target variable because it is, by far, the most important peak measure for allocation of demand related costs.

The current Utah schedule 023 study was used to provide estimates of means and residual variances required in these sample designs. The range of sample data employed encompassed the twelve month period from January 2007 through December 2007. Billing data for the twelve months ending February 2008 were used to determine appropriate stratification.

### **Choice of the Stratification Variable**

A potential stratifying variable, according to Cochran, should meet three criteria<sup>1</sup>:

1. *The population is composed of institutions varying widely in size.*
2. *The principle variables to be measured are closely related to the sizes of the institutions.*
3. *A good measure of size is available for setting up the strata.*

Average monthly billing kWh (KWH\_MNTH), which is the average monthly energy registered over a twelve consecutive month period, was selected as the best available variable for this purpose. It is readily available for all customers in this class, with a range from 0 to 46,040 kWh for any given customer in this group.

### **Choice of Method for Estimating kW**

To estimate a peak demand for a population using MPU, the mean peak demand value from the sample is multiplied by the number of elements in the entire population. Use of the MPU method provides an unbiased estimate.

For ratio estimation, the ratio of the target variable (12SYSPK) over the auxiliary variable (KWH\_ANN) is calculated for the sample. This ratio is then multiplied by the total annual billed kWh for the population to get the estimated total group peak demand. Because energy usage and peak demand are correlated, a ratio estimate will have a smaller variance than a MPU estimate. However, a ratio estimate may be slightly biased.

With stratified sample designs, ratio estimators can be computed in two ways: separately for each stratum, or a combined ratio can be computed over all strata. Separate ratio estimation tends to result in smaller variance. However, the combined ratio method is more appropriate when stratum sample sizes are small, because the risk of bias is reduced.

Tables C.1 shows sample size needed for the Utah Schedule 023 study using a mean-per-unit method, assuming a three strata design, with optimal allocation utilizing the Tschprow/Neyman method. Table C.2 details the same information in a four strata schema. The design as presented in Table C.1 was selected for this sample.

---

<sup>1</sup> William G. Cochran, "Sampling Techniques", Third Edition, Wiley, pg.101

### **Choice of the Number of Strata**

As the number of strata increases, precision of the estimate of the total contribution to demand (kW) at system peak also increases. However, the increase in precision per additional stratum diminishes after a relatively small number of strata<sup>2</sup>. Desire for simplicity, and for a reasonable number of sites in each stratum lead to a preference for a small number of strata. If a minimum number of sites policy is followed (eg. 10 sites minimum per stratum), then the addition of strata can actually lead to more, rather than fewer, total sites. If such a policy is not followed, the result can be strata with so few recorders that confidence in sample estimates is at risk from unexpected data problems, variance estimates may not be sufficiently precise for future sample design purposes, and the sample may not be robust enough to be useful when analysis needs change.

A final decision on the number of strata requires actual cost comparison of potential stratification schemes to evaluate effectiveness versus cost. For this study, a three strata scheme was employed. The method described below was used to compare stratification approaches.

### **Construction of Strata Boundaries**

Various methods might be used for definition of strata boundaries. Cochran found the “cumulative square root of  $f$ ”<sup>3</sup> rule, as defined by Dalenius and Hodges (1959), to be superior in a comparative study of such methods applied to actual distributions exhibiting a range of skewness.

Steps in calculating strata boundaries under the “cumulative square root of  $f$ ” rule are as follows. First, tabulate frequencies of the stratifying variable. For these studies, average monthly energy (KWH\_MNTH) from customer billing records for the twelve months ending February 2008 were used. All Utah schedule 023 customers, whose end of year status was active, and whose total annual kWh consumption was greater than 250 kWh were included in this procedure, and in population figures for the sample design. Second, multiply the number of customers in each interval by the interval factor. Third, take the square root of these frequencies. Fourth, cumulatively sum the square roots. The resulting distribution of adjusted cumulative square roots of frequency is then partitioned into equal intervals by dividing by the number of strata. The final stratification scheme of three strata is presented in Table B.1, and shows the optimal boundaries resulting from

---

<sup>2</sup> William G. Cochran, “Sampling Techniques”, Third Edition, Wiley, Pg. 132

<sup>3</sup> William G. Cochran, “Sampling Techniques”, Third Edition, Wiley, Pgs. 129-130



the above procedure, after adjustments made to accommodate prior cost analysis requirements (if any).

### Allocation of Sample Points to Each Stratum

Once the stratum boundaries have been determined, sample points (i.e., load recorders) must be assigned to the strata. The Tschprow-Neyman allocation procedure<sup>4</sup> allocates an optimal sampling rate to each stratum. Optimal allocation techniques minimize the variance of the population estimates by increasing the sample proportion in the strata having larger variances. This produces a sampling rate for each stratum which is proportional to the standard deviation within the stratum. The analogous procedure for a ratio sampling plan is allocation in proportion to the square root of the residual variance.

Data for estimating the variance of the 12SYSPK measure for each stratum were available for customers included in the current Utah schedule 023 load study. These data were used to provide estimates for the new Utah schedule 023 sample design. For the mean-per-unit method, the variance within each stratum was the ordinary variance of the mean.

Minimum recorder allocations and data loss adjustments are required for each stratum to maintain adequate data in case of recorder failure and to provide data for analysis of load characteristics other than the primary target variable, should such analysis be necessary. Minimums ranging from 5 to 15 sites per stratum have been used in past studies. In the present studies, a minimum of 10 sites was used. A minimum on the high side was selected, despite improvements in data quality due to solid state recording equipment, because changing requirements for load research and other areas using this data may require unanticipated applications, and because overall sample efficiencies are bringing these studies in well below the budgeted number of sites, even with the 10 site minimum. The final allocation of recorders reflected an additional ten percent data loss adjustment per stratum over the optimal or minimum allocation.

Because of a desire to materially reduce the desired precision target level, the decision was made to substantially increase the number of sites to be installed vs. the sample design. The three strata design requires the installation of 68 recorders to meet design standards. This design was supplemented with an additional 7 recorders, which translates to  $\pm 9.67\%$  precision at the 90% confidence level.

---

<sup>4</sup> William G. Cochran, "Sampling Techniques", Third Edition, Wiley, pgs. 96-99

### Sample Selection

Systematic sample selections were used for each stratum to ensure a representative distribution. For practical reasons, inactive customers, customers with no kWh meter installed (usually certain types of lighting customers with very predictable demand and consumption, indicated by absence of a kWh meter number), and customers with very low consumption (<250 kWh total in the past 12 billing periods) were eliminated from the sampling frame. Eligible customers were then sorted by stratum and by average monthly billed energy (KWH\_MNTH) within stratum. The number of customers available in the sampling frame for each stratum was then divided by the number of recorders allocated to that stratum ( $N_h/n_h$ ), yielding the sampling interval size. A five digit random number between 0 and 1 was chosen for each stratum, and multiplied by the stratum interval size to obtain the starting selection point for each stratum (Table A). Beginning with this site, additional sites were selected at the given sampling intervals to obtain the desired number of sample sites. This procedure was repeated four times to provide a list of alternate selection sites.

The list of primary and alternate selection sites for this sample are contained in Appendix 1. This list was compared against current Utah profile metering installations to check for duplicates. Duplicates between the design and production systems if any, were noted and updated in the Appendix.

1

100

2

100

3

100

4

100

5

100

6

100

7

100

8

100

9

100

100

Utah Commercial 023 Sample Parameters

Active Customers with kWh Meters  
For the 12 Months Ending February 2008

Stratum	1	2	3	4	5	6
Sampling Frame	38,769	17,360	4,792			
Sample	29	33	13			
Interval	1,336.86	526.06	368.62			
Random Starts						
Primary						
Random No. <sup>(1)</sup>	0.77058	0.74693	0.87889			
Start	1030	393	324			
Alternate 1						
Random No. <sup>(1)</sup>	0.73299	0.42598	0.99982			
Start	980	224	369			
Alternate 2						
Random No. <sup>(1)</sup>	0.66732	0.29197	0.35048			
Start	892	154	129			
Alternate 3						
Random No. <sup>(1)</sup>	0.24683	0.49639	0.16335			
Start	330	261	60			
Alternate 4						
Random No. <sup>(1)</sup>	0.92241	0.86882	0.06259			
Start	1233	457	23			

<sup>(1)</sup> Random numbers from Excel's random function.

Ulah 023 DH Worksheet  
Three Strata

Range	Customer Count	Interval $f$	$\mu$	$\mu f$	$\sqrt{\mu f}$	cum $\sqrt{\mu f}$	
0 to 250	12176	250	1	12176	110.3	110.3	
251 to 500	8590	250	1	8590	92.7	203.0	
501 to 750	6295	250	1	6295	79.3	282.4	
751 to 1000	4660	250	1	4660	68.3	350.6	
1001 to 1250	3895	250	1	3895	62.4	413.0	
1251 to 1500	3153	250	1	3153	56.2	469.2	38,769
1501 to 1750	2625	250	1	2625	51.2	520.4	
1751 to 2000	2283	250	1	2283	47.8	568.2	
2001 to 2250	1938	250	1	1938	44.0	612.2	
2251 to 2500	1648	250	1	1648	40.6	652.8	
2501 to 2750	1397	250	1	1397	37.4	690.2	
2751 to 3000	1253	250	1	1253	35.4	725.6	
3001 to 3250	1151	250	1	1151	33.9	759.5	
3251 to 3500	946	250	1	946	30.8	790.3	
3501 to 3750	839	250	1	839	29.0	819.3	
3751 to 4000	808	250	1	808	28.4	847.7	
4001 to 4250	714	250	1	714	26.7	874.4	
4251 to 4500	641	250	1	641	25.3	899.7	
4501 to 4750	619	250	1	619	24.9	924.6	
4751 to 5000	498	250	1	498	22.3	946.9	17,360
5001 to 5250	477	250	1	477	21.8	968.8	
5251 to 5500	414	250	1	414	20.3	989.1	
5501 to 5750	404	250	1	404	20.1	1,009.2	
5751 to 6000	373	250	1	373	19.3	1,028.5	
6001 to 6250	353	250	1	353	18.8	1,047.3	
6251 to 6500	301	250	1	301	17.3	1,064.6	
6501 to 6750	253	250	1	253	15.9	1,080.6	
6751 to 7000	237	250	1	237	15.4	1,095.9	
7001 to 7250	202	250	1	202	14.2	1,110.2	
7251 to 7500	217	250	1	217	14.7	1,124.9	
7501 to 7750	151	250	1	151	12.3	1,137.2	
7751 to 8000	175	250	1	175	13.2	1,150.4	
8001 to 8250	144	250	1	144	12.0	1,162.4	
8251 to 8500	155	250	1	155	12.4	1,174.9	
8501 to 8750	123	250	1	123	11.1	1,186.0	
8751 to 9000	103	250	1	103	10.1	1,196.1	
9001 to 9250	80	250	1	80	8.9	1,205.0	
9251 to 9500	82	250	1	82	9.1	1,214.1	
9501 to 9750	63	250	1	63	7.9	1,222.0	
9751 to 10000	52	250	1	52	7.2	1,229.2	
10001 to 11000	203	1000	4	812	28.5	1,257.7	
11001 to 12000	97	1000	4	388	19.7	1,277.4	
12001 to 13000	62	1000	4	248	15.7	1,293.2	
13001 to 14000	29	1000	4	116	10.8	1,304.0	
14001 to 15000	15	1000	4	60	7.7	1,311.7	
15001 to 143600	27	143600	514.4	13888.8	117.9	1,429.6	4,792
Total N							60,921

BOUNDARIES INDICATED FOR STRATA:

	3	4	5	6
1	476.5	357.4	285.9	238.3
2	953.0	714.8	571.8	476.5
3		1,072.2	857.7	714.8
4			1,143.6	953.0
5				1,191.3

SAMPLING ST/ Avg. kWh<sup>1</sup> Mean kW<sup>2</sup> St. Dev.<sup>2</sup>

1	549.051	1.365	1.205
2	2,753.970	6.753	3.065
3	7,153.640	14.814	4.271
4			
5			
6			

<sup>1</sup> Billing records for March 2007 through February 2008

<sup>2</sup> Load Research data for January 2007 through December 2007

Table B.1

Utah 023 DH Worksheet  
Four Strata

Range	Customer Count	Interval Factor	$\mu$	$\mu f$	$\sqrt{\mu f}$	cum $\sqrt{\mu f}$
0 to 250	12176	1	12176	110.3	110.3	
251 to 500	8590	1	8590	92.7	203.0	
501 to 750	6295	1	6295	79.3	282.4	
751 to 1000	4660	1	4660	68.3	350.6	31,721
1001 to 1250	3895	1	3895	62.4	413.0	
1251 to 1500	3153	1	3153	56.2	469.2	
1501 to 1750	2625	1	2625	51.2	520.4	
1751 to 2000	2283	1	2283	47.8	568.2	
2001 to 2250	1938	1	1938	44.0	612.2	
2251 to 2500	1648	1	1648	40.6	652.8	
2501 to 2750	1397	1	1397	37.4	690.2	16,939
2751 to 3000	1253	1	1253	35.4	725.6	
3001 to 3250	1151	1	1151	33.9	759.5	
3251 to 3500	946	1	946	30.8	790.3	
3501 to 3750	839	1	839	29.0	819.3	
3751 to 4000	808	1	808	28.4	847.7	
4001 to 4250	714	1	714	26.7	874.4	
4251 to 4500	641	1	641	25.3	899.7	
4501 to 4750	619	1	619	24.9	924.6	
4751 to 5000	498	1	498	22.3	946.9	
5001 to 5250	477	1	477	21.8	968.8	
5251 to 5500	414	1	414	20.3	989.1	
5501 to 5750	404	1	404	20.1	1,009.2	
5751 to 6000	373	1	373	19.3	1,028.5	
6001 to 6250	353	1	353	18.8	1,047.3	
6251 to 6500	301	1	301	17.3	1,064.6	9,791
6501 to 6750	253	1	253	15.9	1,080.6	
6751 to 7000	237	1	237	15.4	1,095.9	
7001 to 7250	202	1	202	14.2	1,110.2	
7251 to 7500	217	1	217	14.7	1,124.9	
7501 to 7750	151	1	151	12.3	1,137.2	
7751 to 8000	175	1	175	13.2	1,150.4	
8001 to 8250	144	1	144	12.0	1,162.4	
8251 to 8500	155	1	155	12.4	1,174.9	
8501 to 8750	123	1	123	11.1	1,186.0	
8751 to 9000	103	1	103	10.1	1,196.1	
9001 to 9250	80	1	80	8.9	1,205.0	
9251 to 9500	82	1	82	9.1	1,214.1	
9501 to 9750	63	1	63	7.9	1,222.0	
9751 to 10000	52	1	52	7.2	1,229.2	
10001 to 11000	203	4	812	28.5	1,257.7	
11001 to 12000	97	4	388	19.7	1,277.4	
12001 to 13000	62	4	248	15.7	1,293.2	
13001 to 14000	29	4	116	10.8	1,304.0	
14001 to 15000	15	4	60	7.7	1,311.7	
15001 to 143600	27	514.4	13888.8	117.9	1,429.6	2,470
Total N		60,921				60,921

BOUNDARIES INDICATED FOR STRATA:

	3	4	5	6
1	476.5	357.4	285.9	238.3
2	953.0	714.8	571.8	476.5
3		1,072.2	857.7	714.8
4			1,143.6	953.0
5				1,191.3

SAMPLING ST#	Avg. kWh <sup>1</sup>	Mean kW <sup>2</sup>	St. Dev <sup>2</sup>
1	396.862	0.662	0.788
2	1,707.240	2.913	0.796
3	4,167.170	9.330	3.202
4	8,529.070	16.309	3.705
5			
6			

<sup>1</sup> Billing records for March 2007 through February 2008

<sup>2</sup> Load Research data for January 2007 through December 2007

Table B.2

Utah 023 DH Worksheet  
Five Strata

Range	Customer Count	Interval Factor	$f$	$\mu$	$\mu f$	$\sqrt{\mu f}$	cum $\sqrt{\mu f}$	
0 to 250	12176	1	12176		12176	110.3	110.3	
251 to 500	8590	1	8590		8590	92.7	203.0	
501 to 750	6295	1	6295		6295	79.3	282.4	27,061
751 to 1000	4660	1	4660		4660	68.3	350.6	
1001 to 1250	3895	1	3895		3895	62.4	413.0	
1251 to 1500	3153	1	3153		3153	56.2	469.2	
1501 to 1750	2625	1	2625		2625	51.2	520.4	
1751 to 2000	2283	1	2283		2283	47.8	568.2	16,616
2001 to 2250	1938	1	1938		1938	44.0	612.2	
2251 to 2500	1648	1	1648		1648	40.6	652.8	
2501 to 2750	1397	1	1397		1397	37.4	690.2	
2751 to 3000	1253	1	1253		1253	35.4	725.6	
3001 to 3250	1151	1	1151		1151	33.9	759.5	
3251 to 3500	946	1	946		946	30.8	790.3	
3501 to 3750	839	1	839		839	29.0	819.3	
3751 to 4000	808	1	808		808	28.4	847.7	9,980
4001 to 4250	714	1	714		714	26.7	874.4	
4251 to 4500	641	1	641		641	25.3	899.7	
4501 to 4750	619	1	619		619	24.9	924.6	
4751 to 5000	498	1	498		498	22.3	946.9	
5001 to 5250	477	1	477		477	21.8	968.8	
5251 to 5500	414	1	414		414	20.3	989.1	
5501 to 5750	404	1	404		404	20.1	1,009.2	
5751 to 6000	373	1	373		373	19.3	1,028.5	
6001 to 6250	353	1	353		353	18.8	1,047.3	
6251 to 6500	301	1	301		301	17.3	1,064.6	
6501 to 6750	253	1	253		253	15.9	1,080.6	
6751 to 7000	237	1	237		237	15.4	1,095.9	
7001 to 7250	202	1	202		202	14.2	1,110.2	
7251 to 7500	217	1	217		217	14.7	1,124.9	
7501 to 7750	151	1	151		151	12.3	1,137.2	5,854
7751 to 8000	175	1	175		175	13.2	1,150.4	
8001 to 8250	144	1	144		144	12.0	1,162.4	
8251 to 8500	155	1	155		155	12.4	1,174.9	
8501 to 8750	123	1	123		123	11.1	1,186.0	
8751 to 9000	103	1	103		103	10.1	1,196.1	
9001 to 9250	80	1	80		80	8.9	1,205.0	
9251 to 9500	82	1	82		82	9.1	1,214.1	
9501 to 9750	63	1	63		63	7.9	1,222.0	
9751 to 10000	52	1	52		52	7.2	1,229.2	
10001 to 11000	203	4	812		812	28.5	1,257.7	
11001 to 12000	97	4	388		388	19.7	1,277.4	
12001 to 13000	62	4	248		248	15.7	1,293.2	
13001 to 14000	29	4	116		116	10.8	1,304.0	
14001 to 15000	15	4	60		60	7.7	1,311.7	
15001 to 143600	27	514.4	13888.8		13888.8	117.9	1,429.6	1,410
Total N		60,921						60,921

BOUNDARIES INDICATED FOR STRATA:

	3	4	5	6
1	476.5	357.4	285.9	238.3
2	953.0	714.8	571.8	476.5
3		1,072.2	857.7	714.8
4			1,143.6	953.0
5				1,191.3

SAMPLING ST/

	Avg. kWh <sup>1</sup>	Mean kW <sup>2</sup>	St. Dev <sup>2</sup>
1	315.437	0.385	0.334
2	1,280.920	2.699	0.816
3	2,829.430	6.270	1.932
4	5,422.430	11.775	3.423
5	9,627.600	13.821	5.747
6			

<sup>1</sup> Billing records for March 2007 through February 2008  
<sup>2</sup> Load Research data for January 2007 through December 2007

Table B.3

Utah 023 DH Worksheet

Six Strata

Range	Customer Count	Interval Factor	$\mu$	$\mu f$	$\sqrt{\mu f}$	cum $\sqrt{\mu f}$	
0 to 250	12176	1	12176	110.3	110.3		
251 to 500	8590	1	8590	92.7	203.0	20,766	
501 to 750	6295	1	6295	79.3	282.4		
751 to 1000	4660	1	4660	68.3	350.6		
1001 to 1250	3895	1	3895	62.4	413.0		
1251 to 1500	3153	1	3153	56.2	469.2	18,003	
1501 to 1750	2625	1	2625	51.2	520.4		
1751 to 2000	2283	1	2283	47.8	568.2		
2001 to 2250	1938	1	1938	44.0	612.2		
2251 to 2500	1648	1	1648	40.6	652.8		
2501 to 2750	1397	1	1397	37.4	690.2	9,891	
2751 to 3000	1253	1	1253	35.4	725.6		
3001 to 3250	1151	1	1151	33.9	759.5		
3251 to 3500	946	1	946	30.8	790.3		
3501 to 3750	839	1	839	29.0	819.3		
3751 to 4000	808	1	808	28.4	847.7		
4001 to 4250	714	1	714	26.7	874.4		
4251 to 4500	641	1	641	25.3	899.7		
4501 to 4750	619	1	619	24.9	924.6		
4751 to 5000	498	1	498	22.3	946.9	7,469	
5001 to 5250	477	1	477	21.8	968.8		
5251 to 5500	414	1	414	20.3	989.1		
5501 to 5750	404	1	404	20.1	1,009.2		
5751 to 6000	373	1	373	19.3	1,028.5		
6001 to 6250	353	1	353	18.8	1,047.3		
6251 to 6500	301	1	301	17.3	1,064.6		
6501 to 6750	253	1	253	15.9	1,080.6		
6751 to 7000	237	1	237	15.4	1,095.9		
7001 to 7250	202	1	202	14.2	1,110.2		
7251 to 7500	217	1	217	14.7	1,124.9		
7501 to 7750	151	1	151	12.3	1,137.2		
7751 to 8000	175	1	175	13.2	1,150.4		
8001 to 8250	144	1	144	12.0	1,162.4		
8251 to 8500	155	1	155	12.4	1,174.9		
8501 to 8750	123	1	123	11.1	1,186.0	3,979	
8751 to 9000	103	1	103	10.1	1,196.1		
9001 to 9250	80	1	80	8.9	1,205.0		
9251 to 9500	82	1	82	9.1	1,214.1		
9501 to 9750	63	1	63	7.9	1,222.0		
9751 to 10000	52	1	52	7.2	1,229.2		
10001 to 11000	203	4	812	28.5	1,257.7		
11001 to 12000	97	4	388	19.7	1,277.4		
12001 to 13000	62	4	248	15.7	1,293.2		
13001 to 14000	29	4	116	10.8	1,304.0		
14001 to 15000	15	4	60	7.7	1,311.7		
15001 to 143600	27	514.4	13888.8	117.9	1,429.6	813	
Total N		60,921				60,921	

BOUNDARIES INDICATED FOR STRATA:

	3	4	5	6
1	476.5	357.4	285.9	238.3
2	953.0	714.8	571.8	476.5
3		1,072.2	857.7	714.8
4			1,143.6	953.0
5				1,191.3

SAMPLING ST/	Avg. kWh <sup>1</sup>	Mean kW <sup>2</sup>	St. Dev <sup>2</sup>
1	223.916	0.385	0.334
2	924.085	2.453	0.781
3	2,044.450	3.394	0.663
4	3,693.570	8.433	2.240
5	6,436.950	13.734	3.224
6	10,661.300	14.072	5.740

<sup>1</sup> Billing records for March 2007 through February 2008  
<sup>2</sup> Load Research data for January 2007 through December 2007

Table B.4



UTAH COMMERCIAL 023 LOAD STUDY DESIGN OPTION (2008)  
THREE STRATA, MEAN-PER-UNIT DESIGN

	a	b	c	d	e	f	g	h	i	j
	Sample Mean Kw	Sample Mean Kw/h	2008 Pop N	Variance of Mean	Standard Deviation	Wtd. Devts. c'e	Proport. row / sum f	Optimal Allocation g <sup>h</sup> total	Optimal with Attrition	Final with Attrition
STRATUM 1	1,365	549.051	38,769	1.4530	1.205	46733	0.3881	26	26	29
STRATUM 2	1501-5000 kwh 6,753	2,753.970	17,360	9.3952	3.065	53211	0.4419	30	30	33
STRATUM 3	GT-5000 kwh 14,814	7,153.640	4,792	18.2436	4.271	20468	0.1700	12	12	13

EST POP MEAN (wtd by N) 3,958 1,696,875 60,921

120412 1,0000 68

68 75

Sample Estimate 68  
Adj Sample Estimate 75

RELATIVE PRECISION OF SAMPLE KW ESTIMATE

	TOTAL KW Optimal n (col. h)	TOTAL KW Adjusted n (cc Final (col. j)	TOTAL KW	MEAN KW Adj. n
Variance contributed by strata:	1 87,300,517	87,300,517	77,940,854	0.023522
	2 97,466,709	97,466,709	88,313,914	0.026262
	3 37,989,398	37,989,398	34,816,330	0.010236

Total Variance 222,756,624 222,756,624 201,071,098 0.060020

Standard Error 14925.03346 14925.03346 14179.95409 0.244989962

Desired Conf. Level (z two tailed)	90% 1.645	90% 1.645	90% 1.645	90% 1.645
------------------------------------	--------------	--------------	--------------	--------------

Conf. Interval 24551.68004 24551.68004 23326.02449 0.403008487

MPU Est of KW 241123.6339 241123.6339 241123.6339 3.9580

Relative Conf. Int. 10.18% 10.18% 9.67% 10.18%

Table C.1

UTAH COMMERCIAL 023 LOAD STUDY DESIGN OPTION (2008)  
 FOUR STRATA, MEAN-PER-UNIT DESIGN

	a	b	c	d	e	f	g	h	i	j
	Sample Mean kW	Sample Mean KWh	2008 Pop N	Variance of Mean	Standard Deviation	Wtd. Devtns. c*e	Proprtn. row f/ sum f	Optimal Allocation g*h total	Optimal with Attrition	Final with Attrition
STRATUM 1	0 - 1000 KWh	396,862	31,721	0.6214	0.788	25005	0.3165	9	10	11
STRATUM 2	1001 - 2750 KWh	1,707,240	16,939	0.6340	0.796	13488	0.1707	5	10	11
STRATUM 3	2751 - 6500 KWh	4,167,170	9,791	10.2541	8.202	31353	0.3969	12	12	13
STRATUM 4	GT 6501 KWh	8,529,070	2,470	13.7234	3.705	9150	0.1158	3	10	11

EST POP MEAN (wtd by N) 3.315 1,696,876 60,921 78996 1,0000 30

Sample Estimate	42	46
Adj Sample Estimate	30	46

'RELATIVE PRECISION OF SAMPLE KW ESTIMATE

	Optimal n (col. h)	TOTAL KW	Adjusted n (cc Final (col. j)	MEAN KW
Variance contributed by strata:	1	78,133,862	69,450,132	62,503,147
	2	45,465,467	20,200,908	18,179,743
	3	89,254,096	89,254,096	81,807,888
	4	41,811,804	9,265,148	8,335,243
Total Variance		254,665,229	188,170,283	170,826,022
Standard Error		15958.2339	13717.5174	13070.0429
Desired Conf. Level (z two tailed)	90%	1.645	1.645	1.645
Conf. Interval		26251.29476	22565.31612	21500.2206
MPU Est of kW		201968.0661	201968.0661	201968.066
Relative Conf. Int.		13.00%	11.17%	10.65%

Table C.2

UTAH COMMERCIAL 023 LOAD STUDY DESIGN OPTION (2008)  
 FIVE STRATA, MEAN-PER-UNIT DESIGN

	a	b	c	d	e	f	g	h	i	j
	Sample Mean Kw	Sample Mean Kw	2008 Pop N	Variance of Mean	Standard Deviation	Wtd. Dev'ts. c'e	Propr'n. row / sum f	Optimal Allocation g* total	Optimal with Attrition	Final with Attrition
STRATUM 1	0.385	315.437	27,061	0.1117	0.334	9046	0.1292	2	10	11
STRATUM 2	751 - 2000 KWh	2,699	1,280,920	0.6662	0.816	13662	0.1937	4	10	11
STRATUM 3	2001 - 4000 KWh	6,270	2,829,430	3.7309	1.932	19277	0.2753	5	10	11
STRATUM 4	4001 - 7750 KWh	11,775	5,422,430	11.7201	3.423	20041	0.2862	5	10	11
STRATUM 5	GT 7750 KWh	13,821	9,627,600	33.0241	5.747	8103	0.1157	2	10	11
EST POP MEAN (wtd by N)	3,385	1,696,875	60,921			70029	1.0000	18	50	55

RELATIVE PRECISION OF SAMPLE KW ESTIMATE

	TOTAL KW Optimal n (col. h)	TOTAL KW Adjusted n (cc Final (col. j)	TOTAL KW MEAN KW Adj. n
Variance contributed by strata:	1 81,825,209	9,089,002	8,179,799
2	61,298,538	20,425,466	18,381,812
3	92,853,323	41,247,458	37,118,989
4	100,324,280	44,550,453	40,088,546
5	65,561,998	7,243,276	6,514,292
Total Variance	401,853,349	122,555,655	110,283,439
Standard Error	20046.5296	11070.48575	10501.59222

Desired Conf. Level (z two tailed)	90% 1.645	90% 1.645	90% 1.645	90% 1.645
Conf. Interval	32976.54119	18210.94906	17275.1192	0.298927284
MPU Est of KW	206247.7077	206247.7077	206247.7077	3.3855
Relative Conf. Int.	15.99%	8.83%	8.38%	8.83%

Table C.3

UTAH COMMERCIAL 023 LOAD STUDY DESIGN OPTION (2008)  
SIX STRATA, MEAN-PER-UNIT DESIGN

	a	b	c	d	e	f	g	h	i	j
	Sample Mean kW	Sample Mean kW/h	2008 Pop N	Variance of Mean	Standard Deviation	Wtd. Devits. c <sup>e</sup>	Proprtn. row f/ sum f	Optimal Allocation g <sup>h</sup> total	Optimal with Attrition	Final with Attrition
STRATUM 1	0 - 500 kWh	0.385	223,916	20.766	0.334	69.42	0.1124	1	10	11
STRATUM 2	501 - 1500 kWh	2.453	924,085	18.003	0.781	140.58	0.2275	3	10	11
STRATUM 3	1501 - 2750 kWh	3.394	2,044,450	9.891	0.663	65.62	0.1062	1	10	11
STRATUM 4	2751 - 5000 kWh	8.433	3,693,570	7.469	2.240	167.27	0.2707	1	10	11
STRATUM 5	5001 - 8750 kWh	13.734	6,436,950	3.979	3.224	128.28	0.2076	2	10	11
STRATUM 6	GT 8751 kWh	14.072	10,661,300	8.13	5.740	466.7	0.0755	1	10	11
EST POP MEAN (wtd by N)		3.526	1,696,875	60.921		617.83	1.0000	12	60	66

Sample Estimate	12
Adj Sample Estimate	66

RELATIVE PRECISION OF SAMPLE KW ESTIMATE

	TOTAL KW	TOTAL KW	TOTAL KW	MEAN KW
	Optimal n (col. h)	Adjusted n (col. Final (col. j)	Adj. n	
Variance contributed by strata:				
1	#DIV/0!	5,351,623	4,816,229	0.001442
2	98,796,155	21,946,163	19,750,449	0.005913
3	#DIV/0!	4,779,021	4,300,683	0.001288
4	139,842,437	31,046,961	27,938,518	0.008365
5	164,470,890	18,237,783	16,409,869	0.004914
6	#DIV/0!	2,390,302	2,148,593	0.000644
Total Variance	#DIV/0!	83,751,853	75,364,342	0.022566
Standard Error	#DIV/0!	9151,603832	8681,263827	0.150220841

Desired Conf. Level (z two tailed)	90%	90%	90%	90%
Conf. Interval	#DIV/0!	15054,3883	14280,679	0.247113283
MPU Est of KW	214793,8354	214793,8354	214793,8354	3.5258
Relative Conf. Int.	#DIV/0!	7.01%	6.65%	7.01%



Utah Schedule 023 kWh Summary  
For the Twelve months Ended December 2007

N	MIN	MEAN	MAX	SUM
60921	20.9167	1696.88	46040	103375338.88

08APR08 11:54

Utah Schedule 023 Bill Frequency Worksheet

STRATUM		n	KWH
0 -	250 kWh	12176	1479353.46
251 -	500 kWh	8590	3170489.41
501 -	750 kWh	6295	3886196.34
751 -	1000 kWh	4660	4052828.97
1001 -	1250 kWh	3895	4370999.22
1251 -	1500 kWh	3153	4326279.09
1501 -	1750 kWh	2625	4259747.28
1751 -	2000 kWh	2283	4273871.73
2001 -	2250 kWh	1938	4115525.01
2251 -	2500 kWh	1648	3910701.29
2501 -	2750 kWh	1397	3661782.09
2751 -	3000 kWh	1253	3596897.75
3001 -	3250 kWh	1151	3593109.81
3251 -	3500 kWh	946	3194257.27
3501 -	3750 kWh	839	3036260.46
3751 -	4000 kWh	808	3129214.85
4001 -	4250 kWh	714	2945360.59
4251 -	4500 kWh	641	2803785.01
4501 -	4750 kWh	619	2862282.09
4751 -	5000 kWh	498	2426138.25
5001 -	5250 kWh	477	2444556.14
5251 -	5500 kWh	414	2225808.51
5501 -	5750 kWh	404	2269200.04
5751 -	6000 kWh	373	2192661.42
6001 -	6250 kWh	353	2162867.26
6251 -	6500 kWh	301	1918363.82
6501 -	6750 kWh	253	1675808.86
6751 -	7000 kWh	237	1627743.02
7001 -	7250 kWh	202	1438834.15
7251 -	7500 kWh	217	1598485.46
7501 -	7750 kWh	151	1151014.55
7751 -	8000 kWh	175	1377131.82
8001 -	8250 kWh	144	1169241.34
8251 -	8500 kWh	155	1299826.07
8501 -	8750 kWh	123	1061078.63
8751 -	9000 kWh	103	913453.75
9001 -	9250 kWh	80	730909.44
9251 -	9500 kWh	82	767551.45
9501 -	9750 kWh	63	606506.15
9751 -	10000 kWh	52	514000.70
10001 -	11000 kWh	203	2121667.36
11001 -	12000 kWh	97	1106727.59
12001 -	13000 kWh	62	773889.25
13001 -	14000 kWh	29	387809.08
14001 -	15000 kWh	15	216264.62
GT	15001 kWh	27	528858.43

Utah 023 Billing Statistics  
Mean kWh - Three Strata

----- STRATUM=1 -----

N	KWH_MEAN
38769	549.051

----- STRATUM=2 -----

N	KWH_MEAN
17360	2753.97

----- STRATUM=3 -----

N	KWH_MEAN
4792	7153.64



Utah 023 Billing Statistics  
Mean kWh - Four Strata

----- STRATUM=1 -----

N	KWH_MEAN
31721	396.862

----- STRATUM=2 -----

N	KWH_MEAN
16939	1707.24

----- STRATUM=3 -----

N	KWH_MEAN
9791	4167.17

----- STRATUM=4 -----

N	KWH_MEAN
2470	8529.07

Utah 023 Billing Statistics  
Mean kWh - Five Strata

----- STRATUM=1 -----	
N	KWH_MEAN
27061	315.437
----- STRATUM=2 -----	
N	KWH_MEAN
16616	1280.92
----- STRATUM=3 -----	
N	KWH_MEAN
9980	2829.43
----- STRATUM=4 -----	
N	KWH_MEAN
5854	5422.43
----- STRATUM=5 -----	
N	KWH_MEAN
1410	9627.60

Utah 023 Billing Statistics  
Mean kWh - Six Strata

----- STRATUM=1 -----	
N	KWH_MEAN
20766	223.916
----- STRATUM=2 -----	
N	KWH_MEAN
18003	924.085
----- STRATUM=3 -----	
N	KWH_MEAN
9891	2044.45
----- STRATUM=4 -----	
N	KWH_MEAN
7469	3693.57
----- STRATUM=5 -----	
N	KWH_MEAN
3979	6436.95
----- STRATUM=6 -----	
N	KWH_MEAN
813	10661.30

Utah Schedule 023 Eligible Sample Point Summary  
Annual kWh GT 250, Agreement Status=ACT

1

13:55 Thursday, April 10, 2008

----- STRATUM=0 - 1,500 kWh -----

The MEANS Procedure

Analysis Variable : KWH\_MNTH Billed Usage

N	Mean
38146	548.6611961

----- STRATUM=1,501 - 5,000 kWh -----

Analysis Variable : KWH\_MNTH Billed Usage

N	Mean
17138	2756.40

----- STRATUM=GT 5,000 kWh -----

Analysis Variable : KWH\_MNTH Billed Usage

N	Mean
4748	7157.49

----- STRATUM=0 - 1,500 kWh -----

The MEANS Procedure

Analysis Variable : KWH\_MNTH Billed Usage

N	Mean
38146	548.6611961

----- STRATUM=1,501 - 5,000 kWh -----

Analysis Variable : KWH\_MNTH Billed Usage

N	Mean
17138	2756.40

----- STRATUM=GT 5,000 kWh -----

Analysis Variable : KWH\_MNTH Billed Usage

N	Mean
4748	7157.49

Utah Schedule 023 Eligible Sample Point Summary  
Annual kWh GT 250, Agreement Status=ACT

3

13:55 Thursday, April 10, 2008

----- STRATUM=0 - 1,500 kWh -----

The MEANS Procedure

Analysis Variable : KWH\_MNTH Billed Usage

N	Mean
38769	549.0506975

----- STRATUM=1,501 - 5,000 kWh -----

Analysis Variable : KWH\_MNTH Billed Usage

N	Mean
17360	2753.97

----- STRATUM=GT 5,000 kWh -----

Analysis Variable : KWH\_MNTH Billed Usage

N	Mean
4792	7153.64

