

Addendum to Dave Johnston Unit 3 BART Report

PREPARED FOR: Wyoming Division of Air Quality
PREPARED BY: CH2M HILL
COPIES: Bill Lawson/PacifiCorp
DATE: March 26, 2008

Introduction

In compliance with the Regional Haze Rule (40 Code of Federal Regulations [CFR] 51), the Wyoming Division of Air Quality (WDAQ) required PacifiCorp Energy to conduct a detailed Best Available Retrofit Technology (BART) review to analyze the effects to visibility in nearby Class I areas from plant emissions, both for baseline and for reasonable control technology scenarios. PacifiCorp submitted these evaluations to WDAQ in January 2007. A revised report was submitted in October 2007.

On January 3, 2008, PacifiCorp Energy personnel met with WDAQ staff to discuss the status of the BART reviews. At that time, the state requested that additional modeling scenarios for several of the PacifiCorp facilities be performed to aid in their BART review. This memorandum presents the economics analysis for two scenarios, referred to as Scenario A and Scenario B and described as follows:

- Scenario A: PacifiCorp committed controls at permitted rates—low nitrogen oxide (NO_x) burners (LNBs) with over-fire air (OFA), dry flue gas desulfurization (FGD), new fabric filter
- Scenario B: PacifiCorp committed controls and selective catalytic reduction (SCR) at permitted rates

The CALPUFF modeling system (v. 5.711a) was used for this analysis. All technical options and model triggers used in CALMET, CALPUFF, and CALPOST are consistent with those used for the previous BART analyses and described in the BART report submitted in October 2007.

Stack Parameters, Emissions Information, and Capital Cost

Table 1 summarizes the control equipment for Scenarios A and B as well as the current equipment installed at the plant. The overall capital cost of installing these options is also shown.

TABLE 1
Control Scenario Summary
Dave Johnston Unit 3

| | Equipment Type | | | Capital Cost |
|------------|----------------------|-----------------|------------------|-----------------|
| | NO _x | SO ₂ | PM ₁₀ | Million dollars |
| Baseline | No control | No control | ESP | — |
| Scenario A | LNB with OFA | Dry FGD | Fabric Filter | \$187.0 |
| Scenario B | LNB with OFA and SCR | Dry FGD | Fabric Filter | \$299.2 |

Emissions were modeled for the following pollutants:

- Sulfur dioxide (SO₂)
- NO_x
- Coarse particulate (PM_{2.5}<diameter<PM₁₀)
- Fine particulate (diameter<PM_{2.5})
- Sulfates

Table 2 shows stack parameters and emission rates that were used for the Dave Johnston Unit 3 BART modeling and analysis.

TABLE 2
Calpuff Model Inputs
Dave Johnston Unit 3

| Model Input Data | BART Comparison ^(d) | | |
|--|--------------------------------|---------------------------|---------------------------|
| | Baseline | Scenario A ^(e) | Scenario B ^(f) |
| Hourly Heat Input (mmBtu/hour) | 2,500 | 2,800 | 2,800 |
| Sulfur Dioxide (SO ₂) Stack Emissions (lb/hr) | 3,000 | 420 | 420 |
| Nitrogen Oxide (NO _x) Stack Emissions (lb/hr) | 1,750 | 784 | 196 |
| PM ₁₀ Stack Emissions (lb/hr) | 75 | 42.0 | 42.0 |
| Coarse Particulate (PM _{2.5} <diameter< PM ₁₀) Stack Emissions (lb/hr) ^(a) | 32.3 | 23.9 | 23.9 |
| Fine Particulate (diameter<PM _{2.5}) Stack Emissions (lb/hr) ^(b) | 42.8 | 18.1 | 18.1 |
| Sulfuric Acid (H ₂ SO ₄) Stack Emissions (lb/hr) | 46 | 2.6 | 3.7 |
| Ammonium Sulfate [(NH ₄) ₂ SO ₄] Stack Emissions (lb/hr) | — | — | 0.7 |
| (NH ₄)HSO ₄ Stack Emissions (lb/hr) | — | — | 1.2 |
| H ₂ SO ₄ as Sulfate (SO ₄) Stack Emissions (lb/hr) | 45.1 | 2.5 | 3.6 |
| (NH ₄) ₂ SO ₄ as SO ₄ Stack Emissions (lb/hr) | — | — | 0.5 |
| (NH ₄)HSO ₄ as SO ₄ Stack Emissions (lb/hr) | — | — | 1.0 |

TABLE 2
Calpuff Model Inputs
Dave Johnston Unit 3

| Model Input Data | BART Comparison ^(d) | | |
|---|--------------------------------|---------------------------|---------------------------|
| | Baseline | Scenario A ^(e) | Scenario B ^(f) |
| Total Sulfate (SO ₄) (lb/hr) ^(c) | 45.1 | 2.5 | 5.1 |
| Stack Conditions | | | |
| Stack Height (meters) | 152 | 152.4 | 152.4 |
| Stack Exit Diameter (meters) | 4.6 | 4.57 | 4.57 |
| Stack Exit Temperature (Kelvin) | 445 | 348 | 348 |
| Stack Exit Velocity (meters per second) | 32 | 25.5 | 25.5 |

NOTES:

^(a) Based on AP-42, Table 1.1-6, the coarse particulates are counted as a percentage of PM₁₀. This equates to 43% ESP and 57% Baghouse. PM₁₀ and PM_{2.5} refer to particulate matter less than 10 and 2.5 micrometers, respectively, in aerodynamic diameter.

^(b) Based on AP-42, Table 1.1-6, the fine particulates are counted as a percentage of PM₁₀. This equates to 57% ESP and 43% Baghouse.

^(c) Total Sulfate (SO₄) (lb/hr) = H₂SO₄ as Sulfate (SO₄) Stack Emissions (lb/hr) + (NH₄)₂SO₄ as SO₄ Stack Emissions (lb/hr) + (NH₄)HSO₄ as SO₄ Stack Emissions (lb/hr)

^(d) SO₂, NO_x, and PM rates are expressed in terms of permitted emission rates. Actual emissions will be less than the permitted rates.

^(e) PacifiCorp Committed Controls @ permitted rates: LNB with OFA, Dry FGD, New Fabric Filter

^(f) PacifiCorp Committed Controls and SCR @ permitted rates

Economic Analysis

In completing this additional analysis to supplement the previous BART study, technology alternatives were investigated and potential reductions in NO_x, SO₂, and PM₁₀ emissions rates were identified.

A comparison of Scenarios A and B on the basis of costs, design control efficiencies, and tons of pollutant removed is summarized in Tables 3 through 5. Capital costs were provided by PacifiCorp. The complete economic analyses for these two scenarios are provided as Attachment 1.

TABLE 3
 Scenario A Control Cost
 Dave Johnston Unit 3

| | NO _x Control | SO ₂ Control | PM ₁₀ Control | Scenario A |
|--|-------------------------|-------------------------|--------------------------|--------------|
| | LNB with OFA | Dry FGD | Fabric Filter | Control Cost |
| Total Installed Capital Costs (million dollars) | \$17.5 | \$169.5 | — | \$187.0 |
| Annualized First-Year Capital Costs | \$1.66 | \$16.12 | — | \$17.79 |
| First Year Fixed & Variable O&M Costs (million dollars) | \$0.10 | \$5.30 | — | \$5.40 |
| Total First Year Annualized Costs (million dollars) ^(a) | \$1.76 | \$21.42 | — | \$23.19 |
| Power Consumption (MW) | — | 3.88 | — | 3.88 |
| Annual Power Usage (Million kWh/Yr) | — | 30.59 | — | 30.59 |
| Permitted Emission Rate (lb/mmBtu) | 0.28 | 0.15 | 0.02 | — |
| Additional Tons of Pollutant Removed per Year over Baseline | 4,636 | 11,589 | 166 | 16,391 |
| First Year Average Control Cost (\$/Ton of Pollutant Removed) | 381 | 1,848 | — | 1,414 |

NOTE:

^(a) First year annualized costs include power consumption costs.

TABLE 4
 Scenario B Control Cost
 Dave Johnston Unit 3

| | NO_x Control | SO₂ Control | PM₁₀ Control | Scenario B |
|--|-------------------------------|-------------------------------|--------------------------------|---------------------|
| | LNB with OFA & SCR | Dry FGD | Fabric Filter | Control Cost |
| Total Installed Capital Costs (million dollars) | \$129.7 | \$169.5 | — | \$299.2 |
| Annualized First-Year Capital Costs | \$12.34 | \$16.12 | — | \$28.46 |
| First Year Fixed & Variable O&M Costs (million dollars) | \$4.01 | \$5.30 | — | \$9.30 |
| Total First Year Annualized Costs (million dollars) ^(a) | \$16.35 | \$21.42 | — | \$37.77 |
| Power Consumption (MW) | 0.23 | 3.88 | — | 5.45 |
| Annual Power Usage (Million kWh/Yr) | 12.34 | 30.59 | — | 42.97 |
| Permitted Emission Rate (lb/mmBtu) | 0.07 | 0.15 | 0.02 | — |
| Additional Tons of Pollutant Removed per Year over Baseline | 6,954 | 11,589 | 166 | 18,709 |
| First Year Average Control Cost (\$/Ton of Pollutant Removed) | 2,351 | 1,848 | — | 2,019 |

NOTE:

^(a) First year annualized costs include power consumption costs.

TABLE 5
Incremental Control Costs, Scenario B compared to Scenario A
Dave Johnston Unit 3

| | NO_x Control | SO₂ Control | PM₁₀ Control | Total |
|---|-------------------------------|-------------------------------|--------------------------------|--------------|
| | Control Cost | | | |
| Incremental Installed Capital Costs (million dollars) | \$112.2 | 0 | 0 | \$112.2 |
| Incremental Annualized First-Year Capital Costs | \$10.67 | 0 | 0 | \$10.67 |
| Incremental First Year Fixed & Variable O&M Costs (million dollars) | \$3.91 | 0 | 0 | \$3.91 |
| Incremental First Year Annualized Costs (million dollars) ^(a) | \$14.58 | 0 | 0 | \$14.58 |
| Incremental Power Consumption (MW) | 1.57 | 0 | 0 | 1.57 |
| Incremental Annual Power Usage (Million kWh/Yr) | 12.38 | 0 | 0 | 12.38 |
| Incremental Improvement in Emission Rate (lb/mmBtu) | 0.21 | 0 | 0 | — |
| Incremental Tons of Pollutant Removed | 2,318 | 0 | 0 | 2,318 |
| Incremental First Year Average Control Cost (\$/Ton of Pollutant Removed) | 6,291 | 0 | 0 | 6,291 |

NOTE:

^(a)Incremental first year annualized costs include power consumption costs.

Modeling Results and Least-Cost Envelope Analysis

CH2M HILL modeled Dave Johnston Unit 3 for two post-control scenarios. The results determine the change in deciview based on each alternative at the Class I areas specific to the project. The Class I areas potentially affected are Badlands National Park and Windcave National Park for this unit.

Modeled Scenarios

Current operations (baseline) and two alternative control scenarios were modeled to cover the range of effectiveness for the combination of the individual NO_x, SO₂, and PM control technologies being evaluated. The modeled scenarios include the following:

- Baseline: Current operations with ESP
- Scenario A: LNB with OFA, Dry FGD, new fabric filter
- Scenario B: Scenario A with SCR

Summary of Visibility Analysis

Tables 6 and 7 present a summary of the modeling period (2001–2003) results for each scenario and Class I area.

TABLE 6
Costs and Visibility Modeling Results as Applicable to Badlands National Park
Dave Johnston Unit 3

| Scenario | Controls | Total First Year Annualized Cost | Highest ΔdV | 98 th Percentile ΔdV | Maximum Annual Number of Days Above 0.5 dV |
|------------|---|----------------------------------|-------------|---------------------------------|--|
| Baseline | Current Operations with ESP | — | 4.202 | 1.500 | 59 |
| Scenario A | Scenario A: PacifiCorp Committed Controls | \$23,184,500 | 1.297 | 0.432 | 7 |
| Scenario B | Scenario B: PacifiCorp Committed Controls and SCR | \$37,766,998 | 0.638 | 0.208 | 3 |

TABLE 7
Costs and Visibility Modeling Results as Applicable to Wind Cave National Park
Dave Johnston Unit 3

| Scenario | Controls | Total First Year Annualized Cost | Highest ΔV | 98 th Percentile ΔV | Maximum Annual Number of Days Above 0.5 dV |
|------------|---|----------------------------------|------------|--------------------------------|--|
| Baseline | Current Operations with ESP | — | 5.191 | 1.971 | 57 |
| Scenario A | Scenario A: PacifiCorp Committed Controls | \$23,184,500 | 1.805 | 0.583 | 11 |
| Scenario B | Scenario B: PacifiCorp Committed Controls and SCR | \$37,766,998 | 0.904 | 0.262 | 2 |

Results

Tables 8 and 9 present a summary of the costs and modeling results for each scenario and Class I area.

TABLE 8
Incremental Costs and Incremental Visibility Improvements Relative to Badlands National Park
Dave Johnston Unit 3

| Scenario Comparison | Controls | Incremental Annualized Cost (Million\$) | Reduction in 98 th Percentile maximum dV | Reduction in Number of Days Above 0.5 dV | Cost per dV Reduction (Million\$/dV Reduced) | Cost per Day to Achieve a Reduction in the Days above 0.5 dV (Million\$/Day) |
|-----------------------------------|---|---|---|--|--|--|
| Scenario A Compared to Baseline | Scenario A: PacifiCorp Committed Controls | \$23.18 | 1.068 | 52 | \$21.71 | \$0.45 |
| Scenario B Compared to Baseline | Scenario B: PacifiCorp Committed Controls and SCR | \$37.77 | 1.292 | 56 | \$29.23 | \$0.67 |
| Scenario B Compared To Scenario A | Addition of SCR | \$14.58 | 0.224 | 4 | \$65.10 | \$3.65 |

TABLE 9
 Incremental Costs and Incremental Visibility Improvements Relative to Wind Cave National Park
Dave Johnston Unit 3

| Scenario Comparison | Controls | Incremental Annualized Cost (Million\$) | Reduction in 98th Percentile maximum dV | Reduction in Number of Days Above 0.5 dV | Cost per dV Reduction (Million\$/dV Reduced) | Cost per Day to Achieve a Reduction in the Days above 0.5 dV (Million\$/Day) |
|-----------------------------------|---|--|---|---|---|---|
| Scenario A Compared to Baseline | Scenario A: PacifiCorp Committed Controls | \$23.18 | 1.388 | 46 | \$16.70 | \$0.50 |
| Scenario B Compared to Baseline | Scenario B: PacifiCorp Committed Controls and SCR | \$37.77 | 1.709 | 55 | \$22.10 | \$0.69 |
| Scenario B Compared To Scenario A | Addition of SCR | \$14.58 | 0.321 | 9 | \$45.43 | \$1.62 |

Least-Cost Envelope Analysis

The least-cost envelope graphs for Badlands National Park are shown in Figures 1 and 2 and for Wind Cave National Park are shown in Figures 3 and 4.

FIGURE 1




FIGURE 2




FIGURE 3





FIGURE 4



ATTACHMENT 1

**Complete Economic Analyses
for Scenarios A and B**

ECONOMIC ANALYSIS SUMMARY - FIRST YEAR COSTS

DJ3

Boiler Design: 3-Cell BurnerOpposed Wall-Fired PC

| TYPE OF EMISSIONS CONTROLS | | NO _x Control | | | | SO ₂ and PM Control | | | Scenario A | Scenario B |
|--|-------------------|---|-----------------------|---|---|--------------------------------|----------------------------------|---------------------|--|---|
| Technology Label | BASE | A | B | C | D | E | F | G | A+F | D+F |
| | Current Operation | Low NO _x Burners with Overfire Air | Rotating Overfire Air | Low NO _x Burners with Overfire Air and Non-Selective Catalytic Reduction | Low NO _x Burners with Overfire Air and Selective Catalytic Reduction | Dry FGD w/ESP | Upgraded Dry FGD & Fabric Filter | Wet FGD w/ ESP | LNB w/OFA, Dry Flue Gas Desulfurization and Fabric Filter Baghouse | LNB w/OFA, SCR, Dry Flue Gas Desulfurization and Fabric Filter Baghouse |
| CAPITAL INVESTMENT | | | | | | | | | | |
| Total Installed Capital Costs (\$) | \$0 | \$17,500,000 | \$12,054,022 | \$24,035,544 | \$129,700,000 | \$91,499,734 | \$169,500,000 | \$144,300,464 | \$187,000,000 | \$299,200,000 |
| FIRST YEAR DEBT SERVICE (\$/Yr) | \$0 | \$1,664,737 | \$1,146,673 | \$2,286,449 | \$12,338,079 | \$8,704,171 | \$16,124,166 | \$13,726,989 | \$17,788,903 | \$28,462,245 |
| FIRST YEAR FIXED O&M Costs (\$/Yr) | | | | | | | | | | |
| Operating Labor (\$/Yr) | \$0 | \$0 | \$0 | \$0 | \$0 | \$506,128 | \$506,128 | \$809,804 | \$506,128 | \$506,128 |
| Maintenance Material (\$/Yr) | \$0 | \$40,000 | \$60,000 | \$98,000 | \$155,000 | \$714,175 | \$714,175 | \$1,182,587 | \$754,175 | \$869,175 |
| Maintenance Labor (\$/Yr) | \$0 | \$60,000 | \$90,000 | \$147,000 | \$2,325,000 | \$476,928 | \$476,928 | \$788,391 | \$536,928 | \$2,801,928 |
| Administrative Labor (\$/Yr) | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 |
| TOTAL FIRST YEAR FIXED O&M COST | \$0 | \$100,000 | \$150,000 | \$245,000 | \$2,480,000 | \$1,697,231 | \$1,697,231 | \$2,780,782 | \$1,797,231 | \$4,177,231 |
| FIRST YEAR VARIABLE O&M Costs (\$/Yr) | | | | | | | | | | |
| Makeup Water Costs (\$/Yr) | \$0 | \$0 | \$0 | \$0 | \$0 | \$99,566 | \$99,566 | \$132,371 | \$99,566 | \$99,566 |
| Reagent Costs (\$/Yr) | \$0 | \$0 | \$0 | \$57,025 | \$526,265 | \$1,104,023 | \$1,182,881 | \$1,025,183 | \$1,182,881 | \$1,709,146 |
| SCR Catalyst / FF Bag Costs (\$/Yr) | \$0 | \$0 | \$0 | \$0 | \$384,000 | \$0 | \$151,528 | \$0 | \$151,528 | \$535,528 |
| Waste Disposal Costs (\$/Yr) | \$0 | \$0 | \$0 | \$0 | \$0 | \$572,810 | \$634,896 | \$746,581 | \$634,896 | \$634,896 |
| Electric Power Costs (\$/Yr) | \$0 | \$0 | \$1,087,992 | \$90,666 | \$618,894 | \$981,558 | \$1,529,496 | \$1,359,990 | \$1,529,496 | \$2,148,390 |
| TOTAL FIRST YEAR VARIABLE O&M COSTS (\$/Yr) | \$0 | \$0 | \$1,087,992 | \$147,691 | \$1,529,159 | \$2,757,957 | \$3,598,367 | \$3,264,126 | \$3,598,367 | \$5,127,527 |
| SUMMARY OF FIRST YEAR COSTS (\$/Yr) | | | | | | | | | | |
| First Year Debt Service (\$/Yr) | \$0 | \$1,664,737 | \$1,146,673 | \$2,286,449 | \$12,338,079 | \$8,704,171 | \$16,124,166 | \$13,726,989 | \$17,788,903 | \$28,462,245 |
| First Year Fixed O&M Costs (\$/Yr) | \$0 | \$100,000 | \$150,000 | \$245,000 | \$2,480,000 | \$1,697,231 | \$1,697,231 | \$2,780,782 | \$1,797,231 | \$4,177,231 |
| First Year Variable O&M Costs (\$/Yr) | \$0 | \$0 | \$1,087,992 | \$147,691 | \$1,529,159 | \$2,757,957 | \$3,598,367 | \$3,264,126 | \$3,598,367 | \$5,127,527 |
| Total First Year Costs (\$/Yr) | \$0 | \$1,764,737 | \$2,384,665 | \$2,679,140 | \$16,347,238 | \$13,159,358 | \$21,419,765 | \$19,771,897 | \$23,184,501 | \$37,767,002 |
| CONTROL COST COMPARISONS | | | | | | | | | | |
| NO_x Technology Comparison | | | | | | | | | | |
| Additional NO _x Removed From Base Case (Tons/Yr) | 0 | 4,636 | 5,629 | 5,298 | 6,954 | | | | | |
| First Year Average Control Cost (\$/Ton NO _x Removed) | \$0 | \$381 | \$424 | \$506 | \$2,351 | | | | | |
| Technology Case Comparison | | | | | | | | | | |
| Incremental NO _x Removed (Tons/Yr) | 0 | A-BASE 4,636 | B-A 993 | C-A 662 | D-A 2,318 | | | | | |
| Incremental Control Cost (\$/Ton NO _x Removed) | \$0 | \$381 | \$624 | \$1,381 | \$6,291 | | | | | |
| SO₂ Technology Comparison | | | | | | | | | | |
| Additional SO ₂ Removed From Base Case (Tons/Yr) | 0.5% | | | | | 81.8% | 87.6% | 95.0% | | |
| First Year Average Control Cost (\$/Ton SO ₂ Removed) | \$0 | | | | | \$1,217 | \$1,848 | \$1,571 | | |
| Technology Case Comparison | | | | | | | | | | |
| Incremental SO ₂ Removed (Tons/Yr) | 0 | | | | | E-BASE 10,817 | F-E 773 | G-F 993 | | |
| Incremental Control Cost (\$/Ton SO ₂ Removed) | \$0 | | | | | \$1,217 | \$10,691 | -\$1,659 | | |
| PM Technology Comparison | | | | | | | | | | |
| Additional PM Removed From Base Case (Tons/Yr) | 0.0% | | | | | 0 | 166 | 0 | | |
| First Year Average Control Cost (\$/Ton PM Removed) | \$0 | | | | | #DIV/0! | \$129,375 | #DIV/0! | | |
| Technology Case Comparison | | | | | | | | | | |
| Incremental PM Removed (Tons/Yr) | 0 | | | | | E-BASE 0 | F-E 166 | G-F -166 | | |
| Incremental Control Cost (\$/Ton PM Removed) | \$0 | | | | | #DIV/0! | \$0 | \$0 | | |
| SCENARIO A AND B COMPARISONS | | | | | | | | | | |
| Additional NO _x , SO ₂ , & PM Removed From Base Case (Tons/Yr) | 0 | | | | | | | | 16,391 | 18,709 |
| First Year Average Control Cost Compared to Base Case (\$/Ton Removed) | \$0 | | | | | | | | \$1,414 | \$2,019 |
| Incremental Tons Removed - Scenario B vs Scenario A (Tons/Yr) | 0 | | | | | | | | | 2,318 |
| Incremental Control Costs - Scenario B vs Scenario A (\$/Ton Removed) | \$0 | | | | | | | | | \$6,291 |

| INPUT CALCULATIONS | | | | | | | | | | |
|--|---|--------------------------------------|--------------|------------------|-----------------|---|--------------------------------|----------------|--|--|
| DJ3 | Boiler Design: 3-Cell BurnerOpposed Wall-Fired PC | | | | | | | | | |
| PARAMETER | Current Operation | NO _x Control Technologies | | | | SO ₂ and PM Control Technologies | | | Scenario A | Scenario B |
| Control Technologies | Good Practices | LNB w/OFA | ROFA | LNB w/OFA & SNCR | LNB w/OFA & SCR | Dry FGD w/ESP | Upgraded Dry FGD Fabric Filter | Wet FGD w/ ESP | LNB w/OFA Upgraded Dry FGD Fabric Filter | LNB w/OFA & SCR Upgraded Dry FGD Fabric Filter |
| General Plant Design and Operating Data | PC | PC | PC | PC | PC | PC | PC | PC | PC | PC |
| Type of Unit | PC | PC | PC | PC | PC | PC | PC | PC | PC | PC |
| Annual Power Plant Capacity Factor | 90% | 90% | 90% | 90% | 90% | 90% | 90% | 90% | 90% | 90% |
| Annual Operation (Hours/Year) | 7,884 | 7,884 | 7,884 | 7,884 | 7,884 | 7,884 | 7,884 | 7,884 | 7,884 | 7,884 |
| Net Power Output (kW) | 223,214 | 223,214 | 223,214 | 223,214 | 223,214 | 223,214 | 223,214 | 223,214 | 223,214 | 223,214 |
| Net Plant Heat Rate (Btu/kW-Hr) | 12,175 | 12,175 | 12,175 | 12,175 | 12,175 | 12,175 | 12,175 | 12,175 | 12,175 | 12,175 |
| Boiler Heat Input, Measured by Fuel Input (MMBtu/Hr) | 2,718 | 2,718 | 2,718 | 2,718 | 2,718 | 2,718 | 2,718 | 2,718 | 2,718 | 2,718 |
| Annual Heat Input, Measured by Fuel Input (MMBtu/Year) | 21,425,798 | 21,425,798 | 21,425,798 | 21,425,798 | 21,425,798 | 21,425,798 | 21,425,798 | 21,425,798 | 21,425,798 | 21,425,798 |
| Boiler Heat Input, Measured by CEM (MMBtu/Hr) | 2,800 | 2,800 | 2,800 | 2,800 | 2,800 | 2,800 | 2,800 | 2,800 | 2,800 | 2,800 |
| Annual Heat Input, Measured by CEM (MMBtu/Year) | 22,075,200 | 22,075,200 | 22,075,200 | 22,075,200 | 22,075,200 | 22,075,200 | 22,075,200 | 22,075,200 | 22,075,200 | 22,075,200 |
| Plant Fuel Source | Dry Fork PRB | Dry Fork PRB | Dry Fork PRB | Dry Fork PRB | Dry Fork PRB | Dry Fork PRB | Dry Fork PRB | Dry Fork PRB | Dry Fork PRB | Dry Fork PRB |
| Boiler Fuel Source | Dry Fork PRB | Dry Fork PRB | Dry Fork PRB | Dry Fork PRB | Dry Fork PRB | Dry Fork PRB | Dry Fork PRB | Dry Fork PRB | Dry Fork PRB | Dry Fork PRB |
| Coal Heating Value (Btu/Lb) | 7,784 | 7,784 | 7,784 | 7,784 | 7,784 | 7,784 | 7,784 | 7,784 | 7,784 | 7,784 |
| Coal Sulfur Content (wt.%) | 0.47% | 0.47% | 0.47% | 0.47% | 0.47% | 0.47% | 0.47% | 0.47% | 0.47% | 0.47% |
| Coal Ash Content (wt.%) | 5.01% | 5.01% | 5.01% | 5.01% | 5.01% | 5.01% | 5.01% | 5.01% | 5.01% | 5.01% |
| Coal Flow Rate (Lb/Hr) | 349,130 | 349,130 | 349,130 | 349,130 | 349,130 | 349,130 | 349,130 | 349,130 | 349,130 | 349,130 |
| Coal Consumed (Ton/Yr) | 1,376,272 | 1,376,272 | 1,376,272 | 1,376,272 | 1,376,272 | 1,376,272 | 1,376,272 | 1,376,272 | 1,376,272 | 1,376,272 |
| Nitrogen Oxide Emissions | | | | | | | | | | |
| NO _x Emission Rate (Lb/MMBtu) | 0.70 | 0.28 | 0.19 | 0.22 | 0.07 | | | | 0.28 | 0.07 |
| NO _x Emission Rate (Lb/Hr) | 1,960 | 784 | 532 | 616 | 196 | | | | 784 | 196 |
| NO _x Emission Rate (Lb Moles/Hr) | 65.31 | 26.12 | 17.73 | 20.53 | 6.53 | | | | 26.12 | 6.53 |
| NO _x Emission Rate (Ton/Yr) | 7,726 | 3,091 | 2,097 | 2,428 | 773 | | | | 3,091 | 773 |
| Add'l NO _x Removed from Current Operations (Lb/Hr) | 0 | 1,176 | 1,428 | 1,344 | 1,764 | | | | 1,176 | 1,764 |
| Add'l NO _x Removed from Current Operations (Ton/Yr) | 0 | 4,636 | 5,629 | 5,298 | 6,954 | | | | 4,636 | 6,954 |
| Sulfur Dioxide Emissions | | | | | | | | | | |
| Uncontrolled SO ₂ (Lb/MMBtu) | 1.21 | | | | | 1.21 | 1.21 | 1.21 | 1.21 | 1.21 |
| Uncontrolled SO ₂ (Lb/Hr) | 3,378 | | | | | 3,378 | 3,378 | 3,378 | 3,378 | 3,378 |
| Uncontrolled SO ₂ (Lb Moles/Hr) | 52.73 | | | | | 52.73 | 52.73 | 52.73 | 52.73 | 52.73 |
| Uncontrolled SO ₂ (Tons/Yr) | 13,316 | | | | | 13,316 | 13,316 | 13,316 | 13,316 | 13,316 |
| Controlled SO ₂ Emission Rate (Lb/MMBtu) | 1.20 | | | | | 0.22 | 0.15 | 0.06 | 0.15 | 0.15 |
| SO ₂ Removal Efficiency (%) | 0.5% | | | | | 81.8% | 87.6% | 95.0% | 87.6% | 87.6% |
| Controlled SO ₂ Emissions (Lb/Hr) | 3,360 | | | | | 616 | 420 | 168 | 420 | 420 |
| Controlled SO ₂ Emissions (Ton/Yr) | 13,245 | | | | | 2,428 | 1,656 | 662 | 1,656 | 1,656 |
| SO ₂ Removed (Lb/Hr) | 18 | | | | | 2,762 | 2,958 | 3,210 | 2,958 | 2,958 |
| SO ₂ Removed (Ton/Yr) | 71 | | | | | 10,887 | 11,660 | 12,654 | 11,660 | 11,660 |
| Add'l SO ₂ Removed from Current Operations (Lb/Hr) | 0 | | | | | 2,744 | 2,940 | 3,192 | 2,940 | 2,940 |
| Add'l SO ₂ Removed from Current Operations (Ton/Yr) | 0 | | | | | 10,817 | 11,589 | 12,583 | 11,589 | 11,589 |
| Particulate Matter Emissions | | | | | | | | | | |
| Uncontrolled Fly Ash (Lb/Hr) | 13,993 | | | | | 13,993 | 13,993 | 13,993 | 13,993 | 13,993 |
| Uncontrolled Fly Ash (Lb/MMBtu) | 4.998 | | | | | 4.998 | 4.998 | 4.998 | 4.998 | 4.998 |
| Uncontrolled Fly Ash (Tons/Yr) | 55,161 | | | | | 55,161 | 55,161 | 55,161 | 55,161 | 55,161 |
| Controlled Fly Ash Emission Rate (Lb/MMBtu) | 0.030 | | | | | 0.030 | 0.015 | 0.030 | 0.015 | 0.015 |
| Controlled Fly Ash Removal Efficiency (%) | 99.4% | | | | | 99.4% | 99.7% | 99.4% | 99.7% | 99.7% |
| Controlled Fly Ash Emissions (Lb/Hr) | 84 | | | | | 84 | 42 | 84 | 42 | 42 |
| Controlled Fly Ash Emissions (Ton/Yr) | 331 | | | | | 331 | 166 | 331 | 166 | 166 |
| Fly Ash Removed (Lb/Hr) | 13,909 | | | | | 13,909 | 13,951 | 13,909 | 13,951 | 13,951 |
| Fly Ash Removed (Ton/Yr) | 54,830 | | | | | 54,830 | 54,995 | 54,830 | 54,995 | 54,995 |
| Add'l Ash Removed from Current Operation (Lb/Hr) | 0 | | | | | 0 | 42 | 0 | 42 | 42 |
| Add'l Ash Removed from Current Operation (Ton/Yr) | 0 | | | | | 0 | 166 | 0 | 166 | 166 |
| Economic Factors | | | | | | | | | | |
| Interest Rate (%) | 7.10% | 7.10% | 7.10% | 7.10% | 7.10% | 7.10% | 7.10% | 7.10% | 7.10% | 7.10% |
| Discount Rate (%) | 7.10% | 7.10% | 7.10% | 7.10% | 7.10% | 7.10% | 7.10% | 7.10% | 7.10% | 7.10% |
| Plant Economic Life (Years) | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 |

| INPUT CALCULATIONS | | | | | | | | | | |
|--|-------------------|--------------------------------------|------------------------------------|------------------|---------------------------|---|--------------------------------|----------------|--|--|
| DJ3 | Boiler Design: | | 3-Cell BurnerOpposed Wall-Fired PC | | | | | | | |
| PARAMETER | Current Operation | NO _x Control Technologies | | | | SO ₂ and PM Control Technologies | | | Scenario A | Scenario B |
| Control Technologies | | | | | | | | | | |
| NO _x Emission Control System | Good Practices | LNB w/OFA | ROFA | LNB w/OFA & SNCR | LNB w/OFA & SCR | Dry FGD w/ESP | Upgraded Dry FGD Fabric Filter | Wet FGD w/ ESP | LNB w/OFA Upgraded Dry FGD Fabric Filter | LNB w/OFA & SCR Upgraded Dry FGD Fabric Filter |
| SO ₂ Emission Control System | ESP | | | | | | | | | |
| PM Emission Control System | | | | | | | | | | |
| Installed Capital Costs | | | | | | | | | | |
| NO _x Emission Control System (\$2006) | | \$17,500,000 | \$12,054,022 | \$24,035,544 | \$129,700,000 | | | | \$17,500,000 | \$129,700,000 |
| SO ₂ Emission Control System (\$2006) | | | | | | \$91,499,734 | \$169,500,000 | \$144,300,464 | \$169,500,000 | \$169,500,000 |
| PM Emission Control System (\$2006) | | | | | | \$0 | \$0 | \$0 | \$0 | \$0 |
| Total Emission Control System Capital Costs (\$2006) | | \$17,500,000 | \$12,054,022 | \$24,035,544 | \$129,700,000 | \$91,499,734 | \$169,500,000 | \$144,300,464 | \$187,000,000 | \$299,200,000 |
| NO _x Emission Control System (\$/kW) | | \$78 | \$54 | \$108 | \$581 | | | | \$78 | \$581 |
| SO ₂ Emission Control System (\$/kW) | | | | | | \$410 | \$759 | \$646 | \$759 | \$759 |
| PM Emission Control System (\$/kW) | | | | | | | | | | |
| Total Emission Control Capital Costs (\$/kW) | | \$78 | \$54 | \$108 | \$581 | \$410 | \$759 | \$646 | \$838 | \$1,340 |
| Fixed Operating & Maintenance Costs | | | | | | | | | | |
| Operating Labor (\$) | | \$0 | \$0 | \$0 | \$0 | \$506,128 | \$506,128 | \$809,804 | \$506,128 | \$506,128 |
| Maintenance Material (\$) | | \$40,000 | \$60,000 | \$98,000 | \$155,000 | \$714,175 | \$714,175 | \$1,182,587 | \$754,175 | \$869,175 |
| Maintenance Labor (\$) | | \$60,000 | \$90,000 | \$147,000 | \$2,325,000 | \$476,928 | \$476,928 | \$788,391 | \$536,928 | \$2,801,928 |
| Administrative Labor (\$) | | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 |
| Total 1st Fixed Year O&M Cost (\$) | | \$100,000 | \$150,000 | \$245,000 | \$2,480,000 | \$1,697,231 | \$1,697,231 | \$2,780,782 | \$1,797,231 | \$4,177,231 |
| Annual Fixed O&M Cost Escalation Rate (%) | | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% |
| Levelized Fixed O&M Cost (\$/Yr) | | \$118,550 | \$177,825 | \$290,448 | \$2,940,047 | \$2,012,072 | \$2,012,072 | \$3,296,625 | \$2,130,623 | \$4,952,120 |
| Variable Operating & Maintenance Costs | | | | | | | | | | |
| Water Cost | | | | | | | | | | |
| Makeup Water Usage (gpm) | | 0 | 0 | 0 | 0 | 173 | 173 | 230 | 173 | 173 |
| Unit Price (\$/1000 gallons) | | \$1.22 | \$1.22 | \$1.22 | \$1.22 | \$1.22 | \$1.22 | \$1.22 | \$1.22 | \$1.22 |
| First Year Water Cost (\$) | | \$0 | \$0 | \$0 | \$0 | \$99,566 | \$99,566 | \$132,371 | \$99,566 | \$99,566 |
| Annual Water Cost Escalation Rate (%) | | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% |
| Levelized Water Costs (\$/Yr) | | \$0 | \$0 | \$0 | \$0 | \$118,036 | \$118,036 | \$156,926 | \$118,036 | \$118,036 |
| Reagent Cost | | | | | | | | | | |
| Type of Reagent | | None | None | Urea | Anhydrous NH ₃ | Lime | Lime | Lime | Lime | Lime & Anhydrous NH ₃ |
| Unit Cost (\$/Ton) | | \$0.00 | | \$370.00 | \$400.00 | \$91.25 | \$91.25 | \$91.25 | \$91.25 | |
| Unit Cost (\$/Lb) | | \$0.000 | | \$0.185 | \$0.200 | \$0.046 | \$0.046 | \$0.046 | \$0.046 | |
| Molar Stoichiometry | | 0.00 | | 0.41 | 1.00 | 1.15 | 1.15 | 1.02 | 1.02 | |
| Reagent Purity (Wt.%) | | 100% | | 100% | 100% | 90% | 90% | 100% | 100% | |
| Reagent Usage (Lb/Hr) | | | | 39 | 334 | 3,069 | 3,288 | 2,850 | | |
| First Year Reagent Cost (\$) | | \$0 | | \$57,025 | \$526,265 | \$1,104,023 | \$1,182,881 | \$1,025,183 | \$1,182,881 | \$1,709,146 |
| Annual Reagent Cost Escalation Rate (%) | | 2.00% | | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% |
| Levelized Reagent Costs (\$/Yr) | | | | \$67,603 | \$623,889 | \$1,308,822 | \$1,402,309 | \$1,215,358 | \$1,402,309 | \$2,026,198 |
| SCR Catalyst / Fabric Filter Bag Replacement Cost | | | | | | | | | | |
| Material Replaced | | | | | SCR Catalyst | | Bags | | Bags | Bags & SCR Catalyst |
| Annual SCR Catalyst (m3) / No. FF Bags | | | | | 128 | | 1,457 | | | |
| SCR Catalyst (\$/m3) / Bag Cost (\$/ea.) | | | | | \$3,000 | | \$104 | | | |
| First Year SCR Catalyst / Bag Replacement Cost (\$) | | | | | \$384,000 | | \$151,528 | | \$151,528 | \$535,528 |
| Annual SCR Catalyst / Bag Cost Escalation Rate (%) | | | | | 2.00% | | 2.00% | | 2.00% | 2.00% |
| Levelized Catalyst/Fabric Filter Bag Costs (\$/Yr) | | | | | \$455,233 | | \$179,637 | | \$179,637 | \$634,870 |
| FGD Waste Disposal Cost | | | | | | | | | | |
| FGD Solid Waste Disposal Rate, Dry (Lb/Hr) | | | | | | 5,972 | 6,620 | 7,784 | 6,620 | 6,620 |
| FGD Waste Disposal Unit Cost (\$/Dry Ton) | | | | | | \$24.33 | \$24.33 | \$24.33 | \$24.33 | \$24.33 |
| First Year FGD Waste Disposal Cost (\$) | | | | | | \$572,810 | \$634,896 | \$746,581 | \$634,896 | \$634,896 |
| Annual Waste Disposal Cost Esc. Rate (%) | | | | | | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% |
| Levelized Waste Disposal Costs (\$/Yr) | | | | | | \$679,068 | \$752,671 | \$885,074 | \$752,671 | \$752,671 |
| Auxiliary Power Cost | | | | | | | | | | |
| Auxiliary Power Requirement (MW) | | 0.00 | 2.76 | 0.23 | 1.57 | 2.49 | 3.88 | 3.45 | 3.88 | 5.45 |
| Auxiliary Power Requirement (% of Plant Output) | | 0.00% | 1.24% | 0.10% | 0.70% | 1.12% | 1.74% | 1.55% | 1.74% | 2.44% |
| Auxiliary Power Usage (MWh) | | 0 | 21,760 | 1,813 | 12,378 | 19,631 | 30,590 | 27,200 | 30,590 | 42,968 |
| Unit Cost (\$2006/MW-Hr) | | \$50.00 | \$50.00 | \$50.00 | \$50.00 | \$50.00 | \$50.00 | \$50.00 | \$50.00 | \$50.00 |
| First Year Auxiliary Power Cost (\$) | | \$0 | \$1,087,992 | \$90,666 | \$618,894 | \$981,558 | \$1,529,496 | \$1,359,990 | \$1,529,496 | \$2,148,390 |
| Annual Power Cost Escalation Rate (%) | | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% | 2.00% |
| Levelized Auxilliary Power Costs (\$/Yr) | | \$0 | \$1,289,818 | \$107,485 | \$733,701 | \$1,163,640 | \$1,813,222 | \$1,612,272 | \$1,813,222 | \$2,546,923 |