

DPU Data Request 36.8

Plant Additions: Pollution Control

Did the existing scrubber systems (that relate to the projects listed in RMP's response to UAE 3.3) meet the emission control requirements that existed at the time PacifiCorp committed to the upgrade or modification to existing flue gas desulfurization facility?

Response to DPU Data Request 36.8

Unit	SO ₂ Limit Existing Prior to Commitment	Was the Unit Meeting this Rate?	Other Compliance Issues/Concerns With Existing System Prior to Commitment?
Huntington 1	80% removal and 0.21 lb/mmBtu	YES	YES. The waste handling system was unable to deliver a waste product to the landfill void of free liquids at average ash levels. A new reagent preparation facility was not needed on this unit.
Hunter 1	80% removal and 0.21 lb/mmBtu	YES	YES. The waste handling system was unable to deliver a waste product to the landfill void of free liquids at average ash levels. The reagent preparation facility was unable to reliably produce sufficient product for coal sulfur content in excess of 0.6%.
Hunter 2	80% removal and 0.21 lb/mmBtu	YES	YES. The waste handling system was unable to deliver a waste product to the landfill void of free liquids at average ash levels. The reagent preparation facility was unable to reliably produce sufficient product for coal sulfur content in excess of 0.6%.
Jim Bridger 1	0.3 lb/mmBtu	YES	NO
Jim Bridger 2	0.3 lb/mmBtu	YES	NO
Jim Bridger 3	0.3 lb/mmBtu	YES	NO
Jim Bridger 4	0.2 lb/mmBtu and 1,004 lb/hr	YES	NO
Wyodak	0.5 lb/mmBtu	YES	Condition of existing ESP associated with corrosion issues.
Cholla 4	0.8 lb/mmBtu	YES	NO