APPENDIX C

ROCKY MOUNTAIN POWER UTAH NET METERING APPLICATION LEVEL 3 REVIEW CAPACITY OF 2 MW OR LESS

Section 1: For Rocky Mountain Power Use Only			
Customer-Generator Name:			
Service Address:			
City, State, Zip:			
Customer Account No. and Request No:			
Interconnection Agreement Received Acknowledgement (Date):			
Rocky Mountain Power Inspection Needed: Yes No			
Application fee: \$ Date Paid			
Section 2: To Be Completed By Customer-Generator			
A. Applicant Information			
Name:			
Mailing Address:			
City: State: Zip Code:			
Site Street Address (if different from above):			
City: State: Zip Code:			
Daytime Phone: () Fax: ()			
Email:			
B. System Information			
System Type: Solar Wind Hydro Other (Specify):			
Generation Nameplate Capacity: kW (Combine DC total of wind turbines, solar panels, etc. or AC rating if an inverter is not utilized)			
Inverter Manufacturer: Model: Number of Inverters: Rating: kW			
Manufacturer Nameplate Inverter Total AC Capacity Rating: kW			
Inverter(s): Single Phase Three Phase Multiple Single Phase Connected on Poly-phase (three phase) system – (Attach Inverter and Panel Technical Specifications Sheets)			
Type: Induction Inverter Synchronous Other			
Type of Service: Single Phase Three Phase			

Salfid	Contained Location:
Outdo	oor Manual AC Disconnect Switch Location (show Disconnect Switch and Rocky Mountain Por Location on Site Plan), unless exempt under Utah Administrative Rule 746-312-4(2):
System	m Location (show all protective devices on One Line Diagram):
Will t	he net metering facility interconnect to a switchgear? Yes No
accord meter discon	mer-Generator must post metal or plastic engraved signage indicating on-site generation in ance with National Electric Code. The signage must be permanent and located adjacent to the base and disconnect switch noting "Parallel Generation on Site" and identifying the manual nect switch with the words "Manual Disconnect for Parallel Generation." S
One I	ine Diagram Attached: Yes No Site Plan Attached: Yes No
Instal	lation Test Plan attached: Yes No
	ipated Operational Date of Net Metering Facilities:
	nt short circuit interrupting capability Net metering facility available fault duty at the point of onnection distribution circuit common coupling:
(A Ro	ocky Mountain Power Engineer may contact you for additional information)
Electr	rical Inspection approval date (attach copy or provide to utility when obtained):
	lication Fees
\$ + \$	100.00 Base \$2.00 x kW of net metering facility's capacity
+ \$	TOTAL APPLICATION FEE
	tional Information
Addi	***
Addi 1.	An equipment package will be considered certified for interconnected operation if it has been submitted by a manufacturer to a nationally recognized testing and certification laboratory, at has been tested and listed by the laboratory for continuous interactive operation with an elect distribution system in compliance with the applicable IEEE and UL 1741 standards in the Ru

Mountain Power will not require any further design review, testing or additional information. If the equipment package includes only the interface components (switchgears, inverters, or other

interface devices), an interconnection applicant must show that the generator or other electric

3.

source being utilized with the equipment package is compatible with the equipment package and consistent with the testing and listing specified for the package. If the generator or electric source being utilized with the equipment package is consistent with the testing and listing performed by the nationally recognized testing and certification laboratory, the equipment package will be deemed certified and Rocky Mountain Power will not require further design review, testing or additional equipment.

- 4. A net metering facility must be equipped with metering equipment that can measure the flow of electricity in both directions, comply with ANSI C12.1 standards and Utah Administrative Rule R746-312. Rocky Mountain Power will install the required metering equipment at Rocky Mountain Power's expense.
- 5. Customer Generator must post signage indicating on site generation in accordance with NEC 110.22 and 430.102. The signage must be permanent and located adjacent to the meter base and disconnect switch noting "Parallel Generation on Site" and identifying the manual disconnect switch with the words "Manual Disconnect for Parallel Generation." The sign shall be of sufficient durability to withstand the environment involved.
- 6.5. Rocky Mountain Power will not be responsible for the cost of determining the rating of equipment

owned by the customer-generator or of equipment owned by other local customers.

- 7.6. Customer—Generator may operate the Net Metering Facility temporarily for testing and obtaining inspection approval. Customer—Generator shall not operate the Net Metering Facility in continuous parallel without an executed Interconnection and Net Metering Service Agreement, and approval from Rocky Mountain Power.
- 8.7. Customer—generator will pay to Rocky Mountain Power at the time of application the applicable Application fee of \$100.00 plus \$2.00 per kilowatt of the net metering facility's capacity; and costs of modifications or additional review as set forth in Utah Administrative Rule R746-312.

E Customer-generator Acknowledgment

I certify that the information provided in this Application is true. I will provide Rocky Mountain Power a copy of the signed government electrical inspection approval document when obtained, if not already provided with this Application.

I agree to abide by the terms of this Application and I agree to notify Rocky Mountain Power thirty (30) days prior to modification or replacement of the System's components or design. Any such modification or replacement may require submission of a new Application to Rocky Mountain Power.

I agree not to operate the Net Metering Facility in parallel with Rocky Mountain Power, except
temporarily for testing and obtaining inspection approval, until this Application is approved by Rocky
Mountain Power, until this agreement is signed by both parties, and until I have provided Rocky
Mountain Power with at least ten (10 five (5)) days notice of anticipated start date.

-Customer-Generator or Applicant:	 Signature & Date

Please send completed application to:

Rocky Mountain Power

Please scan the completed application and email

Customer Generation		
 Customer Generation	or	netmetering@pacificorp.com
P.O. Box 25308		
Salt Lake City, UT 84125-0308		
Phone: (888) 221-7070		
Of		
Please scan the completed applica	tion and email	to:
netmetering@pacificorp.com		

Section 3. To be completed by <u>System</u> Install <u>eration Contractor (if available)</u>				
Installation Contractor Inform	nation/Hardware	and Installation Complia	ance	
Installation Contractor (Compar	ny Name):			
Contractor's License No.:		Proposed Insta	llation Date:	
Mailing Address:				
City:		State:	Zip Code:	
Daytime Phone:	Fax:	Email:		
For inverter-controlled system, meets IEEE Standards and UL 1741 Inverters, Converters, and Controllers for use in Independent Power Systems as set forth in the Rule: Yes No				
For induction or synchronous do as set forth in the Rule: Yes		Standard 1547 and IEEE/A	ANSI Standard C37.90 requirements	
If Photovoltaic System, System must be installed in compliance with IEEE Standards, Recommended Practice for Utility Interface of Photovoltaic Systems. All System types must be installed in compliance with applicable requirements of local electrical codes, Rocky Mountain Power and the National Electrical Code® (NEC) and must use a nonan anti-islanding inverter.				
The System must include a manual, lockable, load-break (disconnect) switch, unless exempt under Utah Administrative Rule 746-312-4(2), accessible at all times to Rocky Mountain Power personnel and located within 10 feet of Rocky Mountain Power's meter. The disconnect switch may be located more than 10 feet from Rocky Mountain Power's meter if permanent instructions are posted at the meter indicating the precise location of the disconnect switch. Rocky Mountain Power must approve the location of the disconnect switch prior to the installation of the net metering facility.				
If the Net Metering Facility is designed to provide uninterruptible power to critical loads, either through energy storage, back-up generator, or the generation source, the Net Metering Facility will include a parallel blocking scheme for this backup source. This function may be integral to the inverter manufacturer's packaged system.				
Does the Net Metering Facility	include a parallel b	locking scheme: Yes	☐ No	
Signed (Contractor):		D	Date:	

Name (Print):
Section 4. To be completed by Decky Mountain Dowers
Section 4. To be completed by Rocky Mountain Power:
A. If approving the application:
Rocky Mountain Power does not, by approval of this Application, assume any responsibility or liability for
damage to property or physical injury to persons. Further, this Application does not constitute a dedication of the owner's System to Rocky Mountain Power electrical system equipment or facilities.
Customer-Generator entered into an Interconnection and Net Metering Service Agreement with Rocky Mountain Power on the day of, 20
Customer-Generator satisfactorily passed Witness Commissioning Tests on the day of, 20
(Rocky Mountain Power may waive <u>WitnessCommissioning</u> Tests at its option; if tests are waived initial here)
This Application is approved by Rocky Mountain Power on this day of, 20
Rocky Mountain Power Representative Name (Print):
Signed (Rocky Mountain Power Representative): Date:
B. If denying the application:
This application is denied by Rocky Mountain Power on this day of, 20 for the following reason(s):
Rocky Mountain Power Representative Name (Print):
Signed (Rocky Mountain Power Representative): Date:
Section 5. To be completed by Rocky Mountain Power Meterman
Customer Account No Site ID No. :
Served from Facility Point No.:
New Net Meter No.: Date net meter installed:
Manual disconnect device in proper location and permanent signage in place: Yes No
Signature/Title: Date: