## **APPENDIX A**

## ROCKY MOUNTAIN POWER UTAH NET METERING APPLICATION LEVEL 1 REVIEW INVERTER BASED SYSTEMS, 25 KW OR SMALLER

Section 1: For Rocky Mountain Power Use Only
Customer-Generator-Name:
Service Address:
City, State, Zip:
Customer Account No. & Request No.:
Interconnection Agreement Received Acknowledgement (Date)::
<u>):</u>
Section 2: To Be Completed By Customer-Generator
A. Applicant Information
Name:
Mailing Address:
City:State: Zip Code:
Site Street Address (if different from above):
City:State: Zip Code:
Daytime Phone: () Fax: ()
Email:
B. System Information
System Type: Solar Wind Hydro Other (Specify):
Generation Nameplate Capacity: kW (Combine DC total of wind turbines, solar panels, etc)
Inverter Controlled: Yes No
Inverter Manufacture <u>r</u> : Model: Number of Inverters: Rating: kW
Manufacturer Nameplate Inverter Total AC Capacity Rating: kW
Type of Service: Inverter(s):  Single Phase  Three Phase_  Multiple Single Phase    Connected on Poly-phase (three phase) system – (Attach Inverter and Panel Technical Specifications Sheets)  Single Phase  Single Phase
Type of Service: Single Phase Three Phase
Meets IEEE standard 1547 & UL Subject 1741 requirements as specified in Rule: 🗌 Yes 🗌 No

Please note: A disconnect switch is not required for an inverter-based facility with a name plate rating of not more than 10 kW.
Manual disconnect required: Yes No
Will the net metering facility interconnect to a switchgear? Yes No
Net metering facility available fault duty at the point of common coupling:
For other service types, the net metering facility must not impact the Customer-Generator's service conductors by more than 10 kW. If a disconnect switch is installed, Customer-Generator to provide a simple one-line diagram that shows the location of the disconnect switch and Rocky Mountain Power meter.
"Parallel Generation Onsite"    Customer-Generator must post metal or plastic engraved signage posted as required by the latest edition of the indicating on-site generation in accordance with National Electric Code Section 110.22. The signage must be permanent and 430.102: located adjacent to the meter base and disconnect switch noting "Parallel Generation on Site" and identifying the manual disconnect switch with the words "Manual Disconnect for Parallel Generation."    Yes  No
Electrical Inspection approval date (attach copy or provide to utility when obtained):
Anticipated Operational Date of Net Metering Facilities:
Customer-Generator may operate the Net Metering Facility temporarily for testing and obtaining inspection approval. Customer-Generator shall not operate the Net Metering Facility in continuous parallel without an executed Interconnection and Net Metering Service Agreement.
I hereby certify that the information provided in this Application is true. I will provide Rocky Mountain Power a copy of signed government electrical inspection approval when obtained.
Customer-Generator or Applicant Signature & Date:
Please send completed application to:
Rocky Mountain Power    Customer Generation  Or  Scan the completed application/agreement and email to:    P.O. Box 25308  netmetering@pacificorp.com    Salt Lake City, Utah 84125-0308  Phone: (888) 221-7070
C. Additional Information
1.    An equipment package will be considered certified for interconnected operation if it has      been submitted by a manufacturer to a nationally recognized testing and certification      laboratory, and has been tested and listed by the laboratory for continuous interactive      operation with an electric distribution system in compliance with the applicable IEEE and
UL 1741 standards in the Rule.    2.  If the equipment package has been tested and listed as an integrated package, which includes a generator or other electric source, the equipment package will be deemed

	certified, and Rocky Mountain Power will not require any further design review, testing or						
	additional information.						
<u>3.</u>	If the equipment package includes only the interface components (switchgears, inverters,						
	or other interface devices), an interconnection applicant must show that the generator or other electric source being utilized with the equipment peckage is compatible with the						
	other electric source being utilized with the equipment package is compatible with the equipment package and consistent with the testing and listing specified for the package. If						
	the generator or electric source being utilized with the equipment package is consistent						
	with the testing and listing performed by the nationally recognized testing and						
	certification laboratory, the equipment package will be deemed certified and Rocky						
	Mountain Power will not require further design review, testing or additional equipment.						
4.	A net metering facility must be equipped with metering equipment that can measure the						
flow of electricity in both directions, comply with ANSI C12.1 standards and U							
	Administrative Rule R746-312. Rocky Mountain Power will install the required metering						
	equipment at Rocky Mountain Power's expense.						
<u>5.</u>							
	equipment owned by the customer-generator or of equipment owned by other local						
	customers.						
<del>1.<u>6.</u></del>	Customer-Generator may operate the Net Metering Facility temporarily for testing and						
	obtaining inspection approval. Customer-Generator shall not operate the Net Metering						
	Facility in continuous parallel without an executed Interconnection and Net Metering						
	Service Agreement, and approval from Rocky Mountain Power.						
D. Cust	omer <del>-generator</del> Acknowledgment						
<u>I cert</u>	I certify that the information provided in this Application is true. I will provide Rocky Mountain						
Powe	Power a copy of the signed government electrical inspection approval document when obtained, if						
not already provided with this Application.							
I agree to abide by the terms of this Application and I agree to notify Rocky Mountain Power							
thirty (30) days prior to modification or replacement of the System's components or design. Any							
such modification or replacement may require submission of a new Application to Rocky							
Mountain Power.							
Lage	as not to operate the Net Metering Facility in negallel with Booky Mountain Dower, execut						
	ee not to operate the Net Metering Facility in parallel with Rocky Mountain Power, except						
temporarily for testing and obtaining inspection approval, until this Application is approved by Rocky Mountain Power, until this agreement is signed by both parties, and until I have provided							
Rocky Mountain Power, until this agreement is signed by both parties, and until I have provided Rocky Mountain Power with at least five (5) days notice of anticipated start date.							
Custo	omer-Generator or Applicant Signature & Date:						
Pleas	e send completed application to:						
D 1							
	y Mountain Power Please scan the completed application and						
email Custo							
	omer Generationornetmetering@pacificorp.comBox 25308						
	Lake City, UT 84125-0308						
	e: (888) 221-7070						
E HILDI	E 1000 ZZI-7U/U						

Section 3: To be completed by the Syste	em Installer <del>(if available</del>	<del>)</del>		
Installation Contractor Information/Har	dware and Installation	Compliance		
Installation Contractor (Company Name): _				
Contractor's License No.:	Proposed Insta	Illation Date:		
Mailing Address:				
City:	State:	Zip Code:		
Daytime Phone: Fax:	Email: _			
For inverter-controlled system, meets IEEE Controllers for use in Independent Power S				
If Photovoltaic System, System must be installed in compliance with IEEE Standards, Recommended Practice for Utility Interface of Photovoltaic Systems. All System types must be installed in compliance with applicable requirements of local electrical codes, Rocky Mountain Power and the National Electrical ¢ode® (NEC) and must use <u>a nonan anti</u> -islanding inverter.				
The System must include a manual, lockable, load-break (disconnect) switch, unless exempt under Rule 746-312-4(2), accessible at all times to Rocky Mountain Power personnel and located within 10 feet of Rocky Mountain Power's meter. The disconnect switch may be located more than 10 feet from Rocky Mountain Power's meter if permanent instructions are posted at the meter indicating the precise location of the disconnect switch. Rocky Mountain Power must approve the location of the disconnect switch prior to the installation of the net metering facility.				
If the Net Metering Facility is designed to p energy storage, back-up generator, or the ge parallel blocking scheme for this backup so manufacturer's packaged system.	eneration source, the Net	Metering Facility will include a		
Does the Net Metering Facility include a pa	arallel blocking scheme: [	Yes No		
Signed (Contractor): Name (Print):				
Section 4. To be completed by Rocky M	lountain Power:			

## A. If approving the application:

Rocky Mountain Power does not, by approval of this Application, assume any responsibility or liability for damage to property or physical injury to persons. Further, this Application does not constitute a dedication of the Power electrical system equipment or facilities.

Customer-Generator entered into an Interconnection and Net Metering Service Agreement with Rocky Mountain 20\_\_\_.

Customer-Generator satisfactorily passed CommissioningWitness Tests on the \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_.

(Rocky Mountain Power may waive CommissioningWitness Tests at its option; if tests are waived initial here \_\_\_\_

This Application is approved by Rocky Mountain Power on this \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_

Rocky Mountain Power Representative Name (Print):			
B. If denying the application: This application is denied by Rocky Mountain Power on this day of			
Rocky Mountain Power Representative Name (Print):			
Section 5: To be completed by Rocky Mountain Power Meterman			
Customer Account No Site ID No. :			
Served from Facility Point No.:			
New Net Meter No.: Date net meter installed:			
Manual disconnect required: Yes No Proper location & permanent signage in place: Ye	s 🗌 No		
Signature/Title: Date:			