

## P.S.C.U. No. 49

# **ELECTRIC SERVICE REGULATION - Continued**

#### (c) Clearances

Whenever the initial clearances of serving facilities over the Customer's premises, required by applicable laws, ordinances, rules, or regulations of public authorities, become inadequate due to changes made by the Customer, the Customer shall be responsible for correction of the deficiency. Such correction may require the Customer provide, at his/her own expense, a new approved support for connection of the Company's serving facilities as well as new service entrance facilities.

## 2. CUSTOMER'S LOAD AND OPERATION

## (a) **Protection of Customer's Equipment**

The Customer shall furnish, install, inspect and keep in good and safe condition all electrical wires and lines on the Customer's side of the point of delivery. The Customer shall provide devices to protect his/her equipment from high and low voltage, overload, single phasing, phase reversal or other abnormal conditions.

## (b) **Protection of the Company's Equipment and other Customers**

The Customer shall provide control equipment to eliminate excessive starting current or undesirable voltage fluctuations on the Company's circuits. If the Customer makes any substantial additions or changes in his/her electrical facilities, either in size or character, the Customer shall give the Company prior written notice of this fact. Any such additions or changes in load shall be of such size that it is not a detriment to the furnishing of service to other Customers.

#### (c) Customers with Self-Generation

Service will be furnished to a Customer with self-generation only by written agreement. Such agreement shall specify the terms and conditions governing the furnishing of service including the Company's Parallel Generation Interconnection Requirements. The Customer's generating facilities will be allowed to be interconnected with the Company's facilities upon compliance with the provisions of this agreement and upon acceptance by the Company of a performance test for proper interconnection equipment operation. It shall be the responsibility of the

(continued)

Issued by authority of Report and Order of the Public Service Commission of Utah in Docket No. 11-035-200