

---

**ELECTRIC SERVICE REGULATION NO. 7 – Continued**

**1. INSTALLATION (continued)**

When a complaint is received from a customer (landlord or tenant) or government agency of possible switched meters, the Company will check such meter installations to verify that they are correctly labeled. The Company will charge the Meter Verification Fee, as set forth in Schedule 300, to the owner for each meter installation checked. If all meters at a building are correctly labeled for each unit the Company will waive the Meter Verification Fee for that building.

If a developer/owner or landlord requests the Company to verify or certify that each meter base is labeled correctly, including when locations with multiple units are sold, the Company will charge the party requesting such verification or certification the Meter Verification Fee as set forth in Schedule 300.

**2. METER TESTS**

The Company will test and inspect its meters from time to time and maintain their accuracy of registration in accordance with generally accepted practices and the rules and standards established by the Public Service Commission of Utah. Upon request, the Company shall promptly and without charge test the accuracy of a customer's meter.

If the meter has been tested within 12 months preceding the date of the request, the Company may require the customer to make a deposit as provided in Schedule 300. The deposit shall not exceed the estimated cost of performing the test. If the meter is found to have an error of more than two percent of the tested capacity, the deposit shall be refunded; otherwise, the deposit may be retained by the Company as a service charge. Customers shall be entitled to observe tests, and the Company shall provide test reports to customers.

In the event of a dispute, the customer may request a referee test in writing. The Commission may require the deposit of a testing fee. Upon filing of the request and receipt of the deposit, if required, the Commission shall notify the Company to arrange for the test. The Company shall not remove the meter prior to the test without Commission approval. The meter shall be tested in the presence of a Commission representative, and if the meter is found to be inaccurate by more than two percent of tested capacity, the customer's deposit shall be refunded; otherwise, it shall be retained.

(continued)