



Net Metering Workgroup Session I

Docket No. 14-035-114

April 27, 2015

Prepared for

Utah Department of Commerce
Division of Public Utilities


Prepared by

Ben Norris,
Clean Power Research
on behalf of Utah Clean Energy

PV Power Maps

January to December 2014

January 2014




Copyright © 2015 Clean Power Research



Agenda


- Solar characteristics in Utah
- Impacts of solar in the distribution system
- Differences between utility-scale and distributed solar



Solar Characteristics in Utah


Load Match Between Solar and System

PacifiCorp East + West, 2012




How to Improve Load Match Analysis

- For generation coincidence, should use load data from PacifiCorp East load balancing area (not available to public)
- For distribution coincidence, should use load data from RMP Utah (not available to public)
- Solar modeling should be based on fleet data, rather than a single system




Production Profiles by Orientation

(For illustration)




Capacity “Buckets” by Orientation (and location)

(Austin Energy – used for illustration)




Why do Fleet Modeling?


SDG&E peak day, 2012 (September 14)



Impact on 2012 Peak Load Day (Preliminary)

PacificCorp East+West, July 12, 2012





Impacts of solar in the distribution system



Hawaiian Electric Experience

Hawaiian Electric has the highest DG penetration in the nation. A company filing to the state PUC on DER Policies, Jan 20, 2015, Docket No. 2014-0192:

- Proposes to raise circuit penetration threshold for transient overvoltage from 120% of “gross minimum daily load” to 250% based on inverter testing (load rejection overvoltage, “LRO”) with NREL, EPRI, and Solar City.
- Proposes to monitor impacts on safety and reliability (circuit and system).
- Proposes requiring advanced inverters.
- Proposes to make strategic and cost-effective capital investments to upgrade circuits to support increased thresholds. Seeks collaboration with stakeholders to identify high demand / high benefit circuits.
- Proposes that costs be treated as grid improvements that benefit all customers (paid by all, not just those installing DG).

Utah PV Penetration

| | Utah (2014) 9 – 15 ¢/kWh | Utah, 10-yr forecast (2024) | California ISO (2014) 16-33 ¢/kWh | Hawaiian Electric (Oahu, 2014) 25-28 ¢/kWh |
|----------------------------|------------------------------------|-----------------------------------|---|---|
| [A] Installed BTM Solar | 14 MW | 175 MW ^[2] | 5,655 MW ^[4] | 283 MW ^[6] |
| [B] Peak Load | 5,024 MW ^[1] | 5,935 MW ^[3] | 45,089 MW ^[5] | 1,200 MW ^[7] |
| Penetration = [A] / [B] | 0.3% | 2.9% | 13% | 24% (85 x Utah) |

[1] Non-coincident Jurisdictional Peak for Utah, 2014, from PacifiCorp 2015 IRP, Table A.6.

[2] PacifiCorp 2015 IRP (Utah only), developed by Navigant.

[3] Assumes 10-year forecasted average coincident peak load growth rate for Utah (1.68% per year), 2015-24, from PacifiCorp 2015 IRP, Table A.2.

[4] Compiled by Clean Power Research (MW-DC) for PG&E, SCE and SDG&E.

[5] California ISO.

[6] HECO, filing to PUC 1/20/2015.

[7] HECO 2013 IRP.



Technical Interconnection Issues

- Voltage fluctuations
 - Fluctuations in voltage may be caused by cloud transients, requiring additional voltage regulation
 - Aggregations of systems can smooth output
 - Advanced inverters can mitigate
- Circuit protection not designed for backfeed
 - With DG, power can flow in both directions
 - May require upgrades to protective devices and new coordination (protection designs were based on one-way flow only)
- Distribution transformer sizing
 - Output of solar may exceed the rated capacity of the existing transformer
 - May require upgrade to accept higher power




Advanced Inverters

- Advanced inverters can:
 - Act like variable capacitors (source or sink reactive power) - mitigate voltage swings
 - Provide voltage and frequency ride through – improve system reliability
 - If used, would not only mitigate PV impacts, but potentially improve stability and reliability
- “Advanced” inverters use old technology, but new interconnection standards.
 - Rules do not currently allow inverters to control voltage. New standards are being developed by IEEE P1547 Working Group. Utah may wish to keep abreast of this.



Cost impacts

- Upgrades to voltage regulation, distribution transformers, protective devices
- Highly site specific
 - Requirements are specific to circuit, location and proposed installation
 - Some installations require significant upgrade, some require nothing (e.g., small PV system on heavily loaded circuit will not have significant impact)
 - Depends on other DG already installed (“hot potato”)



Difference between utility-scale and distributed solar



Design Differences: Utility Scale vs DG

- Orientation
 - DG often conforms to roof slopes
 - Commercial vs residential fleet shapes
- Tracking
 - Utility scale often designed to track the path of the sun
- Aggregation
 - Distributed systems:
 - Are more widely dispersed (more smoothing)
 - Are higher in redundancy (more reliability)

Valuation Differences: Utility Scale vs Distributed

(Illustrative - categories may not apply to Utah)

Distributed Solar

| Gross Value | Load Match Factor | Loss Savings Factor | Distributed PV Value |
|-------------|-------------------|---------------------|----------------------|
| A | × B | × (1+C) | = D |
| (\$/kWh) | (%) | (%) | (\$/kWh) |

| | | | | | |
|-------------------------------|-----------------------------------|----|-----|------------|----|
| Energy Supply | Avoided Fuel Cost | C1 | | LSF-Energy | V1 |
| | Avoided Variable O&M Cost | C2 | | LSF-Energy | V2 |
| | Avoided Fixed O&M Cost | C3 | EC | LSF-EC | V3 |
| | Avoided Gen. Capacity Cost | C4 | EC | LSF-EC | V4 |
| Transmission and Distribution | Avoided Trans. Capacity Cost | C5 | EC | LSF-EC | V5 |
| | Avoided Dist. Capacity Cost | C6 | PLR | LSF-Dist | V6 |
| Environmental | Avoided Environmental Compliance | C7 | | LSF-Energy | V7 |
| | Avoided SO ₂ Emissions | C8 | | LSF-Energy | V8 |
| Customer | Avoided Fuel Price Uncertainty | C9 | | LSF-Energy | V9 |

Total

Valuation Differences: Utility Scale vs Distributed

(Illustrative - categories may not apply to Utah)


Utility Scale Solar

| Gross Value | Load Match Factor | Loss Savings Factor | Distributed PV Value |
|-------------|-------------------|---------------------|----------------------|
| A | × B | × (1+C) | = D |
| (\$/kWh) | (%) | (%) | (\$/kWh) |

| | | | | | |
|-------------------------------|-----------------------------------|----|-----|------------|----|
| Energy Supply | Avoided Fuel Cost | C1 | | LSF-Energy | V1 |
| | Avoided Variable O&M Cost | C2 | | LSF-Energy | V2 |
| | Avoided Fixed O&M Cost | C3 | EC | LSF-EC | V3 |
| | Avoided Gen. Capacity Cost | C4 | EC | LSF-EC | V4 |
| Transmission and Distribution | Avoided Trans. Capacity Cost | C5 | EC | LSF-EC | V5 |
| | Avoided Dist. Capacity Cost | C6 | PLR | LSF-Dist | V6 |
| Environmental | Avoided Environmental Compliance | C7 | | LSF-Energy | V7 |
| | Avoided SO ₂ Emissions | C8 | | LSF-Energy | V8 |
| Customer | Avoided Fuel Price Uncertainty | C9 | | LSF-Energy | V9 |


Total


Avoiding T&D Losses with DG



Avoided Distribution Capacity Costs

Peak Load Reduction – Illustrative (not Utah loads)





What Costs Should Be Included in the Distribution Capacity Value Calculation?

- Only capital costs
- Only equipment that PV can defer/avoid (“capacity related”)

Example 1: SCADA Communications Gear

Analysis: This equipment is needed to provide operators with real-time information about the grid. It is needed whether PV is present or not.

Conclusion: Do not include this as a deferrable cost.

Example 2: Substation Transformer


Analysis: This equipment is needed to serve all load in the area. If the load reaches the transformer capacity limit, it has to be replaced with a larger unit. DG can reduce the load on this equipment and potentially delay the investment of a new unit.

Conclusion: Include this as a potentially deferrable cost (depends on load match).



Thank you



Ben Norris
ben@cleanpower.com



Appendix



Measured data at two high-density networks

| Location | Cordelia Junction, CA | Napa, CA |
|-------------------------|-----------------------|----------------------|
| Grid Size | 400 m x 400 m | 4 km x 4 km |
| Representative Capacity | 4 MW | 400 MW |
| Data collection rate | 10 seconds | 10 seconds |
| Data collection period | 11/6/10 to 11/12/10 | 11/19/10 to 11/23/10 |





10-second data in 4 km grid (11/21/10)

Combining output from multiple locations reduces variability




10-second data in 400 meter grid (11/10/10)

Combining output from multiple locations reduces variability



Generation Relates Linearly to Avg. Losses

Example of marginal loss savings calculation for a given hour



| | Without PV | With PV | Change |
|--------------|------------|----------|------------|
| Generation | 10,000 MW | 9,000 MW | 1,000 MW |
| Avg. Losses | 10% | 9% | |
| Losses | 1,000 MW | 810 MW | 190 MW |
| Loss Savings | | | 19% |

Example Account Evaluation

| Account | Account Name | Additions (\$) [A] | Retirements (\$) [R] | Net Additions (\$) = [A] - [R] | Capacity Related? | Deferable (\$) |
|--------------|---|----------------------|----------------------|--------------------------------|-------------------|-----------------------|
| | DISTRIBUTION PLANT | | | | | |
| 360 | Land and Land Rights | 13,931,928 | 233,588 | 13,698,340 | 100% | 13,698,340 |
| 361 | Structures and Improvements | 35,910,551 | 279,744 | 35,630,807 | 100% | 35,630,807 |
| 362 | Station Equipment | 478,389,052 | 20,808,913 | 457,580,139 | 100% | 457,580,139 |
| 363 | Storage Battery Equipment | | | | | |
| 364 | Poles, Towers, and Fixtures | 310,476,864 | 9,489,470 | 300,987,394 | | |
| 365 | Overhead Conductors and Devices | 349,818,997 | 22,090,380 | 327,728,617 | 25% | 81,932,154 |
| 366 | Underground Conduit | 210,115,953 | 10,512,018 | 199,603,935 | 25% | 49,900,984 |
| 367 | Underground Conductors and Devices | 902,527,963 | 32,232,966 | 870,294,997 | 25% | 217,573,749 |
| 368 | Line Transformers | 389,984,149 | 19,941,075 | 370,043,074 | 10% | 37,004,307 |
| 369 | Services | 267,451,206 | 5,014,559 | 262,436,647 | | |
| 370 | Meters | 118,461,196 | 4,371,827 | 114,089,369 | | |
| 371 | Installations on Customer Premises | 22,705,193 | | 22,705,193 | | |
| 372 | Leased Property on Customer Premises | | | | | |
| 373 | Street Lighting and Signal Systems | 53,413,993 | 3,022,447 | 50,391,546 | | |
| 374 | Asset Retirement Costs for Distribution Plant | 15,474,098 | 2,432,400 | 13,041,698 | | |
| TOTAL | | 3,168,661,143 | 130,429,387 | 3,038,231,756 | | \$ 893,320,481 |

Est. 28% of distribution 2012 capital investments were potentially deferrable by DG