

**ELECTRIC SERVICE SCHEDULE NO. 110 - Continued**
**Table 2. Builder Incentive Levels and Qualifying Equipment for Multi-Family Residences**

| Utah Multi-Family          |   |              |
|----------------------------|---|--------------|
| Tier/Measure               | Equipment   | Incentive    |
| <b>Multi-Family Tier 1</b> | For 5-12 contiguous units: Meet ENERGY STAR v 2.0 specifications including performance-based duct sealing, air conditioner equipment minimum standard of SEER 13**, A/C equipment commissioning, performance testing, correct sizing, best practices installation and the thermal bypass checklist; plus installation of CFLs in 50% of all light sockets, ENERGY STAR appliance package (dishwasher, washer, refrigerator where permanently installed)       | <b>\$300</b> |
| <b>Multi-Family Tier 2</b> | For 13 or more contiguous units: Meet ENERGY STAR v 2.0 specifications including performance-based duct sealing, air conditioner equipment minimum standard of SEER 13**, A/C equipment commissioning, performance testing, correct sizing, best practices installation and the thermal bypass checklist; plus installation of CFLs in 50% of all light sockets, ENERGY STAR appliance package (dishwasher, washer, refrigerator where permanently installed) | <b>\$200</b> |
| <b>Plus Measure*</b>       | Lighting Upgrade to 90% ENERGY STAR CFLs (from base of 50% CFLs)  | <b>\$35</b>  |
| <b>Plus Measure*</b>       | 14 SEER*** HVAC equipment with correct sizing and best practices installation   | <b>\$100</b> |

Notes for Table 2

1. \*Plus measures must be installed in conjunction with the Multi-Family Tiers package to be eligible for incentives.
2. \*\*Packaged Terminal Air Conditioning (PTAC) units which exceed federal minimum standards of 10.0 EER may be substituted for SEER 13 AC units in Tiers 1 and 2.
3. \*\*\*Packaged Terminal Air Conditioning (PTAC) units which exceed federal minimum standards of 11.5 EER may be substituted for SEER 14 A/C units.
4. All compact fluorescent lamps (CFLs) must be ENERGY STAR qualified to be eligible for incentives.
5. All qualifying homes must have a qualifying air conditioner or evaporative cooler.

(continued)