

ELECTRIC SERVICE REGULATION NO. 4 - Continued

5. CONTINUITY OF SERVICE (continued)

- (c) Automatic or manual actions taken by the Company, which in its sole judgment are necessary or prudent to protect the performance, integrity, reliability or stability of the Company's electric system or any electrical system with which it is interconnected. Such actions shall include, but shall not be limited to, the operation of automatic or manual protection equipment installed in the Company's electrical system, including, without limitation, such equipment as automatic relays, generator controls, circuit breakers and switches.