

**ROCKY MOUNTAIN POWER
ELECTRIC SERVICE REGULATION NO. 7**

STATE OF UTAH

Metering

1. INSTALLATION

All meter locations and provisions for connecting metering equipment are subject to approval by the Company. Meter locations shall be consistent with good engineering and safety practices and shall comply with appropriate codes and standards.

The Company will install, own and maintain all meters and other metering devices (excluding the meter base\cabinets) necessary for measuring the electric power and energy used by the Customer.

Separate premises, even though owned by the same Customer, will not be supplied through the same meter, except as may be specifically provided for in the applicable electric service schedule.

Demand meters may be installed at the Company's option on any account when the nature of the Customer's equipment and operation indicates that a demand meter may be required for correct application of the electric service schedule.

When multiple meters are installed at a location with multiple units, it is the developer/owner's responsibility to permanently, and correctly, label each meter base for the associated service address. The Company may check such meter installations to verify they are correctly labeled. The Company will charge the Meter Verification Fee set forth in Schedule 300, to the developer/owner for each meter installation checked. In the event all meters are labeled correctly for each unit the Company will waive the Meter Verification Fee for that building.

(continued)