

ELECTRIC SERVICE SCHEDULE NO. 140 - Continued
Table 3a – HVAC Incentives

| Equipment Type | Size Category | Sub-Category | Minimum Efficiency Requirement & Incentive "up to" | | |
|--|-------------------------------------|---------------------------------|--|----------------------|------------|
| | | | \$25/ton | \$50/ton | \$75/ton |
| Unitary Commercial Air Conditioners, Air-Cooled (Cooling Mode) | < 65, 000 Btu/hr (single phase) | Split system and single package | -- | CEE Tier 2 | |
| | All equipment sizes (three phase) | Split system and single package | -- | CEE Tier 1 | CEE Tier 2 |
| Unitary Commercial Air Conditioners, Water and Evaporatively Cooled (See Note 8) | All equipment sizes | Split system and single package | -- | CEE Tier 1 | -- |
| Packaged Terminal Air Conditioners (PTAC) (Cooling Mode) | ≤ 8,000 Btu/hr | Single package | 12.2 EER | -- | -- |
| | > 8,000 Btu/hr and < 10,500 Btu/hr | Single package | 11.9 EER | -- | -- |
| | ≥ 10,500 Btu/hr and ≤ 13,500 Btu/hr | Single package | 10.7 EER | -- | -- |
| | > 13,500 Btu/hr | Single package | 9.9 EER | -- | -- |
| Packaged Terminal Heat Pumps (PTHP) (Heating & Cooling Mode) | ≤ 8,000 Btu/hr | Single package | -- | 12.2 EER and 3.4 COP | -- |
| | > 8,000 Btu/hr and < 10,500 Btu/hr | Single package | -- | 11.5 EER and 3.3 COP | -- |
| | ≥ 10,500 Btu/hr and ≤ 13,500 Btu/hr | Single package | -- | 10.7 EER and 3.1 COP | -- |
| | > 13,500 Btu/hr | Single package | -- | 9.8 EER and 3.0 COP | -- |
| Heat Pumps, Air-Cooled (Cooling Mode) | < 65, 000 Btu/hr (single phase) | Split system and single package | -- | CEE Tier 2 | |
| | < 65, 000 Btu/hr (three phase) | Split system and single package | -- | CEE Tier 1 | CEE Tier 2 |
| | ≥ 65,000 Btu/hr (three phase) | Split system and single package | -- | | -- |
| Heat Pumps, Air-Cooled (Heating Mode) - See Note 3 | < 65, 000 Btu/hr (single phase) | Split system and single package | -- | CEE Tier 2 | |
| | < 65, 000 Btu/hr (three phase) | Split system and single package | -- | CEE Tier 1 | CEE Tier 2 |
| | ≥ 65,000 Btu/hr (three phase) | 47°F db/43°F wb outdoor air | -- | | -- |
| | | 17°F db/15°F wb outdoor air | -- | | -- |
| Heat Pumps, Water-Source (Cooling Mode) | < 135,000 Btu/hr | 86°F Entering Water | -- | CEE Tier 1 | -- |

(Continued)