

ELECTRIC SERVICE SCHEDULE NO. 140 - Continued

~~Table 1a – Retrofit Lighting Energy Efficiency Measures (Continued)~~

~~Notes for Table 1a:~~

- ~~1. To be eligible for the incentives listed, the new lighting system must use less energy than the existing lighting system replaced or the baseline lighting system as determined by the Company.~~
- ~~2. Incentives are capped at 70 percent of Energy Efficiency Project Costs and will not be available to reduce the Energy Efficiency Project simple payback below one year. Energy Efficiency Project costs are subject to Company approval.~~
- ~~3. Incentives for T8 Fluorescent Premium Delamps may not be combined with other linear fluorescent lamp or fixture incentives. Complete fixture removals are not eligible.~~
- ~~4. Incentives for T8 and T5 Fluorescent Relamps may not be combined with other linear fluorescent lamp or fixture incentives and will only be paid once per facility.~~
- ~~5. Qualified equipment lists referenced in the above table are posted on the Utah energy efficiency program section of the Company’s website.~~

~~BF = Ballast Factor~~

~~CEE = Consortium for Energy Efficiency~~

~~CFL = Compact Fluorescent Lamp~~

~~CMH = Ceramic Metal Halide~~

~~HID = High Intensity Discharge (e.g. Mercury Vapor, High Pressure Sodium, Metal Halide)~~

~~HO = High Output~~

~~LED = Light Emitting Diode~~

~~PSMH = Pulse Start Metal Halide~~

~~VHO = Very High Output~~

Table 1b – Lighting Controls and Non-General Illuminance Incentives (Retrofit Only)

Measure	Category	Eligibility Requirements	Incentive <u>“up to”</u>
<u>Interior</u> Lighting Control	Occupancy Control	PIR, Dual Tech, or Integral Sensor	\$0.30/Watt controlled
	Daylighting Control	Must control interior fixtures with Continuous, Stepped, or Bi-level ballast or automated control that dims 50% or more of the fixture in response to daylight.	\$0.34/Watt controlled
	Advanced Daylighting Control	Must incorporate both an occupancy sensor and daylighting sensor operating as part of the same control sequence in the same interior space.	\$0.38/Watt controlled

ELECTRIC SERVICE SCHEDULE NO. 140 - Continued

<p><u>Exterior Lighting Control</u></p>	<p><u>Exterior Dimming Control</u></p>	<p><u>Must control LED technology in an exterior lighting application. Control must be integral to LED fixture or fixture-mounted and reduce fixture power by 75% or more for a minimum of 6 hrs per night or when the space has been unoccupied for 15 minutes or less.</u></p>	<p><u>\$0.34/Watt controlled</u></p>
---	--	--	--------------------------------------

(Continued)