

## **ELECTRIC SERVICE SCHEDULE NO. 140 - Continued**

**Table 4a – Building Envelope Incentives (Retrofit)** 

			<del>Customer</del> Incentive
Equipment Type	Category	Minimum Efficiency Requirement	<u>"up to"</u>
Cool Roof		ENERGY STAR Qualified	\$0.10/square foot
Roof/Attic Insulation		Minimum increment of R-10 insulation added	\$0.05/square foot
Wall Insulation		Minimum increment of R-10 insulation added	\$0.07/square foot
Windows (See Note 3, 4)	Site-Built	U-Factor ≤ 0.30 and SHGC ≤ 0.33 (Glazing Only Rating)	\$0.35/square foot
	Assembly	U-Factor $\leq$ 0.30 and SHGC $\leq$ 0.33 (Entire Window Assembly Rating)	\$0.35/square foot
Window Film	Existing Windows	See Note 5	\$0.15/kWh annual energy savings (See Note 5)

## Notes for Table 4a:

- 1. Equipment that meets or exceeds the efficiency requirements listed for the equipment category in the above table may qualify for the listed incentive.
- 2. Building must be conditioned with mechanical cooling to be eligible for envelope incentives.
- 3. Energy performance of window assemblies and glazing products must be rated in accordance with NFRC. Site-Built metal window systems must include a thermal break within the frame or other appropriate NFRC certification to qualify for incentives. Skylights are not eligible to receive the incentives in the above table.
- 4. Window square footage is determined by the dimensions of the entire window assembly, not just the window glass.
- 5. Incentives for window film are calculated based on film specifications and window orientation at \$0.15/kWh annual energy savings. Energy savings are subject to approval by the Company.

NFRC = National Fenestration Rating Council

SHGC = Solar Heat Gain Coefficient

Table 4b – Building Envelope Incentives (New Construction/Major Renovation)

Equipment Type	Category	Minimum Efficiency Requirement	Customer Incentive "up to"
Cool Roof		ENERGY STAR Qualified	\$0.10/square foot
Roof/Attic Insulation		Minimum increment of R-5 insulation above code (See Note 5)	\$0.05/square foot
Wall Insulation		Minimum increment of R-3.7 continuous insulation above code (See Note 5)	\$0.07/square foot
Windows (See Note 3, 4)	Site-Built	U-Factor ≤ 0.30 and SHGC ≤ 0.33 (Glazing Only Rating)	\$0.35/square foot

Issued by authority of Report and Order of the Public Service Commission of Utah in Docket Advice No. 16-033-035-184

FILED: February September 95, 20164 EFFECTIVE: March September

<u>10</u>4, 201<u>6</u>4



P.S.C.U. No. 50

<u>First Revision of Sheet No. 140.12</u> <u>Canceling</u> Original Sheet No. 140.12

## **ELECTRIC SERVICE SCHEDULE NO. 140 - Continued**

Assembly	U-Factor ≤ 0.30 and SHGC ≤ 0.33 (Entire Window Assembly Rating)	\$0.35/square foot
----------	---	--------------------

(Continued)

Issued by authority of Report and Order of the Public Service Commission of Utah in Docket Advice No. 16-033-035-184

**FILED:** <u>February September</u> <u>95</u>, 201<u>6</u>4 <u>10</u>4, 201<u>6</u>4

EFFECTIVE: MarchSeptember