

Docket No. 15-057-19
Data Request No. 4.03
Requested by Division of Public Utilities
Date of QGC Response March 15, 2016

DPU 4.03 Please provide the projected peak day pressure for the section of FL089 west of the “2016 project” from Attachment 3 page 1 of 2.

Answer: Based on 2015 modeling, the Vernal 1 regulator station gets down to 87 psig on a Peak Day during the peak hour. Vernal 1 is the regulator station at the west end of FL89 shown on Attachment 3 page 1.

Prepared by: Mike Platt, Lead Engineer, System Planning and Analysis, QGC