

PROPOSED COMPLIANCE ORDER FOR MR. MOYAL PERTAINING TO  
THE MASTER METER SYSTEM AT THE MILLSTREAM MOTEL, OGDEN, UTAH

Pursuant to Utah Code Ann. § 54-13-1 et seq. and Public Service Commission of Utah (Commission) Rule R746-409-1 et seq., in particular R746-409-6, the Division of Public Utilities (Division) proposes that the Commission issue to Mr. Michael Moyal a Compliance Order incorporating the following remedial requirements to ensure the compliance of his master meter system at the Millstream Motel (Master Meter System) with pipeline safety regulations. The Division also proposes that written documentation of steps taken to satisfy the Compliance Order and certification that the Compliance Order Items have been completed must be filed with the Commission and Pipeline Safety no later than 60 days after the Final Order has been issued by the Commission.

The Division proposes that the Compliance Order incorporate the following:

1. Mr. Moyal is required to comply with Utah Code Ann. § 54-13-1 et seq. and R746-409 insofar as they pertain to operation of a natural gas master meter system.
2. The Commission finds that Mr. Moyal has failed to comply with Probable Violation Item Nos. 1, 2, 3, 4, and 5 from the Notice of Probable Violation (NOPV).
3. Unless superseded by a Hazardous Facility Order, in regard to Probable Violation Item No. 1 of the NOPV pertaining to the lack of cathodic protection for the Master Meter System, Mr. Moyal must (a) bring the Master Meter System into compliance by ensuring the system provides a level of cathodic protection that complies with one or more of the applicable criteria contained in 49 CFR Part 192, Appendix D, adopted by reference by Utah Code Ann. §§ 54-13-2 and 54-13-3 and by R746-409-1 or (b) cease operating the Master Meter System;
4. In regard to Probable Violation Item Nos. 2 and 3 of the NOPV pertaining to the lack of cathodic protection records, Mr. Moyal must (a) prepare and maintain the required records or (b) cease operating the Master Meter System;
5. In regard to Probable Violation Item No. 4 of the NOPV pertaining to Mr. Moyal not preparing and following a manual of written procedures for conducting operations and maintenance activities and for emergency response pertaining to the Master Meter System, Mr. Moyal must (a) prepare and follow a manual of written procedures for conducting operations and maintenance activities and for emergency response pertaining to the Master Meter System or (b) cease operating the Master Meter System; and
6. In regard to Probable Violation Item 5 of the NOPV pertaining to Mr. Moyal not developing and implementing a written procedure to provide customers public awareness messages twice annually concerning the Master Meter System, Mr. Moyal must (a) develop and implement a written procedure for delivering public awareness messages twice annually containing all the required elements in 49 CFR § 192.515(j) concerning the Master Meter System or (b) cease operating the Master Meter System.

7. Insofar as they pertain to operation of a natural gas master meter system, Mr. Moyal must comply fully with Utah Code Ann. § 54-13-1 et seq. and R746-409 which establish safety standards and rules for Natural Gas Pipeline Safety in Utah and incorporate Part 192 of the Code of Federal Regulations, including integrity management and operator qualification requirements.

8. Written documentation of steps taken to satisfy the Compliance Order and certification that the Compliance Order Items have been completed must be filed with the Commission and Pipeline Safety no later than 60 days after the Final Order has been issued by the Commission.