

**BEFORE THE
PUBLIC SERVICE COMMISSION OF UTAH**

In the Matter of the Complaint of)
McLeodUSA Telecommunications)
Services, Inc., against Qwest Corporation) Docket No. 06-2249-01
for Enforcement of Commission-)
Approved Interconnection Agreement.)
)

**DIRECT TESTIMONY
OF
SIDNEY L. MORRISON**

On behalf of

McLeodUSA Telecommunications Services, Inc.

April 14, 2006

PUBLIC VERSION

TABLE OF CONTENTS

I. INTRODUCTION AND QUALIFICATIONS 1

II. PURPOSE AND SUMMARY OF CONCLUSIONS AND
RECOMMENDATIONS 5

III. CENTRAL OFFICE POWER OVERVIEW 7

A. General Power Concepts and Their Application to Telecommunications
Equipment7

B. Central Office Power Infrastructure.....13

C. Qwest/McLeodUSA DC Power Measuring Amendment and “As
Consumed” Versus “As Ordered” Billing25

IV. MCLEODUSA’S APPLICATION OF THE DC POWER PLANT RATE
ELEMENT IS CONSISTENT WITH THE MANNER IN WHICH DC POWER
PLANT IS ENGINEERED..... 29

A. It is critical to distinguish the sizing of DC power plant from the sizing of
DC power distribution.....29

B. Proper DC power sizing and engineering supports McLeodUSA’s
recommended application of the DC power plant usage charge.....52

C. Qwest’s Power Reduction offering is not a suitable option to billing DC
power usage charges on an “as consumed” basis54

Exhibits

- Exhibit SLM-1** *Curriculum Vitae* of Sidney L. Morrison
- Exhibit SLM-2** Glossary of power terms
- Exhibit SLM-3** Testimony of Qwest Communications Corporation witness
Victoria Hunnicutt-Bishara in Illinois Commerce Commission
Docket No. 05-0675

Figures

- Figure 1** Diagram of central office power infrastructure
- Figure 2** Diagram of AC power components
- Figure 3** Diagram of DC power plant components
- Figure 4** Diagram of DC power distribution components
- Figure 5** Diagram of Network Voltage Drops
- Figure 6** McLeodUSA Collocated Equipment and Power Requirements
- Figure 7** McLeodUSA “as ordered” versus “as consumed” amperage

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

I. INTRODUCTION AND QUALIFICATIONS

Q. PLEASE STATE YOUR NAME, BUSINESS ADDRESS, AND OCCUPATION.

A. My name is Sidney L Morrison. My business address is 550 Sunset Lakes Boulevard SW, Sunset Beach, North Carolina 28468-4900. I am currently employed by QSI Consulting, Inc. (QSI) as a Senior Consultant and the Firm’s Chief Engineer.

Q. PLEASE SUMMARIZE YOUR PROFESSIONAL EXPERIENCE.

A. I have over 30 years of experience in the telecommunications industry. I began my telecommunications career in 1966 in Charlotte, North Carolina as a cable helper for Southern Bell Telephone and Telegraph. Southern Bell was an incumbent local exchange carrier (ILEC) managing numerous exchanges throughout North Carolina. My duties involved splicing underground, buried and aerial cable. I also worked as a switching technician and special services technician.

Beginning in August of 1970, I transferred to Mountain Bell in Denver, Colorado as a central office technician. In 1972, I was promoted to supervise main distribution frame (MDF) operations. My duties included supervising the installation of Plain Old Telephone Service (or POTS), Special Services, Central Office area cuts, MDF replacements and many other projects. In 1980 and 1981, I performed time and motion studies for service provisioning on approximately 75 of Mountain Bell’s MDF operations. These time and motion studies included components for running jumpers and administrative activities on each of these frames. From 1983 until 1986, I was the switching control center and MDF subject matter expert for US West. In this position, I was responsible for staff level support for service provisioning and maintenance,



26 including the development of enhancements for operational support systems (OSS)
27 supporting these activities. From 1986 until 1993, I was responsible for the US West
28 Automatic Message Accounting (AMA) teleprocessing organization for the fourteen state
29 US West region.

30 In 1993, I retired from US West and began contract engineering work and
31 consulting. In 1995, I took an assignment in Kuala Lumpur, Malaysia as a
32 contractor/consultant with a team of specialists to build a competitive local exchange
33 carrier (CLEC) network consisting of a Global System for Mobil (GSM) communications
34 services, fixed network services, cable television (CATV) services and data services
35 integrated into a common transport backbone. One of my primary responsibilities in
36 Malaysia was organizing and implementing a field operations group (FOG) that was
37 responsible for the installation and maintenance of all fixed network and CATV services.
38 My responsibilities included the planning, organizing, staffing and implementation of the
39 FOG, including an installation and maintenance group, assignment center, dispatch
40 center, test center and a repair center. I also had the responsibility of developing business
41 processes and OSS system requirements for provisioning and maintenance supporting the
42 FOG. After launching the FOG, I managed the day-to-day operations of the department,
43 ultimately refining the organization into an ISO 9002¹ qualified organization. In January
44 1997, the Binariang Maxis FOG became the first certified ISO 9002 service organization
45 in Southeast Asia.

46 I returned from Malaysia in June of 1997 and worked for approximately two
47 years as a contract outside plant/central office equipment (OSP/COE) engineer, and
48 trained new engineers for US West collocation efforts.

¹ International Organization Standards, ISO 9002 is the standard set of requirements for an organization whose business processes range from, production, installation and servicing.

49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70

In May 1999, I accepted a contract in Switzerland building a new CLEC under the market name of diAx telecommunications. My responsibilities involved project management to establish OSS supporting all wireless, wireline, and data services offered by diAx. I also provided consulting services developing business processes supporting the establishment of the diAx Internet Provider Operations Center (IPOC) and diAx data services offerings. I established system requirements based on IPOC business processes for fault management systems, provisioning systems, capacity inventory systems, customer service inventory systems and workflow engines controlling overall maintenance and provisioning processes.

In December 2000, I returned from Switzerland and began working for QSI Consulting Inc. as a Senior Consultant. I provide telecommunications companies with engineering advice and counsel for direct network planning, management and cost-of-service support. My specific areas of expertise include network engineering, facility planning, project management, business system applications, incremental cost research and issues related to the provision of unbundled network elements.

Attached to my testimony as Exhibit SLM-1 is a copy of my *Curriculum Vitae*, which contains a comprehensive description of my work experience and educational background.

Q. DO YOU HAVE DIRECT EXPERIENCE IN PLANNING AND ENGINEERING COLLOCATIONS FOR US WEST (N/K/A QWEST) CENTRAL OFFICES?²

² The FCC approved the acquisition of US West by Qwest in March of 2000.

71 A. Yes. As mentioned above and in Exhibit SLM-1, I worked for 22 years in US West's
72 Network Management Group. In 1997, I contracted to US West as a central office
73 engineer, where I was responsible for collocation planning and engineering in the
74 common systems planning and engineering center. My duties in this capacity included
75 Central Office Equipment Facility Management (COEFM) collocation design, floor space
76 planning and allocation, power engineering, tie cable engineering, collocation cage
77 placement, Heating Ventilation and Air Conditioning (HVAC) and collocation AC power
78 and overhead lighting. During this time frame, collocation business processes were being
79 developed, and I provided input to the development of engineering business processes
80 used in the implementation of collocation engineering practices and procedures within
81 the US West Common Systems Planning and Engineering Center (CSPEC) organization.

82 During my time as a central office engineer, I acquired first-hand experience in
83 observing the power usage trends of Qwest (then US West) central offices and
84 recommending power augments for those offices based on my observations and sound
85 engineering principles and practices. The proper planning and sizing of DC power
86 components in the central office is crucial to proper resolution of the disputed issues in
87 this proceeding, and I can speak to this issue based on direct working experience in
88 planning and sizing the power requirements of a central office.

89
90 **Q. HAVE YOU PREVIOUSLY TESTIFIED AS AN EXPERT WITNESS ON**
91 **COLLOCATION POWER ISSUES BEFORE OTHER STATE REGULATORY**
92 **COMMISSIONS?**

93 A. Yes. Most recently, I submitted expert testimony providing the engineering framework
94 supporting McLeodUSA's complaint in Iowa Case FCU-06-20, which is a complaint case

95 similar to this one. Before that, I sponsored testimony before the Indiana Utility
96 Regulatory Commission (Cause No. 42398), in which I described the results of the
97 collocation power audits I performed for a CLEC client in that state and explained that
98 the CLEC did not, and indeed could not, utilize the amount of power for which it was
99 being billed by AT&T/SBC Indiana. I wrote a similar audit report for a client for Public
100 Utilities Commission of Ohio Docket No. 03-802-TP-CSS. The issues in this docket are
101 identical to those in the companion Iowa docket and very similar to those I have testified
102 to in other regions, in that in all instances, the incumbent local exchange carrier is billing
103 the CLEC for an amount of power that the CLEC does not, and indeed could not, use.
104 Throughout my testimony, I will reference positions taken on these issues by Qwest in
105 Iowa because it is very likely that Qwest will take identical positions in its testimony
106 here.

107
108 **II. PURPOSE AND SUMMARY OF CONCLUSIONS AND RECOMMENDATIONS**

109
110 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY?**

111 A. QSI was retained by McLeodUSA to support the cost, policy and engineering framework
112 underlying McLeodUSA's complaint against Qwest regarding the misapplication and
113 excessiveness of Qwest's Direct Current (DC) power plant charges. Michael Starkey,
114 from QSI, is filing testimony simultaneous with mine that will address the policy and cost
115 framework, and my testimony addresses the engineering framework.

116 The purpose of my testimony is to, first, provide a general overview of electricity
117 and power concepts and terminology that are important to a complete understanding of
118 the disputed issues. Second, I will provide descriptions and diagrams of the components
119 of a central office power infrastructure, with an explanation of how these components are

120 engineered and sized. Once the components of the central office power infrastructure are
121 addressed, I will identify the components of the central office to which McLeodUSA's
122 complaint applies – DC power plant –and explain from an engineering perspective why:
123 (a) it is inappropriate from an engineering perspective for Qwest to bill McLeodUSA for
124 DC power plant usage on an “as ordered” basis instead of on an “as consumed” basis, (b)
125 there is nothing improper about ordering more power capacity in the DC power
126 distribution than the CLEC can or will actually use, (c) Qwest power engineers would not
127 augment the power plant of the central office based on individual power-related orders
128 from McLeodUSA, other CLECs, or Qwest, and (d) why Qwest's power reduction
129 offering is not a suitable alternative to billing DC power plant based on McLeodUSA's
130 actual usage.

131

132 **Q. PLEASE SUMMARIZE YOUR CONCLUSIONS.**

133 A. My testimony concludes that McLeodUSA's recommended application of the DC power
134 plant usage charge is consistent with the manner in which DC power plant is sized, and in
135 turn, the manner in which Qwest incurs power plant costs. As my testimony will
136 demonstrate, it is critical to distinguish between power *plant* facilities, which are shared
137 among all power users in a particular central office and sized on an “as consumed” basis,
138 from power *distribution* facilities, which are dedicated to a particular power user and
139 sized on an “as ordered” basis. I will show that McLeodUSA makes the proper
140 distinction between those two power-related infrastructure components by recommending
141 that a power plant usage rate element be applied on an “as consumed” basis, while power
142 distribution facilities may be recovered on an “as ordered” basis. Further, my testimony
143 concludes that since the DC power plant facilities are sized according to forecasted actual

144 peak *usage* of all users in a central office, there is no relationship between *orders* for
145 power by CLECs and DC power plant augment/investment. This is a very important
146 point because Qwest will undoubtedly submit testimony in this proceeding claiming that
147 DC power plant is sized based on CLEC power *orders* – not forecasted actual peak power
148 usage. My direct testimony will demonstrate, however, that Qwest’s position is in direct
149 conflict with Qwest’s own engineering manuals and guidelines as well as inconsistent
150 with the positions taken by Qwest in testimony on DC power issues elsewhere. My
151 testimony will also show that the Commission should interpret the DC power
152 measurement amendment, and, in turn, require Qwest to apply the DC power plant usage
153 charge, in a manner consistent with the way in which the DC power plant is sized (or the
154 way in which Qwest incurs DC power plant costs). My testimony will demonstrate that
155 McLeodUSA’s recommendation adheres to this principle and Qwest’s recommendation
156 does not. Finally, I will explain that that Qwest’s Power Reduction is an unnecessary,
157 risky and costly process that causes more problems instead of solving the existing
158 problem related to Qwest’s application of the DC power plant usage charge. As such, it
159 is not a satisfactory alternative for addressing the problem of over-billed power charges
160 when compared to a proper interpretation of the contract amendment at issue in this
161 proceeding which should provide for “usage based” billing.

162

163 **III. CENTRAL OFFICE POWER OVERVIEW**

164

165 **A. *General Power Concepts and Their Application to Telecommunications***
166 ***Equipment***

167

168 **Q. IS A GENERAL UNDERSTANDING OF ELECTRICITY AND POWER**
169 **CONCEPTS AND TERMINOLOGY IMPORTANT TO THIS PROCEEDING?**

170 A. Yes. While I am an engineer by trade, my testimony will use layman's terms and
171 descriptions when possible to limit the use of industry and technical jargon. However,
172 there are certain technical terms and engineering concepts related to electricity and power
173 that are important for a full understanding of the issues in dispute in this proceeding.
174 Accordingly, I will provide a quick overview of the "building blocks" of power and then
175 explain how these terms and concepts are relevant within the context of
176 telecommunications equipment and collocation power. For ease of reference, I have
177 attached to my testimony Exhibit SLM-2, which is a glossary of technical terms I use in
178 my testimony.

179
180 **Q. WHAT IS POWER AND HOW IS IT MEASURED?**

181 A. In its most basic form, power is the rate at which work is done – whether that power is
182 electrical or mechanical. Work is done whenever a force causes motion, and work is not
183 done when a force does not cause motion. For instance, if a mechanical force is used to
184 lift or move a weight, the force causes motion, and therefore, work is done. However, the
185 force of a compressed spring acting between two fixed objects does not cause motion
186 and, therefore, does not constitute work.

187 As it relates to electricity, electrical force is measured in voltage, which forces
188 current to flow (i.e., electrons to move) in a closed circuit. When voltage (or force) exists
189 between two points and current flows, then work is done. However, when voltage exists
190 between two points, but current cannot flow, no work is done. This is analogous to the
191 compressed spring example above that produced no motion.

192 When work is done by voltage causing electrons to move, the instantaneous rate
193 at which this work is done is called the electrical power rate, and its unit of measure is the
194 watt. The relationship between power, voltage and current can be expressed by the
195 following equation: *Power = Voltage x Current*; where power is measured in watts,
196 voltage is measured in volts and current is measured in amperes.

197
198 **Q. PLEASE DESCRIBE THE FUNDAMENTAL DIFFERENCE BETWEEN**
199 **ALTERNATING CURRENT (AC) VERSUS DIRECT CURRENT (DC).**

200 A. Alternating current (AC) is a specific type of electric current in which the direction of the
201 current's flow is reversed, or alternated, on a regular basis. Direct current is no different
202 electrically from alternating current except for the fact that it flows in the same direction
203 at all times. Nearly all modern electronic devices require direct current for their
204 operation, but alternating current is what is provided by the electric utility. Therefore,
205 rectifiers are used to convert AC power to DC power so that electronic devices can use
206 it.³ The issue of AC power and DC power is relevant because the power that is delivered
207 to a telephone central office by the electric utility is AC power , but telecommunications
208 equipment generally uses DC power (i.e., -48 VDC), and therefore, AC power must be
209 converted to DC power at the central office.

210
211 **Q. HOW DOES ELECTRICAL EQUIPMENT CONSUME POWER?**

212 A. This will depend on the type of electrical equipment. Typically, however, the power
213 consumed by telecommunications equipment is largely dependent on two factors. First,
214 the power consumed by telecommunications equipment is dependent on the number of

³ [http://www.energyvortex.com/energydictionary/alternating_current_\(ac\)_direct_current_\(dc\).html](http://www.energyvortex.com/energydictionary/alternating_current_(ac)_direct_current_(dc).html)



215 active subscribers (or the percent fill) of the equipment. Second, telecommunications
216 equipment power usage is dependent on actual traffic or usage the equipment is
217 supporting. In other words, the consumption of electrical power is dependent upon the
218 “work” undertaken by the equipment, and specific to telecommunications equipment,
219 more (or less) work is generally dependent upon the fixed number of subscribers the
220 equipment must be equipped to support, and the amount of activity required by that
221 customer base.

222

223 **Q. PLEASE DEMONSTRATE HOW TELECOMMUNICATIONS EQUIPMENT**
224 **CONSUMES POWER USING AN ILLUSTRATIVE PIECE OF EQUIPMENT?**

225 A. A Digital Subscriber Line Access Multiplexer (DSLAM) is a common piece of
226 telecommunications equipment that exhibits power usage characteristics that are
227 representative of how telecommunications equipment typically consumes power. A
228 DSLAM receives signals from multiple customer Digital Subscriber Line (xDSL)
229 connections and aggregates the signals on a high-speed backbone using multiplexing
230 techniques. With the addition of a splitter, this combination of equipment allows voice
231 (low band) and data (high band) signals to be carried over a copper twisted pair. To
232 demonstrate my point, I will use a popular DSLAM model - the Alcatel 7300 Advanced
233 Services Access Manager (ASAM),⁴ which according to Alcatel, is “the most widely
234 deployed digital subscriber line access multiplexer (DSLAM) in the world...”⁵ This

⁴ I use this Alcatel DSLAM model for illustrative purposes because it is a popular model and because there is considerable public information available about the technical specifications of this particular DSLAM model. McLeodUSA may or may not use this particular Alcatel model somewhere in its collocations – though the particular DSLAM McLeodUSA does use in its collocations would exhibit power usage characteristics identical to those described above.

⁵<http://www.alcatel.com/products/productsummary.jhtml?relativePath=/com/en/appxml/opgproduct/alcatel7300advancedservicesaccessmanerasamansiversiontcm228115681635.jhtml>

235 Alcatel DSLAM is capable of serving 5,000 lines per network interface with subtending
236 shelves.⁶ Regarding the first point – that power consumed is dependent on the percent fill
237 of the equipment – this DSLAM at 50% fill (or serving 2,500 of the possible 5,000 lines)
238 uses less power than if it were at 100% fill (or serving all 5,000 customers), everything
239 else equal.

240 Regarding the second point – that power consumption is dependent on the traffic
241 handled – the DSLAM will use less power when handling relatively lower levels of
242 traffic, or in other words, whether the DSLAM is serving 2,500 or 5,000 customers, the
243 power consumption is less when the circuits are idle and thus experiencing little or no
244 activity from those customers, everything else equal. Even considering that the DSLAM
245 may be fully utilized at 100% fill, the actual traffic patterns of customers varies with
246 periods of minimum use and rises to an average period of peak demand. Hence, two
247 Alcatel 7300 DSLAMs both supporting 2,500 customers may experience very different
248 power requirements depending upon the usage patterns of the individual subscribers they
249 support.

250

251 **Q. ARE THESE FLUCTUATIONS IN POWER CONSUMPTION DUE TO**
252 **PERCENT FILL AND ACTUAL USAGE PARTICULARLY CHARACTERISTIC**
253 **OF TELECOMMUNICATIONS EQUIPMENT?**

254 A. These general power consumption characteristics are largely common across
255 telecommunications equipment, and they are particularly marked in a collocation
256 environment. This results from the fact that, within a CLEC collocation, the CLEC
257 equipment may have very low initial power requirements as the CLEC attempts to build a

⁶ Alcatel 7300 ASAM product guide, p. 3. This DSLAM serves a maximum of 2,592 lines without subtending shelves.

258 customer base relative to that central office. Yet, as the carrier's business grows, the
259 percent fill increases and the actual usage for that equipment will increase, as will the
260 power draw required to electrify the equipment. Hence, with regard to most
261 telecommunications equipment, and collocated telecommunications equipment in
262 particular, the percent fill and the level of actual traffic generated by these customers will
263 change over time.

264

265 **Q. YOU EXPLAIN ABOVE THAT TELECOMMUNICATIONS EQUIPMENT DOES**
266 **NOT CONSUME POWER AT A CONSTANT RATE AND THAT POWER DRAW**
267 **REQUIREMENTS CHANGE OVER TIME. WHY IS THAT IMPORTANT IN**
268 **THIS CASE?**

269 A. The manner in which telecommunications equipment uses power is important to this case
270 because one of the key issues in dispute in this case is how DC power plant is sized by
271 Qwest. And because telecommunications equipment does not consume power at a
272 constant rate, the DC power consumption of central offices also varies. This variation in
273 DC power consumption of central offices impacts the manner in which Qwest engineers
274 size DC power plant in Qwest central offices. In sum, the power engineer must make
275 sure that the central office is capable of accommodating the forecasted actual peak usage
276 of the central office so that when power consumption peaks, Qwest's central office power
277 system can accommodate that peak level. Sizing DC power plant below this level would
278 be under-sizing the DC power plant and could lead to constraints on Qwest's ability to
279 provide power, and sizing DC power plant above this level would be wasteful and
280 inefficient. This peak capacity level by which power engineers size DC power plant is

281 referred to as the “average busy hour,”⁷ and represents the level when the load on the
282 central office telecommunications equipment is at its greatest. Busy hours can vary by
283 central office, and as such, proper DC power planning calls for power engineers to plan
284 for DC power plant in sufficient amounts to accommodate the average busy hour of that
285 particular central office.

286

287 **B. Central Office Power Infrastructure**

288

289 **Q. PLEASE DESCRIBE THE FUNDAMENTAL COMPONENTS OF A TYPICAL**
290 **CENTRAL OFFICE POWER INFRASTRUCTURE?**

291 A. There are four primary components of a typical central office power infrastructure.

292 Those components are as follows:

- 293 1. **Commercial Alternating Current (AC) Power**: this category consists of
294 the AC power procured from the electric utility and can include ancillary
295 distribution equipment including, conduit, cabling, fasteners and protective
296 equipment.⁸
297
- 298 2. **Standby AC Power**: this category consists of AC distribution equipment
299 including engine/alternator, fuel tanks, fuel, AC switching and distribution
300 equipment, that can be used in case of a failure of the office’s primary power
301 source (i.e., the commercial source).
302
- 303 3. **Direct Current (DC) Power Plant**: this category consists of equipment used
304 to convert AC power to DC power regardless of whether the AC power is
305 obtained from the commercial source or standby source. DC power plant
306 generally consists of the following equipment: (i) rectifiers, which are used
307 for the AC/DC conversion;⁹ (ii) batteries, which “provide the necessary
308 current to power telephone switches [or equipment,]” “serve as a filter to
309 smooth out fluctuations in the commercial power[.]” “remove the ‘noise’ that

⁷ The average busy hour drain is established by determining the profile of the office load for the busy day of the busy season (excluding abnormally busy operating days such as Mother’s Day and Christmas).

⁸ Bellcore, Central Office Environment Detail Engineering Generic Requirements, Generic Requirements GR-1502-CORE, Issue 1, June 1994.

⁹ Newton’s Telecom Dictionary, 20th ed., p. 690.

310 power often carries[.]” and “provide necessary backup power should
311 commercial power fail[.]”¹⁰ and (iii) controllers, which manage the DC
312 power.
313

- 314 4. **DC Power Distribution:**¹¹ this category is the power infrastructure that
315 consists of DC power cables and fuses in the Battery Distribution Fuse Bays
316 (BDFBs) and circuit breakers in the Power Boards (PBs). The DC power
317 distribution cabling consists of paired copper cables in insulated sheaths that
318 complete a power circuit from the BDFB/PB to the telecommunications
319 equipment lineups or CLEC collocation cages. One portion of each pair
320 represents the “battery” or distribution of power and the other portion of each
321 pair represents the “ground” or power return to the power source. Given the
322 importance of un-interruptible power to the telecommunications equipment,
323 power cables come in pairs for redundancy purposes. The primary cable feed
324 is known as the “A” lead and the backup power cable is known as the “B”
325 lead. If the A lead fails, the B lead should continue to power the equipment.

326 The BDFB is a fuse bay that contains fuses to protect power leads
327 and cables from power surges and provides a distribution point where a large
328 DC power lead can be broken down into smaller increments of power for
329 distribution to telecommunications equipment. The BDFB allows for users
330 of power in the central office to use smaller, more cost-effective power leads
331 to power their equipment, while the fuses housed therein protect the power
332 cables and telecommunications equipment from power currents that exceed
333 the rated amperage of the fuses. The BDFB also contains alarms and
334 monitors and usually contains ampere meters for manual monitoring.¹² The
335 PB is similar to and provides the same functionality as the BDFB but is
336 typically used for larger current distribution to equipment and collocations.
337 For instance, as indicated in the Qwest/McLeodUSA DC Power Measuring
338 Amendment, Qwest utilizes a BDFB for power orders in increments equal to
339 or less than 60 amps and uses PBs for orders in increments greater than 60
340 amps.¹³
341

342 Figure 1 is a diagram of a typical central office power infrastructure, color-coded so as to
343 distinguish the primary components of the central office power infrastructure from one
344 another.


¹⁰ Newton’s Telecom Dictionary, 20th ed., p. 103.

¹¹ DC power distribution is also referred to as delivery, and the terms DC power distribution and DC power delivery can be used interchangeably.

¹² Bellcore, Central Office Environment Detail Engineering Generic Requirements, Generic Requirements GR-1502-CORE, Issue 1, June 1994.

¹³ DC Power Measuring Amendment to the Interconnection Agreement between Qwest Corp. and McLeodUSA Telecommunications Services, Inc., Attachment 1, Sections 1.1 and 1.2.

Figure 1



345
 346

347

348

349

350

351

352

353

As Figure 1 shows, the four basic power components – (1) AC commercial power (shown in black), (2) standby AC power (shown in green), (3) DC power plant (shown in blue), and (4) DC power distribution (shown in red) - work together to power the telecommunications equipment in a central office. It is important to note that the first 3 categories are shared among all power users in a central office, while the fourth category – DC power distribution – is dedicated to a specific customer (or group of customers). And while a CLEC collocation cage is depicted in Figure 1, the same AC power and DC

354 power-related equipment are also used to serve Qwest's power needs in a nearly identical
355 fashion.

356

357 **Q. YOU MENTIONED REDUNDANCY RELATED TO AC POWER SOURCES**
358 **AND DC POWER DISTRIBUTION CABLES. WHY DO CENTRAL OFFICE**
359 **POWER SYSTEMS EXHIBIT THIS LEVEL OF REDUNDANCY?**


360 A. Redundancy is a basic concept in much of the telecommunications network. Given that
361 electronic equipment commonly found in ILEC central offices is essential to providing
362 service to customers (e.g., switches, processors, optical feeder networks), the power
363 system is designed with redundancy so that this equipment can continue to function even
364 if the primary source or delivery method fails.

365

366 **Q. PLEASE ELABORATE ON EACH OF THE CATEGORIES OF CENTRAL**
367 **OFFICE POWER COMPONENTS.**

368 A. Figure 2 is a diagram of the components of AC power.

Figure 2



369

370

371

372

373

374

375

376

377

378

As Figure 2 shows, AC power is delivered to the central office by the electric utility (or the standby AC power source)¹⁴ and is converted to DC power which is used by telecommunications equipment in the central office. AC power is delivered to the central office on a demand basis controlled by the requirements of the AC service within the office (e.g., AC lights, HVAC, elevators), and the demand requirements of the DC power plant serving telecommunications equipment.


Q. PLEASE ELABORATE ON DC POWER PLANT.

A. Figure 3 below is a diagram of the DC power plant.

¹⁴ Standby AC power consists of an arrangement of a engine, diesel, gasoline or jet turbine, and fuel tanks for producing mechanical power connected to a generator set for producing AC power and a switching mechanism, usually automated, to transfer AC service from a failed utility and to transfer service back to a successfully-recovered utility service.

Figure 3

DC Power Plant Components



379

380

381

382

383

384

385

386

387

388

389

390

391

Q. YOU STATE ABOVE THAT POWER ENGINEERS DESIGN THE DC POWER PLANT OF A CENTRAL OFFICE BASED ON THE FORECASTED ACTUAL PEAK USAGE FOR THAT OFFICE. PLEASE ELABORATE ON THIS PROCESS.

392

393

394

395

A. In a basic example of a Qwest central office, Qwest power engineers monitor the actual usage of DC power and observe the peak power usage that takes place at the average busy hour. Qwest engineers would then take steps to ensure that the DC power plant is capable of handling the usage that occurs at this peak period. In other words, DC power


396 plant is sized based on the maximum power draw that takes place on a CO-wide basis
397 during the busy hour. I will also refer to this in my testimony as the List 1 drain – or the
398 amperage that the equipment uses when the power plant is operating normally at
399 maximum capacity (discussed in more detail below). So, in other words, DC power plant
400 is sized based on List 1 drain. Power engineers oftentimes utilize a fill factor to build in a
401 “cushion” of excess capacity between the busy hour load and the actual capacity of the
402 DC power plant. Or, perhaps more appropriately, those engineers identify a “target”
403 usage level which may indicate to them that the existing power plant, given forecasted
404 peak usage, may fall short in a busy hour scenario. Hence, when usage hits that “target”
405 level, they begin to explore augmentation alternatives. Importantly, however, Qwest DC
406 power engineers do not augment the DC power plant infrastructure based on particular
407 power orders of a CLEC or Qwest. Given that DC power plant is sized based on
408 forecasted actual peak usage for all equipment in the office, there is no relationship
409 between Qwest’s investment/augmentation in DC power plant and individual orders for
410 power (whether they be from Qwest or a CLEC). I will demonstrate below in Section IV
411 that my testimony on the proper sizing of DC power plant and DC power distribution is
412 backed by Qwest’s own engineering manuals and guidelines.

413

414 **Q. PLEASE ELABORATE ON DC POWER DISTRIBUTION.**

415 A. Figure 4 below is a diagram of the components of the DC power distribution
416 infrastructure.

Figure 4



417

418

419

420

421

422

423

424

425

426

427

428

429

Q. HOW IS DC POWER DISTRIBUTION SIZED?

430

A. The short answer to this question is that DC power distribution is sized based on List 2

431

drain. The List 2 Drain is the maximum current that the equipment will draw when the

432 power plant is in worst case condition of voltage and traffic distress - when the DC power
433 plant's batteries are approaching a condition of total failure (List 2 drain will be discussed
434 in more detail below in Section IV). That being said, the process of actually sizing DC
435 power distribution cables is a bit more complex.

436 The basic idea behind distribution cable design is to make the voltage drop in the
437 cable as small as possible, while at the same time installing the power cable with the
438 smallest diameter allowable within specific parameters. Given that the cost of power
439 cables and power cable installation increases significantly as cable diameter increases, the
440 smallest cable capable of maintaining the minimum voltage drop is chosen to minimize
441 the cable cost, as well as to control the amount of space the cables occupy in the power
442 distribution cable racks.

443
444 **Q. PLEASE ELABORATE ON THE SPECIFIC PARAMETERS WITHIN WHICH**
445 **POWER DISTRIBUTION CABLES MUST BE SIZED.**

446 A. DC power distribution cables are sized using a formula and process related to the amount
447 of voltage drop that will be allowed across the power distribution cables. That formula
448 for calculating copper feeder cables is as follows:

449
$$CM = [K \times \text{Amperes} \times \text{Feet}] / \text{Voltage Drop}$$

450 Where:

451 CM = Circular Mills

452 K = 11.1, the conductance constant for copper cables

453 Amperes = List 2 drain

454 Feet = Distance of loop as measured from the relay rack top of each connection
455 point and is not inclusive of the relay rack drop length.

456
457
458
459
460
461

462 Voltage Drop = Allowable voltage drop from Power Board to BDFB and the
463 allowable voltage drop from the BDFB to the Equipment or Load.
464

465 There are three key variables in the power cable sizing formula that leads to the correct
466 sizing of power distribution cables. *First*, the amount of current (measured in amperes)
467 that must be distributed through the cable is the primary variable. As an engineer
468 increases the amount of current needed for distribution across the power cable, the larger
469 the required cable diameter or cross sectional area that must be utilized to carry the added
470 current. The amount of current (in amperes) used in the formula is referred to the List 2
471 Drain. When a DC power plant is in distress, as is the case with List 2 drain, the terminal
472 voltage of the batteries begins to decrease. For the telecommunications equipment load
473 to continue to draw the same amount of DC power, the current increases proportionately
474 (recall that $\text{Power} = \text{Voltage} \times \text{Current}$, wherein a drop in voltage requires a subsequent
475 increase in current to keep the available power at a constant level). This increase in
476 current and decrease in voltage occurs automatically in the telecommunications
477 equipment, so it can continue operating properly. However, the power cable diameters
478 must be sized to accommodate the additional current required in this worst case situation
479 (or List 2 Drain). The List 2 drain is also known as the recommended amperage because
480 it is the amperage level McLeodUSA must order to operate the equipment properly and in
481 accordance with manufacturer's recommendations and safety standards. The
482 recommended amperage is set at a higher amperage level (compared to the amperage that
483 will actually be used by the equipment under normal circumstances) because it takes into
484 account the worst case scenario, such as low voltage during a battery discharge.


485 *Second*, the longer the DC power cable, the greater the voltage drop that will
486 occur, all other factors held constant. This means that, the longer the distribution cable

487 through which the DC current must travel (measured in feet in the formula), the greater
488 the cables resistance, thereby causing an increased voltage drop from the desired voltage
489 level and corresponding increases in heat.

490 *Third*, the larger the diameter of the DC power distribution cable, the lower the
491 voltage drop that will occur, assuming all else equal. That is, if the current has more
492 cable cross-sectional area through which to travel, there is less resistance, thereby causing
493 a smaller voltage drop and less heat.

494 When sizing power cables, a power engineer, using the formula above, must
495 identify the allowable maximum voltage drop between the BDFB/PB and the
496 telecommunications equipment or CLEC collocation. This allows the engineer to size the
497 smallest diameter power cable based on the cable length that must be traversed with a
498 given amperage. Figure 5 depicts an illustration of a typical voltage drop from the Power
499 Board to BDFB and from the BDFB to the equipment.

Figure 5
Distribution Network Voltage Drops



500 In sum, the power distribution cables have a measurable resistance across them that must
501 be controlled. This resistance causes a voltage drop that occurs between the DC Power
502 Plant and the telecommunications equipment, which, if not managed, causes heat buildup
503 in the distribution cables, and could lead to fire and/or service outages.

506

507 **Q. IS THERE ANOTHER FACTOR THAT IS TAKEN INTO ACCOUNT WHEN**
508 **SIZING DC POWER DISTRIBUTION INFRASTRUCUTRE?**

509 A. Yes. Importantly, when a collocator orders a DC power distribution arrangement (or DC
510 power cables), the CLEC is not ordering the DC power distribution capacity that the
511 CLEC needs immediately based on current demand, but rather the DC power distribution
512 capacity that the CLEC will ultimately require in the collocation arrangement when it
513 matures. This is reasonable because it is extremely costly and risky to routinely re-
514 engineer and physically modify its DC power distribution arrangements (e.g., swapping
515 out power cables or resizing fuses/breakers). These costs and risks can be avoided by
516 sizing the DC power cables for their ultimate demand.

517

518 **Q. HAVE CENTRAL OFFICE POWER PLANNING PRINCIPLES AND**
519 **PROCEDURES MATERIALLY CHANGED DUE TO THE INTRODUCTION OF**
520 **COMPETITION?**

521 A. No. In Iowa, Qwest insinuated that the credibility of my expert testimony should
522 somehow be questioned because my experience with regard to central office power
523 planning primarily predates the Telecommunications Act and the advent of collocated
524 CLECs. The Commission should be aware that in case Qwest makes a similar
525 insinuation here, Qwest's claim is not only factually inaccurate but also irrelevant. As
526 the description of my experience above indicates, I contracted with Qwest f/k/a US West
527 in the post-CLEC era (from August 1997 through May 1999) as a central office engineer,
528 responsible for collocation planning and engineering in the common systems planning
529 and engineering center. Moreover, the Telecommunications Act of 1996 and the advent

530 of collocated CLECs did not necessitate material changes to the power planning
531 guidelines or procedures that Qwest and other ILECs had used for years prior to that
532 time. The host of Bellcore and Qwest engineering manuals and technical documents I
533 reference above date back prior to 1996 (some going back to 1989), and are still relevant
534 today, which shows that the introduction of collocated CLECs (due to the introduction of
535 competition in local telecommunications markets) did not change the way in which
536 central office DC power is engineered or how DC power plant is sized. Regardless of
537 whether there is one (1) power user or ten (10) power users in a central office, DC power
538 plant is sized based on the List 1 drain of all telecommunications equipment being
539 powered in the central office, and as such, DC power plants are designed to accommodate
540 loads, and not particular carriers. Therefore, it is truly irrelevant within the context of DC
541 power plant sizing whether the equipment powered is the ILEC's or a CLEC's – or
542 whether experience in designing central office power plants occurred in pre-CLEC or
543 post-CLEC days – because the guidelines would be the same under each scenario.

544

545 *C. Qwest/McLeodUSA DC Power Measuring Amendment and "As Consumed"*
546 *Versus "As Ordered" Billing*

547

548 **Q. PLEASE DESCRIBE YOUR UNDERSTANDING OF THE INTERCONNECTION**
549 **AGREEMENT AMENDMENT SIGNED BETWEEN QWEST AND**
550 **MCLEODUSA RELATIVE TO THE ISSUE OF POWER MEASUREMENT (AND**
551 **WHICH SERVES AS THE BASIS FOR MCLEODUSA'S COMPLAINT).**

552 A. For McLeodUSA collocation arrangements with power feeds greater than sixty (60)
553 amps, the Qwest and McLeodUSA Amendment¹⁵ requires that Qwest monitor
554 McLeodUSA's DC power usage at the power board on a semi-annual basis (unless
555 otherwise requested by McLeodUSA). Per the terms of the amendment, these
556 measurements support a process whereby Qwest measures and records McLeodUSA's
557 actual power consumption and assesses "Power Usage" charges according to that actual
558 usage. The measured usage rate structure required by the Amendment is in contrast to
559 previous situations wherein Qwest assessed all "Power Usage" elements on an "as
560 ordered," as opposed to "as consumed" basis.

561

562 **Q. DO YOU UNDERSTAND THAT ONE OF THE PRIMARY POINTS OF**
563 **CONTENTION BETWEEN MCLEODUSA AND QWEST IN THIS**
564 **PROCEEDING IS WHETHER OR NOT THE "POWER PLANT" CHARGE**
565 **SHOULD BE ASSESSED ON AN "AS CONSUMED" VERSUS AN "AS**
566 **ORDERED" BASIS?**

567 A. Yes, that is my understanding.

568

569 **Q. AND DO YOU FURTHER UNDERSTAND THAT THIS PRIMARY ISSUE**
570 **RESULTS FROM DISPARATE INTERPRETATIONS OF THE SAME POWER-**
571 **MEASUREMENT AMENDMENT?**

572 A. Yes, that is also my understanding.

573

¹⁵ DC Power Measuring Amendment to Qwest/McLeodUSA interconnection agreement.

574 Q. DO YOU ADDRESS COST-CAUSATION OR ECONOMIC-COST RELATED
575 ASPECTS OF THIS COMPLAINT?

576 A. No, Mr. Starkey will address those issues in his testimony. However, I do provide
577 through my testimony the engineering foundation upon which Mr. Starkey bases his
578 conclusions related to cost-causation and proper cost recovery.

579
580 Q. IS THERE ANY ENGINEERING BASIS FOR MCLEODUSA'S
581 INTERPRETATION OF THE AGREEMENT AMENDMENT?

582 A. Yes, in fact, I am surprised that any engineer with an understanding of how central office
583 power plant and power distribution infrastructure are designed would interpret the
584 amendment as Qwest is. The key here is to compare how each party recommends the DC
585 power plant usage charge be applied (i.e., Qwest's "as ordered" recommendation or
586 McLeodUSA's "as consumed" recommendation) to each party's proposal on how the DC
587 power plant is sized in the central office, and in turn, how Qwest invests in DC power
588 plant.

589
590 Q. PLEASE SUMMARIZE MCLEODUSA'S VIEW ON "AS CONSUMED" VERSUS
591 "AS ORDERED" BILLING FOR THE DC POWER PLANT USAGE CHARGE.

592 A. McLeodUSA's "as consumed" recommendation means that the DC power plant usage
593 charge would be applied to the amps that McLeodUSA actually uses. Power plant related
594 equipment is sized and constructed based upon the shared usage demands of the entire
595 office, and as such, it is perfectly logical that users who consume more power will pay
596 more, while users who consume less power should pay less (i.e., these costs should be
597 recovered on an "as consumed" basis). Likewise, because power distribution systems are

598 largely dedicated to individual users or groups of users, and must be sized to the original
599 orders of the user, then those costs are legitimately recovered on an “as ordered” basis. I
600 have read the Power Measurement Amendment referenced above and I interpret it to
601 provide for exactly this situation.

602
603 **Q. WHEN QWEST CLAIMS THAT DC POWER PLANT IS SIZED ACCORDING**
604 **TO CLEC ORDERS FOR POWER, WHAT DOES THAT ACTUALLY MEAN?**

605 A. The CLEC power orders that Qwest claims serve as the trigger for DC power plant
606 augments/investment are orders for *DC power distribution* (i.e., power cables), and as
607 such, Qwest is saying that DC power *plant* is sized according to orders for power
608 *distribution* cables. Or in other words, Qwest claims that if a CLEC orders a 175 Amp
609 power cable to power its collocation cage, Qwest will build 175 Amps of capacity into its
610 DC power plant infrastructure.¹⁶ However, this is not the case, and Qwest is attempting
611 to confuse the two issues of DC power plant and DC power distribution. As was
612 explained above (and will be demonstrated in more detail below through the use of
613 Qwest’s own engineering manuals), DC power distribution is sized based on List 2 drain
614 and DC power plant is sized based on List 1 drain. By claiming that DC power plant is
615 sized based on CLEC orders for power distribution (or List 2 drain), Qwest is either
616 misunderstanding or intentionally mischaracterizing its own engineering practices such
617 that they appear to support Qwest’s interpretation of the Amendment, wherein Qwest
618 would prefer to continue applying the DC power *plant* usage charge based on ordered DC
619 power *distribution*. Fortunately, Qwest’s engineers who work with power plant on a

¹⁶ In fact, in Iowa, Qwest witness Robert Hubbard testified that “even 175 amps...will definitely trigger a power plant capacity growth job.” Direct Testimony of Robert J. Hubbard, Iowa Utilities Board Docket No. FCU-06-20, March 23, 2006, page 8.

620 daily basis document their actual practices in accordance with sound engineering
621 standards and those records refute Qwest's claims in this regard.

622 In the following section of my testimony, I will demonstrate that Qwest's "as
623 ordered" billing recommendation fails to adhere to Qwest's engineering manuals and
624 guidelines and does not square with positions on DC power expressed by Qwest Utah's
625 affiliate, Qwest Communications Corporation.

626

627 **IV. MCLEODUSA'S APPLICATION OF THE DC POWER PLANT RATE**
628 **ELEMENT IS CONSISTENT WITH THE MANNER IN WHICH DC POWER**
629 **PLANT IS ENGINEERED**
630

631 *A. It is critical to distinguish the sizing of DC power plant from the sizing of DC*
632 *power distribution*
633

634 **Q. YOU EXPLAINED ABOVE THAT DC POWER PLANT IS SIZED**
635 **DIFFERENTLY THAN DC POWER DISTRIBUTION, CAN YOU EXPLAIN**
636 **WHY AND HOW THIS IMPACTS MCLEODUSA'S COMPLAINT?**

637 *A.* Yes. I explained that DC power plant is sized by power engineers monitoring the DC
638 power load requirements of the central office at peak capacity – based on List 1 drain -
639 and growing the DC power plant accordingly, and as such, DC power plant is sized
640 according to forecasted actual peak usage of the central office, in terms of the average
641 busy hour of the office. DC power distribution, on the other hand, is sized based on the
642 List 2 drain, or the power draw of the equipment when the power plant is under a worst
643 case scenario and based on the ultimate demand for power. This results in a situation
644 whereby DC power distribution capacity ordered by CLECs for their collocation, which
645 is the amperage level of the DC power cables ordered for that collocation (or "as

646 ordered” capacity) exceeds (oftentimes significantly) the DC power actually used by their
647 equipment (or “as consumed” capacity), which is the capacity level on which the DC
648 power plant is sized.¹⁷ By billing McLeodUSA the DC Power Plant charge on an “as
649 ordered” basis – or on the capacity level on which DC power *distribution* is sized -
650 Qwest is attempting to fit a square peg in a round hole. Instead, DC power plant is sized
651 on an “as consumed” basis and, therefore, it would be consistent and appropriate for the
652 DC power plant charge to apply on an “as consumed” basis. In my opinion, therefore,
653 the interpretation of the Amendment by McLeodUSA is correct.

654
655 **Q. PLEASE DISCUSS IN MORE DETAIL THE CONCEPTS OF LIST 1 DRAIN**
656 **AND LIST 2 DRAIN?**

657 A. List 1 drain and List 2 drain are industry-standard measurements used to measure the
658 power draw requirements of various types of equipment. As mentioned above, List 1
659 drain is the average busy hour current during normal plant operation. The value is used
660 to size DC power plant, such as batteries and rectifiers. List 2 drain is the peak current
661 under worst case conditions of voltage, traffic etc. This current is used to size power
662 distribution cables, plant discharge capacity and over-current protectors. Generally, List
663 1 drain corresponds with the “as consumed” capacity (at the peak level), while List 2
664 drain corresponds to the “as ordered” capacity level. So, restating the problem with
665 Qwest’s application of the DC power plant usage charge in terms of List 1 drain and List
666 2 drain: Qwest is assessing the DC power plant charge based on the List 2 drain, when in
667 reality, List 1 drain defines DC power plant sizing, augmentation and investment.
668 Therefore, assessing the DC power plant charge on a List 2 drain is inconsistent with

¹⁷ Notably, in the context of collocation, DC power distribution is dedicated to a specific user, while DC power plant is shared among all users in the central office (i.e., Qwest and CLECs alike).

669 proper engineering practices. Also, as described above, the List 2 drain significantly
670 exceeds the List 1 drain, which means that Qwest's billing of McLeodUSA for DC power
671 plant based on the higher List 2 drain results in DC power plant charges that significantly
672 exceed the charges that would result from applying the charge to the "as consumed"
673 amperage.

674

675 **Q. IS QWEST'S ASSERTION THAT QWEST SIZES DC POWER PLANT BASED**
676 **ON POWER ORDERS CONSISTENT WITH QWEST'S ENGINEERING**
677 **REQUIREMENTS AND MANUALS?**

678 A. No, it is not. Qwest's own engineering guidelines and requirements belie Qwest's
679 assertions in this regard. In discovery, McLeodUSA requested Qwest to provide various
680 technical documents used by Qwest's collocation planning and power engineers when
681 they design central offices and their associated power infrastructure.¹⁸ This
682 documentation clearly supports my view of the proper sizing and engineering of DC
683 power systems (both DC power plant and DC power distribution), and directly
684 contradicts Qwest's view.

685

686 **Q. PLEASE PROVIDE SOME EXAMPLES WHEREIN QWEST'S INTERNAL**
687 **ENGINEERING DOCUMENTATION SUPPORTS YOUR POSITION AND**
688 **REFUTES THE POSITION TAKEN BY QWEST.**

¹⁸ McLeodUSA Data Request #1 of First Set to Qwest reads as follows: "**Request 1:** Please provide the following Qwest technical documents, or their closest equivalents, used by Qwest collocation planning and power engineers. It is McLeodUSA's understanding that all of these documents were originally produced either by AT&T, Bellcore/Telcordia or US West Business Resources, Inc. and, in some cases, were adapted for Qwest's internal use. If that understanding is not correct, please clarify."

689 A. Consider “*Qwest Technical Publication: Power Equipment and Engineering Standards,*
690 *Technical Document No. 77385, Issue H, September 2003, Copyright 1996, 1998, 1999,*
691 *2000, 2001 and 2002.*”¹⁹

692 Chapter 2 of this document entitled “*DC Power Plants and Chargers*” states as
693 follows:

694 **2.4 Engineering Guidelines**

695 When sizing power plants, the following criteria shall be used:

696 **List 1** drain is used for sizing batteries and chargers; the average busy-
697 hour current at normal operating voltage should be used. Telephony List
698 1 drains are measured at 9 ccs or at 18 ccs for the first 2 hours of a
699 discharge and 6 ccs thereafter.

700 **List 2** drain is used for sizing feeder cables, circuit breakers, and fuses;
701 the current that is required for projected peak under worst operating
702 conditions should be used. Telephony List 2 drains are measured at 36
703 ccs at -42.75 V for a nominal -48 VDC plant.
704
705
706

707 On the same page, the engineering manual discusses the sizing of battery plant – a
708 component of DC power plant – as follows:

709

710 **Q. IS THERE OTHER INFORMATION THAT SUPPORTS YOUR VIEW OF DC**
711 **POWER PLANT SIZING AND DIRECTLY CONTRADICTS QWEST’S VIEW?**

712 A. Yes. Take for example Bellcore’s “*DC Distribution,*” Technical Document No. 790-100-
713 656, which confirms the information above in Qwest’s Technical Publication.

714 Specifically, Section 2 “Telecommunications Equipment Loads” states as follows:

715 *****BEGIN CONFIDENTIAL**

716

717

718

¹⁹ Provided in response to McLeodUSA Data Request #1b and available at
<http://www.qwest.com/techpub>

719
720
721
722
723
724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750
751
752
753
754
755
756

[REDACTED]

END CONFIDENTIAL***

Furthermore, legacy document REGN 790-100-654RG “DC Plant” (published by Qwest)
states as follows:

*****BEGIN CONFIDENTIAL**

[REDACTED]

[REDACTED]

[REDACTED]

END CONFIDENTIAL***

Another excerpt from Qwest’s engineering manuals specifically warns against
doing precisely what Qwest is claiming that it does – i.e., size DC power distribution on
“as ordered” capacity, or List 2 drain. Qwest technical document REGN 790-100-655G
“Batteries” Issue No. 9 dated February 2006 (at page 22) states:

*****BEGIN CONFIDENTIAL**

[REDACTED]

757 **END CONFIDENTIAL*****

758 It is concerning that Qwest would advocate a position that its own engineering
759 manuals recommend against and that would create situations of *****BEGIN**

760 **CONFIDENTIAL** [REDACTED] **END**

761 **CONFIDENTIAL*****

762 Another one of these manuals – Bellcore technical document “Power Systems
763 Installation Planning” BR 790-100-652 (at page 5-1) elaborates on a power study
764 procedure used to size DC power systems. First it requires engineers to *****BEGIN**

765 **CONFIDENTIAL** [REDACTED]
766 [REDACTED]

767 **END CONFIDENTIAL***** This document also contains Figure 5-2 which is a flow
768 diagram of a “Power Study Procedure”. This flow diagram, which is documentation
769 memorializing the DC power plant sizing exercise I described, shows the following steps to
770 sizing DC power plant (pages 5-4 and 5-5): *****BEGIN CONFIDENTIAL** [REDACTED]

771 [REDACTED]
772 [REDACTED]
773 [REDACTED]
774 [REDACTED]
775 [REDACTED]
776 [REDACTED] **END**

777 **CONFIDENTIAL***** This manual also includes an example of the graph (see page 6-
778 11, Figure 6-1) that is created *****BEGIN CONFIDENTIAL** [REDACTED]

779 [REDACTED]
780 [REDACTED]

781
782
783
784
785
786
787
788
789
790
791
792
793
794
795
796
797
798
799
800
801
802
803
804

[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED] END

CONFIDENTIAL***

Q. WHAT DO THESE QWEST ENGINEERING GUIDELINES AND REQUIREMENTS SHOW?

A. The above excerpts from Qwest’s own power engineering manuals, individually and taken together, makes several points very clear:

*****BEGIN CONFIDENTIAL**

[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]
3. [REDACTED]
[REDACTED]

END CONFIDENTIAL***

All three (3) of these points support my testimony.

Q. YOU POINT TO A NUMBER OF ENGINEERING REQUIREMENTS AND MANUALS THAT SUPPORT YOUR VIEW OF THE METHOD FOR SIZING DC

805 **POWER PLANT AND DC POWER DISTRIBUTION. DID QWEST POINT TO**
806 **ANY ENGINEERING MANUALS, REQUIREMENTS OR OTHER**
807 **DOCUMENTATION SUPPORTING ITS VIEW IN IOWA?**

808 A. No and I highly doubt that Qwest will provide any relevant cites to engineering manuals
809 in Utah either, primarily because there are no engineering manuals or specifications
810 supporting Qwest’s notion that DC power plant is sized according to power orders – or
811 List 2 drain.

812
813 **Q. YOU ALSO MENTIONED THAT QWEST’S ASSERTION THAT DC POWER**
814 **PLANT IS SIZED BASED ON POWER ORDERS IS INCONSISTENT WITH**
815 **THE POSITION QWEST HAS TAKEN ELSEWHERE. PLEASE ELABORATE.**

816 A. Qwest Communications Corporation (which is, like Qwest Corp. the ILEC, a direct
817 subsidiary of Qwest Services Corporation)²⁰ recently sponsored testimony in Illinois
818 Commerce Commission Docket No. 05-0675, which addressed AT&T/SBC Illinois’
819 collocation DC power policy. In that case, SBC Illinois was attempting to change the
820 way in which it currently assessed power charges and was attempting to covert its
821 existing measured, kWh based charge to a simple per-amp charge, similar to that assessed
822 by Qwest in Utah. The testimony of the Qwest witness (Victoria Hunnicutt-Bisahra) in
823 Illinois undermines Qwest’s position here in Utah, and I have provided the pertinent
824 portions of Ms. Hunnicutt-Bishara’s response and surrebuttal testimony from Illinois as

²⁰ Qwest Services Corporation is a direct subsidiary of the ultimate parent company, Qwest Communications International, Inc.

825 Exhibit SLM-3 to my direct testimony. For instance, Ms. Hunnicutt-Bishara testified as
826 follows in Illinois:²¹

827
828 **Q. WHAT IS THE PURPOSE OF THE LIST 1 AND LIST 2**
829 **DRAIN SPECIFICATIONS?**

830 A. In the telecommunications industry, List 1 and List 2 drains are
831 the designations of the load current drains. These are used to
832 size various elements of the battery plant. Generally speaking,
833 the List 1 current drain is used to size batteries and rectifiers in
834 the plant. The List 2 current drain is used to size the DC load
835 feeder cables and the circuit protection device (fuse) for the DC
836 power arrangement. The fuse size is also dependent upon the
837 ampacity of the smallest conductor comprising the protected
838 feeder. Protectors should be rated as high as allowable to avoid
839 nuisance tripping due to high load conditions or inrush current
840 during startup.
841

842 Ms. Hunnicutt-Bishara also testified in Illinois as follows:

843 **Q. DOES BELLCORE HAVE ANY DOCUMENTATION RELATING**
844 **TO THE FUSING OF TELECOMMUNICATIONS EQUIPMENT?**

845 A. Yes, in its definition of List 2 drain, Bellcore (previously known as Bell
846 Communications Research, now known as Telcordia) states:

847
848 “These drains are used to size feeder cables and fuses.
849 These drains represent the peak current for a circuit or
850 group of circuits under worst case operating conditions.
851 For example, a constant power load requires maximum
852 current at minimum operating voltage.” (footnote
853 omitted)
854

855 The excerpts from Qwest’s Illinois testimony shows that at least one Qwest –sponsored
856 witness understands that, consistent with Qwest’s engineering guidelines, List 1 drain is
857 used to size DC power plant and List 2 drain is used to size DC power distribution.

²¹ Surrebuttal Testimony of Victoria Hunnicutt-Bishara, ICC Docket No. 05-0675, March 29, 2006, p. 4.

858 Indeed she cites to the same Bellcore technical document I cited to above (“DC
859 *Distribution*,” Technical Document No. 790-100-656) as support for her testimony and
860 attaches this document to her testimony as an exhibit. There is no plausible explanation
861 that Qwest can provide that can square its position in Utah that DC power plant is sized
862 based on CLEC power orders (or List 2 drain) and its affiliate’s testimony in Illinois
863 stating (correctly) that DC power plant is sized based on List 1 drain. Indeed, based on
864 my experience in Iowa, I suspect that Qwest Utah may not even address the concepts of
865 List 1 drain and List 2 drain in its testimony, despite their importance to this proceeding,
866 because when Qwest is forced to concede that DC power plant is sized on List 1 drain
867 and DC power distribution is sized on List 2 drain, Qwest’s position in Utah that
868 McLeodUSA should pay for DC power plant based on List 2 drain is exposed as fatally
869 flawed.

870

871 **Q. ARE THERE OTHER PORTIONS OF QWEST COMMUNICATIONS CORP.’S**
872 **TESTIMONY IN ILLINOIS THAT CONFLICT WITH QWEST’S POSITION IN**
873 **UTAH?**

874 A. Yes. In Illinois, Ms. Hunnicutt-Bishara testified that one of the problems with
875 AT&T/SBC-Illinois’ position in the Illinois docket was SBC’s “false assumption that
876 telecommunications equipment draws power at the maximum load required twenty-four
877 hours a day, seven days a week.”²² Ms. Bishara explained that “[t]his assumption of a
878 maximum and linear power load is erroneous...”²³ In other words, Ms. Hunnicutt-
879 Bishara criticized AT&T/SBC Illinois for assuming in its DC power charge development

²² Response Testimony of Victoria Hunnicutt-Bishara, Illinois Commerce Commission Docket No. 05-0675, on behalf Qwest Communications Corp., QCC Exhibit 1.0, Public Version, February 2, 2006, p. 8.

²³ *Id.*

880 that Qwest's equipment collocated in AT&T/SBC Illinois central offices draws a
881 maximum load at all times. Instead, Ms. Hunnicutt-Bishara argued that Qwest's CLEC
882 equipment draws power relative to factors associated with busy-hour usage.

883 Despite the recognition by its affiliate of the falsehood of a maximum 24x7 load,
884 Qwest Utah is billing McLeodUSA for DC power plant usage as if this continuous,
885 maximum load exists.

886

887 **Q. IN IOWA, QWEST CLAIMED THAT IT MUST ENGINEER POWER PLANT**
888 **BASED ON THE AMOUNT OF POWER (DISTRIBUTION) ORDERED**
889 **BECAUSE QWEST HAS NO IDEA OF HOW FAST THE POWER**
890 **REQUIREMENTS OF MCLEOD OR ANY OTHER CLEC ARE GOING TO**
891 **GROW.²⁴ IS THIS TRUE?**

892 A. No, this is factually inaccurate. Qwest does have an idea of how fast the power
893 requirements of McLeodUSA and other CLECs will grow because CLECs must provide
894 this information to Qwest when ordering and augmenting collocations. For instance, the
895 collocation application form for a collocation new/change/augment contains Section
896 II.F.5, which requires the collocator to provide: (1) a description of the equipment it will
897 collocate, (2) the model numbers of collocated equipment, (3) functionality of collocated
898 equipment, (4) dimensions of collocated equipment and (5) quantity of collocated
899 equipment. Furthermore, Section III.B. of the collocation application form requires the
900 collocator to indicate the quantity of DS0s, DS1s and DS3s the collocator intends to
901 support. Therefore, collocated CLECs keep Qwest well-informed about how fast the
902 power requirements of collocated CLECs are going to grow.

²⁴ See, e.g., Direct Testimony of Robert J. Hubbard, Iowa Utilities Board Docket No. FCU-06-20, March 23, 2006, p. 9, lines 17 – 20.

903

904

Q. QWEST ALSO CLAIMED IN IOWA THAT IT MUST ENGINEER DC POWER PLANT AT THE “AS ORDERED” CAPACITY LEVEL BECAUSE EQUIPMENT MODIFICATIONS TO THE POWER PLANT ARE TIME CONSUMING AND IT WOULD TAKE TOO LONG FOR QWEST TO RESPOND TO ACTUAL DEMAND FLUCTUATIONS.²⁵ IS THIS CORRECT?

905

906

907

908

909

A. No. Not only is Qwest made fully aware of the equipment type and amount that is collocated in its central office as well as the expected number of circuits served by that equipment, Qwest is given ample time to augment its DC power plant should conditions require it. For instance, Section 8.4.3.4.1 of Qwest Utah’s SGAT shows that when certain conditions are met, Qwest has 90 days from receipt of a complete collocation application to provision the request. Accordingly, Qwest cannot be taken by surprise by an increase in usage at a collocation arrangement because it is aware of the equipment the DC power plant is serving, and Qwest is made aware well in advance of any changes to that equipment configuration.

910

911

912

913

914

915

916

917

918

Moreover, demand fluctuations are already accounted for in the proper sizing of DC power plant when it is sized according to List 1 drain. In other words, by sizing DC power plant based on List 1 drain, Qwest is sizing at peak capacity at the busy-hour, which means that all short-term (e.g., daily, weekly, etc.) demand fluctuations are accounted for and can be handled by the DC power plant.

919

920

921

922

923

924

Q. DOES DATA EXIST THAT REFUTES QWEST’S CLAIM THAT MCLEODUSA’S POWER USAGE COULD INCREASE TO A LEVEL THAT

925

²⁵ See, e.g., Direct Testimony of Robert J. Hubbard, Iowa Utilities Board Docket No. FCU-06-20, March 23, 2006, page 8, lines 14 – 17.

926 **WOULD PUT QWEST’S ABILITY TO PROVIDE ORDERED DC POWER IN**
927 **JEOPARDY ASSUMING THAT IT SIZED DC POWER PLANT BASED ON LIST**
928 **1 DRAIN?**

929 A. Yes. In a vast majority of instances, McLeodUSA’s power usage will constitute a very
930 small fraction of the total power draw requirements of the central office. This is
931 supported by the data Qwest provided in response to McLeodUSA’s discovery. For
932 instance, in response to McLeodUSA’s data request No. 8(a) [“For each Qwest central
933 office in Utah wherein McLeodUSA has a collocation space, please provide the
934 following information: (a) the total installed -48V DC Power capacity considering all
935 individual power plants within the office (in Amps).”], Qwest provided Confidential
936 Attachment A, which shows this data by CLLI code. And in response to McLeodUSA
937 data request No. 8(b) [“Actual measured load, busy day, busy hour (for most recent
938 measurement and date of measurement)”], Qwest provided Confidential Attachment B,
939 which provides these measurements by date and by CLLI. Comparing the McLeodUSA
940 busy hour power draw for a central office from Confidential Attachment B to the total
941 installed DC power capacity will show how much of the power capacity for an office
942 McLeodUSA is actually using at peak normal operating conditions. Take for example,
943 the following three (3) central offices: AMFKUTMA, PLGVUTMA, and TOOLUTMA.
944 Confidential Attachment A indicates that the total installed DC power capacity (in Amps)
945 for these offices is *****BEGIN CONFIDENTIAL** [REDACTED]
946 **END CONFIDENTIAL***** Confidential B indicates that between
947 February 6 and 8, 2006, Qwest measured McLeodUSA’s busy hour draw at these offices
948 to be *****BEGIN CONFIDENTIAL** [REDACTED]
949 **END CONFIDENTIAL***** Hence, McLeodUSA’s busy hour draw for these three



950 central offices constitutes only *****BEGIN CONFIDENTIAL** [REDACTED]
951 [REDACTED] **END CONFIDENTIAL***** of the total installed DC power
952 capacity of the offices. As further evidence that these findings are typical, Confidential
953 Attachments A and B also indicate that for the following four (4) CLLI codes
954 (BGCYUTMA, CLFDUTMA, SPVLUTMA, and OREMUTMA), McLeodUSA's busy
955 hour power draw, as a percentage of the total DC power capacity of the end office is ***
956 **BEGIN CONFIDENTIAL** [REDACTED] **END**
957 **CONFIDENTIAL***** The data demonstrates that McLeodUSA's busy hour power usage
958 actually constitutes a very small percentage of the total installed power capacity of a
959 particular central office. Given that power engineers size DC power plant based on the
960 aggregate List 1 drain of all telecommunications equipment being powered, and given
961 that McLeodUSA's peak power usage constitutes a small fraction of Qwest's power
962 capacity, it is clear that McLeodUSA's DC power would be a relatively minute
963 consideration in the Qwest DC power plant planning/sizing process.

964
965 **Q. QWEST CLAIMED IN IOWA THAT IF MCLEODUSA ORDERS 175 AMPS OF**
966 **CAPACITY (OR 175 AMP DISTRIBUTION CABLE), QWEST WOULD**
967 **DEFINITELY AUGMENT ITS DC POWER PLANT CAPACITY REGARDLESS**
968 **OF MCLEODUSA'S ACTUAL USAGE. WOULD QWEST ALREADY HAVE**
969 **THE CAPACITY ON ITS DC POWER PLANT TO PROVIDE MCLEODUSA**
970 **THE POWER USAGE OVER MCLEODUSA'S HYPOTHETICAL 175 AMP**
971 **POWER CABLE WITHOUT AUGMENTING ITS DC POWER PLANT IN A**
972 **VAST MAJORITY OF INSTANCES?**

973 A. Yes. As demonstrated above, McLeodUSA's actual power draw constitutes a very small
974 portion of the total DC power capacity of the central office, so even if the McLeodUSA
975 DC power usage doubled or tripled (which is very unlikely in the short run), it would still
976 constitute a very small portion of total capacity and Qwest's existing capacity could
977 handle it.

978 Further, as even Qwest concedes, the power requirements of the entire central
979 office are taken into account when sizing the DC power plant infrastructure to serve that
980 central office. Since this DC power plant infrastructure is sized in the aggregate (with
981 spare capacity), individual orders by CLECs for DC power distribution cables should not
982 trigger an investment in DC power plant unless the power plant at that particular location
983 is already nearing an augmentation threshold because of the aggregate demand for power
984 from all users in the central office. Because the relative size of that individual order
985 compared to the aggregate investment in DC power plant would be relatively small, it
986 should have little effect on the ability of the DC power plant infrastructure to serve the
987 power needs of that office. Rather, the power requirements associated with the usage
988 over those cables would be aggregated with the power requirements associated with the
989 usage over all other cables in the central office (as observed relative to the average busy
990 hour) to determine the appropriate level of investment in DC power plant. So, when
991 added to the mix, McLeodUSA's hypothetical 175 amp order would require no additional
992 DC power plant augment/investment. This is especially true given that Qwest will
993 monitor the aggregate power requirements of the central office over time and augment
994 DC power plant on a central office-wide basis.

995

996 Q. QWEST’S POSITION RESTS ON THE ASSUMPTION THAT QWEST ADDS DC
997 POWER PLANT EQUIPMENT WHEN MCLEODUSA ORDERS POWER TO A
998 COLLOCATION ARRANGEMENT. DOES QWEST ALSO ASSUME THAT
999 QWEST REMOVES DC POWER PLANT EQUIPMENT WHEN MCLEODUSA
1000 (OR ANY OTHER CLEC) DECOMMISSIONS A COLLOCATION
1001 ARRANGEMENT?

1002 A. No, indeed Qwest specifically states that it does not remove or reduce DC power plant
1003 equipment when CLECs decommission collocation arrangements. In response to
1004 McLeodUSA data request #5, Qwest responded as follows:

As a rule, Qwest does not remove or reduce its Power Plant Capacity based on decommissioned collocations. However, there are instances where Qwest will reassign fuse positions for Battery Distribution Fuse Bay (BDFB) and Power Boards (PBD) based on demand. (emphasis added)

1011 Therefore, what Qwest is saying is that CLEC orders for power distribution cables drive
1012 the addition of (and Qwest investment in) DC power plant equipment, but that CLEC
1013 requests to decommission collocation (thereby removing collocated equipment and
1014 rendering the DC power distribution arrangement to that collocation cage useless) would
1015 not trigger the removal of DC power plant equipment. Following Qwest’s logic, what
1016 would result is an ever-increasing DC power plant capacity that has no relationship to the
1017 power requirements of the central office – regardless of whether those “power
1018 requirements” are based on List 1 drain as I contend or List 2 drain as Qwest contends.

1019 Furthermore, Mr. Qwest’s assertion in this regard conflicts again with Qwest’s
1020 engineering guidelines -specifically Bellcore’s “Power Systems Installation Planning”
1021 manual (at page 6-2), which states that *****BEGIN CONFIDENTIAL** [REDACTED]

1022 [REDACTED]

1023
1024
1025
1026
1027
1028
1029
1030
1031
1032
1033
1034
1035
1036
1037
1038
1039
1040
1041
1042
1043
1044
1045
1046

[REDACTED]

[REDACTED]

[REDACTED] **END CONFIDENTIAL***** Thus, the busy-hour drain is calculated by Qwest and, in turn, the DC power plant is sized by Qwest, based on equipment in service. Again, this information contradicts Qwest’s position which paints a picture of DC power plant being based on CLEC power orders, with Qwest being left “holding the bag” with regard to DC power plant investment when CLECs do not use the power capacity they ordered or if the DC power plant usage charge is applied on an “as consumed” basis.

What Qwest power engineers actually do is *****BEGIN CONFIDENTIAL** [REDACTED]

[REDACTED]

[REDACTED] **END CONFIDENTIAL***** Hence, if CLEC A decommissions its collocation cage, the feeder serving those collocations would not have in-service equipment associated with it, and would therefore not be captured in the List 1 drain or included when sizing DC power plant.

Q. YOU EXPLAIN ABOVE THAT QWEST’S POSITION IS UNDERMINED BY ITS ENGINEERING MANUALS AS WELL AS QWEST EXPERT TESTIMONY IN ILLINOIS. IS QWEST’S POSITION IN THIS CASE ALSO UNDERMINED BY ITS DISCOVERY RESPONSES?

A. Yes. As mentioned above, Qwest’s response to McLeodUSA data request number 5 indicates that Qwest does not remove DC power plant equipment when a CLEC decommissions a collocation arrangement. Therefore, following Qwest’s logic that DC power plant investment is based on CLEC power orders and that Qwest would definitely augment its DC power plant capacity to accommodate a CLEC order for 175 amp DC

1047 power distribution cable, if that CLEC subsequently decommissioned its collocation
1048 arrangement, there should be 175 amps of excess capacity in the DC power plant for that
1049 central office. If McLeodUSA or another CLEC subsequently requests a collocation
1050 arrangement in that office – everything else equal – there should be 175 amps of capacity
1051 in the DC power plant to serve McLeodUSA without any DC power plant
1052 augment/addition/investment. According to Qwest, instead of using the 175 amps of
1053 excess capacity freed up by the original CLEC, Qwest would build in another 175 amps
1054 of DC power plant capacity to meet McLeodUSA’s request. This would be wasteful and
1055 inefficient – not to mention inconsistent with Qwest’s engineering guidelines. And this
1056 example is conservative because it only assumes one decommissioned collocation
1057 arrangement. If we modify the scenario to assume that five (5) CLECs decommissioned
1058 collocation arrangements, each with 175 amps of DC power distribution capacity, Qwest
1059 would apparently ignore the 875 amps of “freed up” DC power plant capacity due to
1060 collocation decommissioning and, instead, build in another 175 amps of DC power plant
1061 capacity to meet McLeodUSA’s request.

1062

1063 **Q. WHAT TYPE OF EQUIPMENT DOES MCLEODUSA TYPICALLY USE IN ITS**
1064 **COLLOCATION SITES IN UTAH AND HOW DOES THIS RELATE TO THE**
1065 **DISCUSSION ABOVE?**

1066 A. McLeodUSA typically uses a collocation design that contains the equipment listed in
1067 Figure 6 below.

1068 *****BEGIN CONFIDENTIAL**

1069

Fig. 6 Typical McLeodUSA Collocated Equipment and Associated Power Requirements			
Collocated Equipment	Fuse Size	Manufac. Maximum Power Draw (DC amps)	McLeodUSA Est. DC Power Draw
Total DC Power Requirement (Amps)			

1070
1071

END CONFIDENTIAL***

1072
1073
1074
1075
1076
1077
1078
1079
1080

Figure 6 provides the following information regarding McLeodUSA’s typical collocation design. The collocated equipment and model is provided in column 1, the Fuse Size amperage is provided in column 2, the manufacturer’s maximum DC power draw (in amps) is provided in column 3, and the estimated DC power draw (in amps) is provided in column 4. The fuse size refers to the amperage for which the fuse panel is fused, the manufacturer’s maximum power draw is the same as the List 2 drain, and the estimated DC power draw amperage is based on actual power readings made by McLeodUSA.

1081
1082
1083
1084
1085
1086
1087
1088

- Q. WHAT DOES FIGURE 6 SHOW?**
- A. Figure 6 demonstrates the point I have made in my testimony above, i.e., “as ordered” amperage bears no relationship to “as consumed” amperage. The “fused amps” power capacity is *****BEGIN CONFIDENTIAL [REDACTED] END CONFIDENTIAL***** As I have explained, carriers must design DC power distribution equipment such that it protects the power cables above and beyond what would be required under a “worst case scenario” draw or List 2 Drain. The List 2 drain is *****BEGIN CONFIDENTIAL [REDACTED] END CONFIDENTIAL*****, which means that, in this typical



1089 arrangement, McLeodUSA’s fused amperage is over *****BEGIN CONFIDENTIAL**
1090 **END CONFIDENTIAL***** greater than List 2 drain.²⁶ Moreover, Figure 6 shows
1091 that McLeodUSA was required to design its power distribution at an amperage level that
1092 is *****BEGIN CONFIDENTIAL** **END CONFIDENTIAL***** greater than the
1093 actual McLeodUSA power draw, and the List 2 drain is *****BEGIN CONFIDENTIAL**
1094 **END CONFIDENTIAL***** greater than McLeodUSA’s actual power draw at the
1095 busy hour. While this difference between “as ordered” and “as consumed” DC power
1096 reflects a typical McLeodUSA collocation arrangement, this difference can vary by
1097 collocation site with the potential for differences between “as ordered” and “as
1098 consumed” amperages far larger than those identified above.

1099

1100 **Q WHY DOES MCLEODUSA HAVE A FUSE PANEL AND FUSES IN THEIR**
1101 **COLLOCATION ARRANGEMENT?**

1102 A. McLeodUSA typically uses a mini-BDFB in their collocation arrangement for power
1103 management purposes, which accepts the DC power from Qwest and (i) distributes power
1104 to each individual relay, (ii) fuses the power at each relay to provide fuse panel protection
1105 and (iii) distributes DC power to the telecommunications equipment listed in Figure 5
1106 above. This provides flexibility to McLeodUSA to better manage the power within its
1107 collocation cage and fuse the power at a level consistent with the need of the individual
1108 equipment.

1109

1110 **Q. EXPLAIN THE MCLEODUSA ESTIMATED DC POWER DRAW IN COLUMN 4**
1111 **OF FIGURE 6.**

²⁶ The List 2 Drain serves as one of the factors in sizing of power distribution cables as indicated in the power cable sizing formula, see *supra*.

1112 A. Column 4 of Figure 6 (McLeodUSA Estimated DC Power Draw) is the actual DC current
1113 in amperes as measured by a McLeodUSA technician using a clamp on ampere meter.
1114 This measurement was made by McLeodUSA during the busy hour period of
1115 approximately 10AM and Noon. As explained above, the measured actual DC power
1116 draw in amperes or “as consumed” power in column 4 is considerably less than “as
1117 ordered” amperage.

1118

1119 **Q. HOW CAN YOU BE SURE THAT THE DC POWER DATA TREND**
1120 **REFLECTED IN FIGURE 6 – THAT FUSED AMPS AND LIST 2 DRAIN BOTH**
1121 **SIGNIFICANTLY EXCEED ACTUAL POWER DRAW – IS REPRESENTATIVE**
1122 **OF THE TYPICAL MCLEODUSA COLLOCATION SITE?**

1123 A. I performed my own analysis of the actual DC power draw requirements of a
1124 McLeodUSA collocation site and arrived at very similar findings. On February 28, 2006,
1125 I visited three (3) McLeodUSA collocation sites in Denver, Colorado: (i) Denver Curtis
1126 Park, (ii) Denver Capitol Hill and (iii) Denver South. During these visits, I had an
1127 opportunity to take my own measurements of the actual DC power draw of
1128 McLeodUSA’s collocated equipment and the distribution of that DC current within the
1129 collocation cages to the collocated equipment being powered. I then compared these
1130 measurements to the amperage of the DC power distribution cables. The results of this
1131 comparison show that DC power distribution capacity for each of these collocation sites
1132 significantly exceed McLeodUSA’s actual DC power draw at the busy hour.

1133

1134 **Q. PLEASE ELABORATE ON THESE POWER MEASUREMENTS?**

1135 A. I personally measured the actual current in amperage being delivered from Qwest to these
 1136 McLeodUSA collocation sites via a Fluke clamp-on meter for both the A and B power
 1137 distribution leads during the busy-hour period of between 10AM and Noon (exact time of
 1138 measurements provided below). I then checked the power distribution cable tags at the
 1139 McLeodUSA mini-BDFBs for the power ratings of each cable. The tags are an
 1140 installation requirement and state the design capability of the power distribution cables in
 1141 amperes. The power data collected from the actual power measurements as well as the
 1142 power distribution cable tags is provided below in Figure 7.

1143 *****BEGIN CONFIDENTIAL**

Figure 7. McLeodUSA “as ordered” versus “as consumed” amperage

Qwest Central Office	“As ordered” Amperage	“As consumed” Amperage	Date & Time of Measurement	% Fused Vs Measured E = C/B
A	B	C	D	E
Denver Curtis Park	[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]
Denver Capitol Hill	[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]
Denver South	[REDACTED]s	[REDACTED]	[REDACTED]	[REDACTED]

1145
 1146 **END CONFIDENTIAL *****

1147
 1148 **Q. PLEASE EXPLAIN THE DATA PRESENTED IN FIGURE 7.**

1149 A. Column A of Figure 7 provides the name of the Qwest central office in which the
 1150 McLeodUSA collocation sites I visited reside. Column B is the amperage of the DC
 1151 power distribution cables (“as ordered” amperage), as taken from the power distribution
 1152 cable tags, which represents the current distribution capacity to the McLeodUSA

1153 collocation cage (i.e., the “as ordered” capacity). Column C is the actual measured
1154 amperage or “as consumed” power of the McLeodUSA collocation arrangement, as
1155 measured by me at the date and time specified in Column D. Finally, Column E
1156 represents the percent of total “as ordered” amps that McLeodUSA’s collocation was
1157 actually using at the time of the power measurement.

1158 Column E of Figure 7 shows that, for each McLeodUSA collocation site, the
1159 actual “as consumed” usage is about *****BEGIN CONFIDENTIAL** ██████████
1160 **END CONFIDENTIAL***** of the “as ordered” amperage. In other words, the “as
1161 ordered” capacity of the power distribution cables exceeds the “as consumed” capacity by
1162 about *****BEGIN CONFIDENTIAL** ██████████ **END CONFIDENTIAL***** This
1163 difference between “as consumed” and “as ordered” is even greater than the *****BEGIN**
1164 **CONFIDENTIAL** ██████████ **END CONFIDENTIAL***** difference
1165 attributed to a typical McLeod collocation site above in Figure 6.

1166
1167 **Q. DO THESE RESULTS INDICATE THAT MCLEODUSA HAS SIMPLY “OVER-**
1168 **ORDERED” DC POWER DISTRIBUTION CAPACITY FROM QWEST?**

1169 A. No. Recall that McLeodUSA is required by engineering specifications and
1170 manufacturers’ requirements to order power distribution capacity at amperage levels that
1171 significantly exceed the actual power draw of its collocated equipment at peak periods.
1172 In any event, DC power distribution facilities are sized differently and McLeodUSA
1173 compensates Qwest for costs related to DC power distribution facilities through separate
1174 charges.

1175

1176 Q. ARE THE RESULTS FROM YOUR AUDIT OF THE COLORADO
1177 COLLOCATIONS REPRESENTATIVE OF UTAH?

1178 A. Yes, I have reviewed a list of collocation equipment within Utah collocations and it is
1179 comparable to the equipment in the Colorado locations. Given the nature of these
1180 devices, the power draw from equipment in a Colorado collocation would be
1181 representative of McLeodUSA's Utah collocations.

1182

1183 B. *Proper DC power sizing and engineering supports McLeodUSA's*
1184 *recommended application of the DC power plant usage charge*
1185

1186 Q. YOU EXPLAINED ABOVE THAT DC POWER DISTRIBUTION IS SIZED
1187 BASED ON LIST 2 DRAIN AND THAT DC POWER PLANT IS SIZED BASED
1188 ON FORECASTED ACTUAL PEAK USAGE. HOW DOES THIS RELATE TO
1189 MCLEODUSA'S COMPLAINT?

1190 A. This shows that there is no relationship between the CLEC's order for power distribution
1191 and the power plant capacity the CLEC actually uses or the power the CLEC should be
1192 required to pay for. Therefore, Qwest's application of the rate for DC power plant needs
1193 to recognize the distinction between the ordering of the DC Power distribution network,
1194 which sizes the power distribution cables extended into the CLEC collocation
1195 arrangement on List 2 drain, *separately* from the demand for DC Power itself (i.e., List 1
1196 drain). Any connection between the engineered size of the DC Power distribution
1197 network and the rate for DC power plant usage is inappropriate and inconsistent with the
1198 way in which DC power is sized and consumed. The crux of McLeodUSA's complaint
1199 stems from the fact that Qwest is assessing a DC power plant usage charge, based on the
1200 "as ordered" amps, when proper engineering practice (and the parties' DC Power

1201 Measurement Amendment) calls for Qwest to assess this charge based on the actual
1202 power consumed (or “as consumed” amps).

1203

1204 **Q. DOES THE FACT THAT CLECS ORDER DC POWER DISTRIBUTION**
1205 **CAPACITY BASED ON A HIGHER LIST 2 DRAIN IMPACT QWEST’S DC**
1206 **POWER PLANT PLANNING/AUGMENTS/INVESTMENTS?**

1207 A. No. Again, DC power plants are sized based on forecasted actual peak usage, i.e.,
1208 average busy hour for the entire central office and is not dependent on the amount of
1209 amps ordered by a particular CLEC for distribution facilities for a collocation. Therefore,
1210 the central office engineers observe the peak power requirements of the central office
1211 power plant as a whole and augment the DC power plant if the peak usage approaches a
1212 level that would exceed the current power capacity. DC power plant augments are not
1213 driven by individual orders for power distribution cables and/or fuses by CLECs (or
1214 Qwest).²⁷ Simply put, Qwest does not plan or augment its power requirements or power
1215 plant based on individual power orders of CLECs and hence, its power plant investments
1216 are not incremental to those orders (as described in more detail by Mr. Starkey).

1217

1218 **Q. WILL QWEST BE FULLY COMPENSATED FOR DC POWER PLANT COSTS**
1219 **IF IT ASSESSES THE DC POWER PLANT USAGE CHARGE ON AN “AS**
1220 **CONSUMED” BASIS INSTEAD OF AN “AS ORDERED” BASIS?**

1221 A. Michael Starkey addresses cost recovery in his testimony. However, it has been my
1222 experience in the past that one of the arguments ILECs use to argue against billing DC

²⁷ Note: a possible exception to this general rule is if Qwest would install an entire switch or major switch addition, or similar, very large-scale equipment addition. My testimony above pertains to the normal, or average, growth in power plant capacity that typically occurs within a central office, the type of growth experienced by McLeodUSA collocated equipment.

1223 power usage on an “as consumed” basis is that such a rate structure will result in stranded
1224 DC power plant investment. The basic (and erroneous) premise of the ILEC argument is:
1225 CLECs order power distribution cables based on the relatively higher “as ordered”
1226 amperage, ILECs must build out their DC power plant to meet these power requirements,
1227 and therefore, assessing DC power plant charges based on the relatively lower “as
1228 consumed” amperage would result in stranded costs for DC power plant. There is no
1229 engineering validity to such an argument.

1230

1231 **Q. WHY DO YOU SAY THAT THERE IS NO ENGINEERING VALIDITY TO**
1232 **QWEST’S ARGUMENT?**

1233 A. As explained above, ILECs do *not* augment the shared DC power plant of their central
1234 offices based on the ordered capacity of the power distribution cables, and as such, Qwest
1235 would not have augmented (or invested in) its DC power plant based on McLeodUSA’s
1236 (or any other CLEC’s) collocation power orders. Accordingly, there is no stranded
1237 investment related to billing DC power plant based on an “as consumed” basis because
1238 this so-called stranded investment was never made in the first place, assuming Qwest is
1239 monitoring and sizing its DC power plant consistent with proper engineering practices.

1240

1241 C. *Qwest’s Power Reduction offering is not a suitable option to billing DC power*
1242 *usage charges on an “as consumed” basis*

1243

1244 **Q. QWEST OFFERS A “POWER REDUCTION” AMENDMENT THAT CLECS**
1245 **CAN INCORPORATE INTO THEIR INTERCONNECTION AGREEMENTS.**
1246 **QWEST HAS ARGUED THAT THIS AMENDMENT SHOULD ALLOW**
1247 **MCLEODUSA TO MORE CLOSELY ALIGN ITS “AS ORDERED” USAGE**

1248 **WITH ITS “AS CONSUMED” USAGE SO AS TO AVOID THE TYPES OF**
1249 **ISSUES YOU DESCRIBE ABOVE. PLEASE BRIEFLY DESCRIBE POWER**
1250 **REDUCTION.**

1251 A. Qwest’s “Power Reduction” offering allows CLECs to eliminate or reduce multiple feeds
1252 from 60 to zero amps or reduce main feeds from 60 to 20 amps.²⁸ According to Exhibit
1253 A to the Power Reduction Amendment, the work performed by Qwest under the Power
1254 Reduction offering includes: changing fuses at the BDFB, changing breakers at the power
1255 plant, re-engineering smaller power cables and various other detailed engineering work
1256 aimed at re-engineering a CLEC’s power *distribution* infrastructure. Qwest has proposed
1257 non-recurring charges for Power Reduction of \$787 and \$1,028 if power cabling changes
1258 are not necessary and ICB-based rates for power cabling changes. Apparently, Qwest has
1259 offered the Power Reduction offering in order for CLECs to reduce the fused amp
1260 capacity of their DC power *distribution* infrastructure (i.e., fuses and power cables).

1261
1262 **Q. YOU EXPLAIN ABOVE THAT QWEST’S POWER REDUCTION OFFERING**
1263 **PERTAINS TO RESIZING DC POWER *DISTRIBUTION* INFRASTRUCTURE.**
1264 **DOESN’T THE PRIMARY DISPUTE IN THIS PROCEEDING PERTAIN TO**
1265 **QWEST’S RATES RELATED TO ITS DC POWER *PLANT* – NOT**
1266 **DISTRIBUTION – CHARGES?**

1267 A. Yes, and this underscores the inapplicability of the Power Reduction Amendment and its
1268 inability to solve the problem McLeodUSA believed it was solving in signing the Power
1269 Measurement Amendment. That is, Qwest is apparently attempting to resolve an issue

²⁸ Qwest DC Power Reduction Amendment, Attachment 1, Section 4.0.

1270 pertaining to its billing of DC power *plant* charges by creating a process (and a costly one
1271 at that) for the CLEC to resize its DC power *distribution* infrastructure.

1272 Qwest’s position is that the Power Reduction offering will allow CLECs to more
1273 closely align their “as ordered” capacity in their DC power distribution arrangements and
1274 their “as consumed” DC power usage, such that the CLEC could theoretically lower its
1275 DC power plant charges. While Mr. Starkey will address the appropriate charges for DC
1276 power plant, from an engineering standpoint, the possibility of reducing power charges
1277 through the Power Reduction process is riddled with flaws and is not a suitable substitute
1278 for assessing DC power plant charges on an “as consumed” basis.

1279

1280 **Q. WHAT ARE THE PROBLEMS WITH QWEST’S POWER REDUCTION**
1281 **OFFERING?**

1282 A. First and foremost, a CLEC does not want to align its “as ordered” capacity for DC
1283 power distribution with the “as consumed” amperage of the DC power plant, which is the
1284 stated objective of Qwest’s Power Reduction offering. As discussed above, there is no
1285 relationship between DC power distribution capacity and DC power plant investment,
1286 and Qwest should not attempt to create such a relationship through the Power Reduction
1287 offering because doing so could result in refusing DC power distribution arrangements
1288 below the level recommended by manufacturers and safety standards. As a result, the
1289 most evident problem is that it does nothing to address the problem with the manner in
1290 which Qwest assesses its DC power plant charge. Under Qwest’s proposal, it would
1291 continue to bill the DC power plant charge on an “as ordered” capacity instead of “as
1292 consumed” – though the “as ordered” level could theoretically be lowered after the
1293 resizing of DC power distribution occurs. For example, if a CLEC resizes its power

1294 distribution arrangement from 60 Amps to 20 Amps, but only uses 8 Amps of DC power,
1295 the CLEC is still overpaying for DC power by 12 Amps (instead of the higher
1296 overpayment of 52 Amps). Such a situation is still inconsistent with the manner in which
1297 DC power plant is sized and would still result in overcharges to McLeodUSA.
1298 Furthermore, Qwest's Power Reduction is unnecessary, potentially dangerous, service-
1299 affecting and costly.

1300

1301 **Q. PLEASE ELABORATE ON WHY QWEST'S POWER REDUCTION OFFERING**
1302 **IS UNNECESSARY, POTENTIALLY DANGEROUS, SERVICE-AFFECTING**
1303 **AND COSTLY?**

1304 A. Qwest's power reduction offering is unnecessary because the CLECs to which this
1305 offering is geared have already engineered and installed power distribution infrastructure
1306 and fused that equipment based on the proper engineering criteria described above.
1307 Hence, to subsequently resize the power cables and fuses serves no real useful purpose.
1308 For instance, if a CLEC's power cables and fuses are sized for 60 Amps, it makes no
1309 sense to reduce the fuse size to 20 Amps, such that the CLEC's power feeds are 60 Amps
1310 while the fuses that protect them are 20 Amps. And since power distribution
1311 infrastructure is sized for ultimate demand, if a CLEC reduces the rated amperage of its
1312 power cables through Qwest's Power Reduction offering (and incurs the costs to resize),
1313 the CLEC may find itself in a situation where it must add capacity in the future. This
1314 constant resizing of DC power distribution infrastructure based on existing demand is
1315 unnecessary and does not comport with good engineering practice.

1316 Such resizing of DC power distribution infrastructure can also be dangerous and
1317 service-affecting. Any time power is augmented in the central office for a collocation

1318 arrangement, there is a risk of losing power altogether to that collocation arrangement,
1319 which, in turn, risks service outages for CLEC customers. For instance, I have explained
1320 that CLECs engineer redundancy into their collocation power leads, wherein a
1321 collocation arrangement is served by both an “A” lead and a backup “B” lead. If the
1322 power for that collocation is switched over to the “B” lead while augmenting the “A”
1323 lead or associated fuses, power could be lost in the transition. Further, augmenting power
1324 cables within the cable racks in the central office, as would be performed under Qwest’s
1325 power reduction offering, poses operational risks related to technicians.

1326 Qwest’s Power Reduction offering is also costly. According to Qwest, this
1327 offering poses both administrative (e.g., Quote Preparation Fee) and engineering costs,
1328 and can exceed \$1,000 to change a fuse and potentially thousands of dollars to change out
1329 a power cable.²⁹ This is in addition to the costs that CLECs would incur to make these
1330 changes. Additionally, the CLEC would place their collocation sites at risk for large,
1331 additional power charges each time equipment additions are made to the collocation site.
1332 In sum, instead of assisting CLECs in managing their power costs, Qwest’s Power
1333 Reduction offering would likely result in very large power charges to the CLEC for
1334 changing power requirements to meet ongoing equipment changes and augments within a
1335 particular CLEC collocation site, while at the same time providing no assistance relative
1336 to the underlying problem, i.e., Qwest will continue to bill power plant-related charges
1337 inappropriately on an “as ordered” as opposed to an “as consumed” basis.

1338

²⁹ Qwest proposes individual case basis (ICB)-based pricing for this option, so the pricing is not actually known. However, it is reasonable to assume that it will significantly exceed the charges for changing fuses.

1339 Q. DO YOU HAVE OTHER CONCERNS WITH THE POWER REDUCTION
1340 AMENDMENT?

1341 A. Yes. Qwest's Power Reduction would force the CLEC to bear all risk associated with
1342 this unnecessary and costly work. Section 2.6 of Qwest's DC Power Reduction
1343 Amendment states: "CLEC assumes all responsibility for outages and/or impacts to
1344 CLEC-provided service and equipment due to the reduction in DC Power." As explained
1345 above, there is potential risk of service-affecting problems due to changing out
1346 fuses/breakers and replacing power cables – all of which is unnecessary given that the
1347 power infrastructure is already in place and working properly – and Qwest's Amendment
1348 provides no recourse for a CLEC should a Qwest mistake result in the CLEC's customers
1349 being without service. Further, given the power problem would be localized to BDFBs or
1350 power cables dedicated specifically to the CLEC (as opposed to the DC power plant
1351 shared by the entire central office), the service-affecting problems would only be
1352 experienced by the customers of that particular CLEC – not by Qwest's customers or the
1353 customers of other carriers.

1354
1355 Q. DID QWEST'S AFFILIATE EXPRESS SIMILAR CONCERNS RELATED TO A
1356 "RE-FUSING" PROPOSAL OF AT&T/SBC ILLINOIS?

1357 A. Yes. In the same Illinois case mentioned above, AT&T/SBC Illinois apparently modified
1358 a fusing proposal such that instead of fusing at 125% of the ordered amount, it would
1359 fuse at 100% of the ordered amount provided that the fuse size is not more than 200%
1360 greater than the CLEC's actual usage. Qwest witness Hunnicutt-Bishara's testimony
1361 explained Qwest's concerns related to AT&T/SBC's fusing proposal as follows:

1362 Q. WHAT ARE YOUR CONCERNS WITH SBC'S MOST RECENT
1363 FUSING PROPOSAL?

1364
1365
1366
1367
1368
1369
1370
1371
1372
1373
1374
1375
1376
1377
1378
1379
1380
1381
1382
1383
1384
1385
1386
1387
1388
1389
1390
1391
1392
1393
1394
1395
1396
1397
1398

A. I have three major concerns, among others, with SBC's most recent fusing proposal. These concerns are legal, financial and operational. First, if the DC power arrangements are fused based upon the usage at any point in time, and not the List 2 drain of the load, it is probable that the fusing would not be in compliance with NFPA 70-2005, Article 215.3. As a result, the fusing would violate Administrative Code Part 785.20(b)(1), which obligates companies to abide by NFPA 70. In other words, collocators will be forced to either ignore SBC's fusing limitations or ignore the Commission's electrical and fire safety requirements.

Second, on a financial level, changes in a collocator's power draw (for instance, because it adds cards to an existing, but under-utilized, multiplexer) will require the collocator to pay SBC to re-fuse the collocator's collocation power arrangement. For each power delivery arrangement (a single collocation arrangement may include multiple power delivery arrangements), SBC would charge the collocator an Order Charge of \$300.50 (physical caged and shared) or \$115.26 (cageless and virtual) and a Power Delivery charge of \$1,802.03. Regular or periodic re-fusing – which is unnecessary from a safety perspective and, in fact, inconsistent with national fire protection standards and the Commission's rules – will obviously prove quite expensive for collocators.

Third, on an operational level, the low fusing amperage will make unnecessary and harmful overloads more likely and more common. An overload is an overcurrent that is confined to normal current paths and could occur when a single high amperage device is on a circuit that is marginally sized for the demand. The purpose of overcurrent protection devices is to prevent conductor insulation failure caused by overloads or short circuits. An overload condition would be the result of a marginally fused power feed during a power outage.

Q. WHAT ARE THE IMPACTS OF A BLOWN FUSE TO QWEST COMMUNICATIONS CORPORATION (“QCC”)?

1399
1400
1401
1402
1403
1404
1405

A. The impacts of power outages due to a blown fuse are numerous, including but not limited to equipment damage, economic loss due to lost production, and irreparable damage to the reputation of QCC with respect to service reliability.

Q. COULD A BLOWN FUSE REALLY DO DAMAGE TO DIGITAL TELECOMMUNICATIONS EQUIPMENT?

1406
1407

A. Absolutely. Years ago, equipment was not as susceptible to power outages as is the sensitive digital equipment of today. Any equipment

1408 containing microprocessors, such as computers and telecommunications
1409 equipment, is especially vulnerable to power down via a blown fuse.
1410 The May 24, 1999 article in Telephony Magazine Online “CIRCUIT
1411 PROTECTION RUNS DEEP” by Dan O’Shea speaks to this issue
1412 specifically:

1413
1414 “The telecom industry's migration to digital networking
1415 has taken several years but is now nearly worldwide.
1416 The shift to digital networks triggers numerous benefits
1417 that affect network efficiency, performance, capacity and
1418 reliability. However, one side effect of this trend is the
1419 fact that distributed electronics are more sensitive to fuse
1420 outages. Also, the migration to new network
1421 architectures and equipment means that different
1422 network elements are constantly being replaced or
1423 installed, brought on-line or taken off-line. This type of
1424 situation is conducive to fuse overloads and other
1425 potential problems.” (footnotes omitted)
1426

1427 The above excerpt from Qwest’s testimony in Illinois is relevant because it shows that
1428 Qwest’s affiliate possesses the same concerns related to AT&T/SBC Illinois’ re-fusing
1429 proposal (i.e. such proposal is unnecessary, costly, may result in service outages, etc.) as I
1430 have about Qwest Utah’s re-fusing proposal. Indeed, Ms. Hunnicutt-Bishara recognizes
1431 the disproportionate impacts such re-fusing proposals could have on competitors of the
1432 incumbent as follows: “SBC’s own equipment – used to serve *its* own retail customers –
1433 will likely remain unaffected given that SBC fuses based on List 2 drain, according to
1434 SBC’s own technical publication.” (pg. 9).

1435
1436 **Q. WOULD THESE COSTS AND RISKS ASSOCIATED WITH QWEST’S POWER**
1437 **REDUCTION OFFERING OCCUR IF THE COMMISSION ADOPTS**
1438 **MCLEODUSA’S RECOMMENDATION WITH REGARD TO THE DC POWER**
1439 **PLANT CHARGE?**

1440 A. No. McLeodUSA believes it has already addressed this issue by signing the Power
1441 Measurement Amendment. If the Commission requires Qwest to abide by the terms of
1442 that Amendment and apply its DC power plant charge on an “as consumed” basis, the
1443 risks, costs and futility of power reduction activities would be avoided.

1444

1445 **Q. DOES THIS CONCLUDE YOUR TESTIMONY?**

1446 A. Yes, at this time.