

1 **Q. Please state your name and business address.**

2 A. My name is Kenneth T. Houston. My business address is 700 N.E. Multnomah,
3 Suite 550, Portland, Oregon 97232.

4 **Q. For whom do you work?**

5 A. I am Director, Transmission Development for PacifiCorp. In my role, my group
6 is responsible for FERC Open Access Transmission Tariff (OATT) compliance,
7 including responding to customer requests for interconnection to the Company's
8 transmission system. My department also reviews and responds to customer
9 requests for transmission service on the Company's transmission system.

10 **Purpose of Testimony**

11 **Q. What is the purpose of your testimony?**

12 A. I will be responding to a number of questions posed by the Commission staff in
13 their memorandum dated January 19, 2006 in relation to the impact of Qualifying
14 Facilities (QF) on Avoided Transmission Capacity Costs and Avoided
15 Transmission Losses. Additionally, my testimony addresses and supports the
16 Company's position paper provided to the Commission sponsored Transmission
17 Workgroup in November 2005. Mr. Griswold will address the methodology for
18 calculating the cost or savings for line loss adjustments to avoided costs in his
19 direct testimony.

20 **Responses to questions by Commission staff**

21 **Q. What is a typical period of analysis in an interconnection study?**

22 A. The OATT defines the standard procedure and process for reviewing and
23 responding to a Large Interconnection Agreement (LGIA) or a Small Generation

24 Interconnection (SGIA) hereby referred to as the “interconnection request”. A
25 Transmission System Impact Study (SIS) is conducted for every interconnection
26 request received by the Company whether the interconnection request qualifies
27 under the OATT or as a QF. The SIS analyzes the proposed interconnection
28 request’s impact on the transmission system with the configuration and conditions
29 existing at the time of the interconnection request application. The study and
30 resulting requirements are valid only for that point in time. FERC requires each
31 interconnection request to be studied sequentially, including requests from
32 PacifiCorp’s merchant function, regardless of whether the generator is a
33 wholesale generator or a QF, based upon request date with requirements assigned
34 accordingly. The Company includes planned system modifications to the
35 transmission system with in-service dates prior to the proposed interconnection
36 date. Planned modifications to meet load growth and reliability standards are
37 taken into account during the SIS.

38 **Q. Why is 10 years of data requested of an applicant for the integration impact**
39 **study but only 5 years proposed for analyzing transmission avoided costs?**

40 A. Network Customers of PacifiCorp Transmission are obligated to provide ten (10)
41 years of load and resource (L&R) data on an annual basis. The L&R data is
42 required to ensure the Company has sufficient transmission capability to reliably
43 serve future loads, over the ten year horizon, for all network customers using the
44 Company’s system.

45 Similarly, the Company’s Integrated Resource Plan (IRP) utilizes a 20-year
46 planning horizon and identifies future generation and transmission additions over

47 the first 10 years of that planning horizon. It is well understood that some types
48 of resources require long planning lead times to site, permit, and construct.
49 Without developing a resource portfolio over a ten year planning horizon, certain
50 resources may not be considered as part of the Company's IRP. This type of
51 transmission and resource planning described above is done at a relatively high
52 level to help inform the Company about the need and timing of taking specific
53 action to add new generating or transmission facilities to the system.

54 The Company has proposed a five (5) year transmission planning horizon to
55 determine the avoided transmission costs and losses associated with new QFs for
56 the following reasons. First, the transmission network is a highly complex system
57 and will dynamically change over the course of a few years depending on several
58 factors. These factors include variation of loads that are added and removed from
59 the network systems, generation sources that are added and removed, reliability
60 requirements may change, and third party usage of the network may also change.
61 As the network changes, so does the impact a QF might have on the system. The
62 Company proposed a five year horizon due to these uncertainties on the planning
63 horizon and to insure reliability is not negatively impacted within the existing
64 system.

65 **Q. What is the difference between the integration system impact study (referred**
66 **to in item 4 of the Company's proposed process) and the interconnection**
67 **system impact study (referred to in item 5 of the Company's proposed**
68 **process)?**

69 A. Item 4 of the Company's proposal defines the difference between an

70 interconnection request to interconnect the generator to the system and a request
71 to integrate the generator from the point of interconnection into the system to
72 serve network load. As previously stated, an Interconnection Study defines the
73 requirements to reliably interconnect a new generator to the Company's system
74 whether it is a QF or not. An "integration study" defines the impacts of the
75 proposed resource on the operation of the transmission system and any
76 requirements necessary to meet load or a Transmission Customer's request to
77 move energy from a point of receipt to a point of delivery. When PacifiCorp's
78 merchant function, requests the integration of a QF as a Network Resource,
79 PacifiCorp's transmission function will conduct a study to identify both the
80 requirements and upgrades necessary on the system to reliably integrate, and
81 deliver the generator output to the network load.

82 **Q. There is also mention in the Company's FERC Open Access Transmission**
83 **Tariff (OATT) of the Transmission System Impact Study. How does this**
84 **study differ from the other two studies and what is its study time horizon.**

85 A. The Transmission System Impact Study or "SIS" is the same as the study relating
86 to integration referred to in the previous question. The two terms are used
87 interchangeably at the wholesale level. A SIS assesses the requirements necessary
88 to reserve transmission capacity on the Company's system for delivery of energy
89 to load.

90 **Q. In its FERC OATT, does the Company limit interconnection to 138 kV lines?**

91 A. No. Studies seek to identify the most effective interconnection voltage with
92 consideration given to other system factors. The cost of the interconnection with

93 consideration given to overall impacts and the anticipated overall reliability level
94 are two major factors considered.

95 **Q. PacifiCorp proposes that savings be based on the net transmission benefits or**
96 **costs that the QF provides to PacifiCorp when integrated as a Network**
97 **Resource into the system. Please describe the standard methodology and the**
98 **standardized set of system models that are used for the studies that**
99 **determine these costs and benefits.**

100 A. Transmission Network Resource studies use base cases prepared by the Western
101 Electricity Coordinating Council (WECC) as the standardized set of system
102 models. Changes are made to the model to add more detail to the sub-transmission
103 representation (46 to 138kV) and to adjust load distribution. Power flow studies,
104 using the Power Technologies Inc. (PTI) program, are then conducted to
105 determine the system impact of adding the facility in question.

106 **Q. Please explain the topology of the transmission system as it is represented in**
107 **the Company's interconnection or integration models described in the**
108 **previous question.**

109 A. The WECC base cases used in these studies represent the generating plants, load
110 distributions, and facilities for all utilities in the western U.S. and Canada. These
111 cases are prepared for various years, seasons and loading conditions. Not all
112 utilities represent the sub-transmission facilities in detail. The Company adds in
113 the necessary detailed representation for the cases that are used for the
114 interconnection and integration studies.

115 **Q. Please explain the difference between PacifiCorp’s 5-year detailed**
116 **transmission plan and its IRP transmission plan. Does PacifiCorp have other**
117 **“transmission plans”?**

118 A. The 5-year detailed transmission plans show additions that are required to serve
119 the projected load requirements. These transmission plans are for facilities of 138
120 kV and below and are detailed enough to determine specific substation equipment
121 and transmission line additions. The five year transmission plan is used to
122 support investment decisions.

123 The IRP, on the other hand, identifies various resource and transmission additions
124 that could be added to meet total system load requirements on a least cost, least
125 risk basis. The transmission costs in the IRP are very “high-level” estimates of
126 main-grid transmission and do not consider facilities below 138 kV. The focus of
127 the IRP is to make economic comparisons of a variety of resource and
128 transmission portfolios over a 10-year horizon. As mentioned above, these studies
129 are used to inform future actions and are not used to make decisions about
130 investing in specific generation or transmission facilities. These “transmission
131 plans” are not detailed plans and may change as each new IRP is developed. The
132 Company does prepare other “transmission plans” which are more accurately
133 represented as studies prepared in response to transmission service requests by
134 third-party transmission entities. The level of detail of these studies varies
135 depending on the type of study (feasibility or facility study).

136 **Q. In the Company’s FERC OATT, it appears that PacifiCorp may “cluster”**
137 **study requests and prorate costs among the cluster. What does this entail**
138 **and to what extent is this done?**

139 A. The FERC interconnection procedures define a cluster study process. The
140 Company does not utilize this process due to the size of PacifiCorp’s system and
141 the scattered nature and timing of the requests previously received and studied in
142 the Company’s interconnection queue. Projects which are not similarly located
143 geographically would not benefit from a cluster analysis. Accordingly, very little
144 attention has been given to defining the associated cluster study process and the
145 process for any allocation of costs.

146 **Avoided Transmission Losses**

147 **Q. When integrated as a Network Resource it appears that the network**
148 **resource must purchase losses per the Company’s OATT network tariff. Is**
149 **this correct?**

150 A. No. Under the OATT, only Transmission Customers pay average system losses
151 by either generating sufficient amounts to account for losses or paying for losses
152 at market rates. As a Network Resource the generator is not a Transmission
153 Customer and therefore is not responsible for losses. Sections 15.7 and 28.5 of
154 the OATT make the Transmission Customer responsible for the losses stated in
155 Schedule 9 of the OATT. Schedule 9 sets out an average transmission system loss
156 factor of 4.48 percent. In the case of Network Service, this loss factor is applied
157 to the metered load and is not responsibility of the Network Resource. The
158 average system losses assessed against network load would be the same whether

159 the Network Resource were a QF or not.

160 **Q. How are losses calculated and costs allocated to Network Resources?**

161 A. Total system average losses were calculated in a 1991 loss study. These rates
162 were validated in the 1996 rate case when the current FERC rates were
163 established. These loss factors are applied to metered load for Network Service
164 and to the amount scheduled to a point of delivery for Point-to-Point Service.

165 **Q. Under what conditions of power delivery are losses charged or not charged
166 or allocated to a network resource?**

167 A. All Transmission Customers must supply or are charged for losses based on load
168 not on generation resources. A Transmission Customer must generate incremental
169 energy in real time to supply losses, or they are assessed for losses as part of
170 energy imbalance and must then pay for the losses at market energy prices.

171 **Q. Are losses charged to a Network Resource for: a) non-firm power; b) the
172 wind proxy contract customer; c) must-run resources; d) fully dispatchable
173 power; e) firm power?**

174 A. All losses are charged to Transmission Customers at the rate set forth in
175 Schedule 9 of the Company's OATT based on load.

176 **Company's Proposal**

177 **Q. The FERC interconnection study procedure does not include the avoided cost
178 studies outlined in the Company's proposal, how can this be reconciled with
179 the requirement and time frame for completing the OATT studies?**

180 A. QF interconnections are not governed by FERC, however the Company has
181 chosen to study them using the FERC interconnection procedure. Using a

182 common procedure eliminates confusion. In many cases customers may not have
183 determined their ultimate status as a QF or some other type of resource until later
184 in the study process. The Company and the customer can choose to add study
185 details and additional time to the standard study upon mutual agreement. This
186 modification would be allowed under the FERC process. In addition, PacifiCorp
187 utilizes the FERC procedure in recognition of the fact that a QF can switch
188 between QF status and exempt wholesale generator status. The ultimate goal of
189 the process is to provide customers with timely and accurate information so
190 project decisions can progress.

191 **Q. Why does the Company propose to use the OATT interconnection process**
192 **for the Avoided Cost study?**

193 A. Each interconnection request currently requires both an interconnection and
194 integration study to be conducted. The intent of the study is to provide the
195 customer with information about the ultimate costs of interconnection at a specific
196 location such that the customer can make a business decision about moving
197 forward. Identification of any additional savings in transmission costs and the
198 resulting payment to the customer is very much related to defining a project's
199 viability.

200 **Q. Is the Company's proposal for QF treatment consistent with how it studies**
201 **any resource addition?**

202 A. Yes, the same reliability criteria will be applied to QF interconnections studies as
203 are applied to other interconnected base load generation.

204

205 **Q. Why should avoided costs be identified on a case by case basis?**

206 A. Each installation is unique and a specific study is necessary to determine whether
207 any transmission costs are actually avoided or if there are incremental costs
208 incurred. While use of a pro-rata calculation or blanket approach may be easier to
209 administer, it is surely inaccurate and would therefore not meet the indifference
210 standard. Furthermore, if the avoided costs were assessed on an IRP based
211 avoided cost methodology rather than being assessed on its own merits, other
212 system users (including energy consumers) could eventually be faced with higher
213 costs.

214 The Company believes QFs will have minimal impact on the need for major
215 transmission investment. The Company plans its transmission system to reliably
216 serve its load. Often that planning results in the need for new transmission lines
217 and acquisition of new transmission rights-of-way. In order to responsibly use the
218 limited amount of transmission rights-of-way that can be obtained, it is the
219 Company's obligation to maximize the capability of these new transmission lines.
220 Unless a QF completely eliminates the need for a new transmission line, the
221 Company would not likely construct a transmission line of lesser capability.
222 Since the QF will be able to cease generating for normal maintenance and during
223 unplanned outages, the Company will need to prudently plan transmission
224 construction assuming that at times individual resources, including a QF may not
225 be able to generate electricity. Without adequate transmission to load areas,
226 during times of such QF outages, the Company may need to curtail load or to
227 place certain loads on automated tripping schemes.

228 The only way to verify the affects of a QF on transmission planning is to
229 specifically analyze each situation on its own merits to determine what effect (if
230 any) a QF as a replacement (or a deferment) of an alternative resource will have
231 on planned transmission resources. It must be noted that the use of a QF in such a
232 situation may be neutral in relationship to the Company's future transmission
233 investments. However, such an analysis may show that the QF either decreases
234 future transmission investments or possibly increases future transmission
235 investments.

236 Lastly, if a pro-rated approach were endorsed, it will cause a QF to be paid in
237 cases where transmission is still required for reliability reasons. In these cases,
238 ratepayers would be required to pay for duplicate or overlapping resources. This
239 would violate the ratepayer neutrality or indifference standard.

240 **Q. How do Company owned resources and the associated transmission network**
241 **support reliable operation of the network?**

242 A. There are numerous reliability functions provided by Company owned generation
243 resources and robust transmission connections are required to maintain reliability.
244 Sole reliance on QF resources without the associated transmission infrastructure
245 would not meet these needs. Conversely most major planned transmission would
246 most likely be required regardless of whether a QF interconnects to the system, or
247 not. The Company's transmission upgrades are required in some instances to
248 bring distant generating resources to load areas but are often driven by load
249 growth and the need to reliably serve this load. Resources locating close to load
250 areas may have an affect on the planned dispatch of the system; however, during

251 times when these resources cannot deliver electricity to the system due to
252 scheduled or forced outages, the Company must still endeavor to reliably serve
253 this load. This can only be done by importing the output of other resources to the
254 various load area over a well planned transmission grid.

255 **Q. How do resources and the transmission system together affect reserve**
256 **requirements?**

257 A. Each second of the day, loads instantaneously change as electricity consumers
258 switch processes on and off. In aggregate, consumers' needs require the
259 Company to match generation output levels with load requirements on an
260 instantaneous (or real-time) basis. This reliability function is known as
261 regulation. The Company must maintain adequate resources directly under
262 automatic generation control to meet the instantaneous changes in loads. Hour to
263 hour load changes of the system also require the Company to maintain adequate
264 responsive resources to meet the daily load curve on the system. The daily shift
265 from minimum loading to peak loading can be significant and Company owned
266 resource or purchased resources with optionality must be maintained to serve
267 daily load curves. Generation reserves must also be maintained to support the
268 potential loss of actual load serving generation in real time. Actual capacity
269 requirements are established by reliability coordinators, however specific
270 generation resources are required to be maintained on line with additional
271 capacity margins available in the event another generator is lost on a forced
272 outage. Transmission capacity margins must be maintained from the reserve
273 resources to the load pockets. The addition of QFs to a load pocket can

274 exacerbate an area's reserve requirements and the associated transmission
275 requirements since QFs would not typically supply a portion of their output as
276 qualified reserves.

277 To summarize, the addition of a QF to the system does not avoid all planned
278 generation resources and transmission investments, particularly those providing
279 reserve capacity and reliability support. Even if it can be shown that the costs of
280 planned generation resources can be avoided, little if any planned main grid
281 transmission developments may be avoided. Once the Company determines that
282 it must build a new transmission line, it has a public obligation to get as much
283 capability as it can from the upgrade and associated right-of-way corridor. A
284 transmission right-of-way is a scarce commodity and when acquired should be
285 used to its maximum capability.

286 **Q. What reliability impacts do generators have on the Transmission System that**
287 **require transmission support?**

288 A. There are certain services that a transmission system needs in order to maintain
289 system stability and security. The default provider of these services is
290 PacifiCorp's merchant function. These include, among others, reactive power,
291 voltage stabilization, regulation, reserves, and black start. These services are
292 provided by the Company's generators as they cannot effectively be provided by a
293 QF due to their smaller size or due to the fact that they may have a requirement to
294 supply process steam to a host that negates the QF's ability to self-supply those
295 services. Furthermore, those services can only be reliably supplied by a robust
296 transmission system the Company's generation through the transmission system.

297 In such cases, transmission costs are not avoided.

298 **Q. Are there any other reliability concerns for using QF resources to serve**
299 **loads?**

300 A. Yes. The Company proposes to study each installation independently where an
301 effective assessment of a specific QF's reliability can be made. For QFs to
302 displace planned transmission, the QF must be reliable and dispatchable. If the
303 QF is not reliable and dispatchable and transmission is not constructed, it is
304 possible that load would need to be shed to maintain system stability during QF
305 outages or reduction in anticipated generating levels. The study and assessment
306 of each QF's reliability levels, ability to support voltage and reactive
307 requirements, and the need for any associated transmission in support of the
308 networks overall reliability is essential.

309 **Q. Why does the PacifiCorp proposal limit the transmission line voltage which**
310 **might qualify for avoided cost payment to 138 kV.**

311 A. As previously described, reliability requirements can be a major factor in
312 determining if major transmission lines are constructed. The addition of a QF to a
313 load pocket is not expected to change the need for a major transmission line. A
314 QF addition has a much higher probability of deferring or avoiding sub-
315 transmission requirements, such as 138 kV and below. The Company's proposal
316 would include a modified system impact study during the interconnection process
317 whereby a system study would determine the transmission requirements with and
318 without the QF to reliably serve the load. Any transmission that can be avoided
319 or deferred would be eligible for an avoided cost payment to the developer. The

320 Company does not believe a QF smaller than 100 MW would have any impact on
321 the need for a major transmission line in excess of 138 kV and has proposed
322 higher voltages to be excluded from any study. High-voltage transmission
323 improvements provide capacity increases in large blocks. The QF generating
324 additions are generally small and do not match the transmission improvements.
325 Sub-transmission and distribution facility additions, on the other hand, will match
326 up better with the smaller generation additions. Because of the interconnected
327 nature of the network and the high capacity of the main grid facilities, the high-
328 voltage transmission lines are not greatly impacted by the addition or loss of
329 smaller generating plants even if they are located near the load center. This
330 impact is much greater on the local sub-transmission and distribution. The
331 planning of high-voltage transmission additions has a greater degree of
332 uncertainty than local facilities. Local sub-transmission and distribution facility
333 additions are driven by known load additions for the most part and very likely to
334 occur. QF generators that are added to the sub-transmission system (<138 kV) are
335 much more likely to significantly change these planned additions. For example, a
336 20 MW generator would be 40 percent of the loading on a 50 MW circuit serving
337 a particular area. The main grid transmission network serving the load center is
338 only slightly affected by these small generators. To illustrate, a 20 MW generator
339 on a main-grid transmission system with a capacity of 4000 MW is only 0.5
340 percent of the loading. High-voltage facilities, on the other hand, are driven by
341 large resource additions of up to 500 MW which are fairly uncertain. A change in
342 location of these large resources can completely change the transmission plan.

343 The addition of small QF generators would have very little impact on the scope or
344 timing of these high-voltage transmission plans.

345 **Q. Does PacifiCorp's proposal apply to distribution interconnection QFs?**

346 A. Yes. The interconnection of a QF to PacifiCorp's distribution system is generally
347 limited to smaller QF projects, most of which are less than 5MW nameplate. If a
348 QF in Utah (of 3 MW or greater) has requested to be interconnected at
349 distribution level and the interconnection study supports interconnection at the
350 distribution level, then PacifiCorp would offer similar studies relating to the
351 distribution system to identify any avoided costs or cost savings associated with a
352 QF interconnecting into the distribution system. Those QF projects less than
353 3 MW nameplate receive standard avoided cost prices and contract terms per
354 Schedule 37 and are not eligible for price adjustments related to transmission
355 savings or costs. However, regardless of the QF, MW capacity and
356 interconnection voltage, they still must comply with the Company's
357 interconnection process.

358 **Q. Does this conclude your testimony?**

359 A. Yes, it does.