

BEFORE THE PUBLIC SERVICE COMMISSION OF UTAH

In the Matter of the Application)
of PacifiCorp for Approval)
of an IRP Based Avoided Cost) Docket No. 03-035-14
Methodology for QF Projects)
Larger than 1 MW)
)

**RECONSIDERATION REBUTTAL TESTIMONY OF KENNETH T.
HOUSTON**

February 17, 2006

1 **Q. Please state your name and business address.**

2 A. My name is Kenneth T. Houston. My business address is 700 N.E. Multnomah,
3 Suite 550, Portland, Oregon 97232.

4 **Q. Have you previously filed testimony in this matter?**

5 A. Yes. I filed reconsideration direct testimony on behalf of PacifiCorp on
6 February 10, 2006.

7 **Q. What is the purpose of your testimony?**

8 A. The purpose of this rebuttal testimony is to respond to direct testimony filed on
9 February 10, 2006 by Richard Collins on behalf of Wasatch Wind LLC, Gregory
10 Probst for West Consulting LLC and Andrea Coon for the Division of Public
11 Utilities. I will respond to assertions and arguments made in relation to avoided
12 transmission costs and Bruce Griswold will address issues relating to avoided
13 transmission losses and the RFP.

14 **Q. Mr. Collins asserts that he has reservations about using the SIS model to**
15 **determine the amount of any avoided cost because the model has not been**
16 **reviewed by an objective third party. Are his concerns well founded?**

17 A. No. The model used is the base case power flow model developed and provided
18 by the Western Electricity Coordinating Council (WECC). The model is
19 developed jointly by all utilities in the WECC and is used by these same utilities
20 for planning and system impact studies. PacifiCorp may be required to add some

21 changes to the model to include any lower voltage systems (46 kV, 69 kV, 115
22 kV, and 138 kV) not included in the overall WECC models. PacifiCorp planning
23 engineers use these models and standard load flow software to conduct
24 contingency and stability studies which define interconnection requirements.
25 Assumptions on unit dispatch may be required to accommodate new generation
26 sources. This model is used to assess all interconnection applications whether QF
27 or under the OATT. Studies are done according to standard industry practice and
28 should be reproducible by the interconnecting customers. In fact, in two recent
29 cases the generation developer has requested to validate PacifiCorp's system
30 impact study results for their projects. PacifiCorp has shared the study model and
31 assumptions used with the generation developers consulting engineer, subject to
32 certain confidentiality provisions.

33 **Q. Ms. Coon suggests the PacifiCorp proposal should be expanded to include**
34 **the transmission network above 138 kV. Please review PacifiCorp's position**
35 **on this issue ?**

36 A. The PacifiCorp proposal limits the avoided cost portion of the system impact
37 study to the 138 kV system and below. For a multitude of reliability and other
38 reasons as stated in my previous reconsideration direct testimony, PacifiCorp does
39 not believe a 100 MW or smaller QF will have any measurable impact to defer or
40 avoid any facilities on the high voltage transmission network. The PacifiCorp
41 proposal was made in an attempt to review the portion of the network where
42 savings would most likely occur while keeping the study scope within reasonable
43 durations and costs.

44 However, the system impact study could be expanded for a QF developer and
45 include the higher voltage network studies, however this would require additional
46 time and expense for the developer. Main grid studies above 138 kV often
47 involve neighboring transmission system and require joint planning studies,
48 increasing complexity, costs and time requirements. If the Commission chose to
49 provide developers an option to expand the avoided cost studies to the high
50 voltage system, PacifiCorp's proposed system impact study durations for these
51 studies would need to be expanded from 120 days to 180 days at a minimum.

52 **Q. The only time that a transmission line investment (above 138 kV and above)**
53 **can be avoided is when a QF entirely eliminates the need for it. Do you**
54 **believe that a QF is capable of ever doing so?**

55 A. Due to the size of QFs in this Docket, although possible, it is unlikely that an IRP
56 resource and the associated transmission will be avoided. The considerations that
57 are taken into account in developing the IRP resource are not the same as those
58 that influence the location and construction of a QF. The IRP deals with issues
59 such as meeting the Company's total system load demands and growth, system
60 stability and security and power quality. These factors do not directly influence
61 the development of a QF project. For example, a wood waste generating plant
62 located near a saw-mill for fuel may not be located near a load large enough to
63 absorb the power generated and the Company still has an obligation to serve the
64 load when the resource is off line. Similarly, a wind generating facility may not
65 generate sufficient energy to serve load or, as is more likely, due to the fact that
66 they are usually located in remote areas to take advantage of a reliable wind

67 resource would not be located near a load large enough to absorb the power
68 generated. Also, due to the fact that the wind QF depends on wind as a fuel
69 source, it cannot be dispatched when needed and therefore cannot reliably serve
70 load at all times when required.

71 The Company is not claiming that QFs will never avoid or defer transmission
72 construction, rather, each case needs to be assessed on its own merits.

73 **Q. Mr. Probst concedes that in most circumstances a proposed transmission**
74 **line's scale is not affected by a proposed QF. What factors preclude the**
75 **scaling down of a transmission line given the existence of a QF?**

76 A. When a decision regarding the scale of a proposed transmission line is made and
77 that line is added to the Company's 5-year plan or even in its IRP, the most
78 efficient scale is chosen to match the requirements. However, the decision is made
79 in the context of some physical and commercial constraints.

80 Avoided cost methodologies that are applied to generation do not work for
81 transmission. There are certain characteristics of a transmission line that make it
82 very difficult to scale down in order to allow for avoided capital costs. This can
83 best be explained by example. IRP generation resources are typically of large
84 scale, but can be scaled down in size if QF resources eliminate or defer the full
85 requirement for a Company owned generation resource. However, in the case of
86 transmission, calculation of avoided costs on a pro rata basis is not appropriate for
87 several reasons. First, major transmission lines, unlike generation, are not easily
88 scalable. Voltage level and conductor ampacity, coupled with a proposed line's

89 interaction with the existing systems, determine capacity. Using a very simplified
90 analogy, typical capacity additions for a new line might be 200 MW for a 138 kV
91 line, 400 MW for a 230 kV line, and 600 MW for a 345 kV line. In addition, due
92 to transmission right-of-way limitation, once a decision is made to construct a
93 line, the capacity of the line should not be scaled down with the addition of
94 resources closer to load due to various reliability reasons including the outage and
95 maintenance of the QF. Therefore, the Company should only avoid transmission
96 investments if the new resource completely eliminates the need for a transmission
97 line.

98 Secondly, Transmission lines are constructed for a multitude of reliability reasons
99 and not solely for a new resource addition. Large generator outages, system
100 reserve requirements, load following requirements, reactive energy flow, voltage
101 support, mitigation of unscheduled flows, and many other reliability concerns all
102 factor into a decision to construct a major transmission line. Reliability issues
103 alone make it inappropriate to consider pro rata calculations when calculating
104 avoided cost. The addition of a new QF near a utility's load would not be a major
105 factor to avoid, defer or downsize a planned major transmission line.

106

107 **Q. Mr. Probst asserts that because a QF or RFP project has impacts on the**
108 **transmission system over a long period of time, it is inappropriate to**
109 **compare the QF's impact to the 5-year transmission plan. He argues that the**
110 **impact should be considered over a 10-year horizon as in the IRP. Do you**
111 **agree?**

112 A. No. I made the point in my reconsideration direct testimony that the IRP
113 provides only a rough approximation of the additions and upgrades required in the
114 system over a 10-year horizon. The 5 year transmission plans are more accurate in
115 terms of whether a transmission resource is actually required or not because
116 system requirements become better known as load requirements become clearer
117 and better defined. Transmission additions and upgrades are required for a
118 number of reasons, not just to interconnect a new generation resource.

119 As stated in my reconsideration direct testimony, system security and stabilization
120 can often best be achieved by investing in transmission. Transmission is the only
121 way to serve load in the event of planned and unplanned generation outages.
122 However, all of these factors can only be accurately identified over a 5-year time
123 horizon rather than a 10-year horizon.

124 The transmission system needs to comply with specific reliability standards. A
125 five year horizon provides adequate time to identify needed transmission
126 investment which may have a 4-5 year permitting and construction window. The
127 5- year time frame also provides a reasonable level of certainty about economic
128 conditions, community expansion plans, load growth and other factors that require

129 additional infrastructure. The reliability of the system must be met on an hourly
130 basis. The level of specificity on the data required to evaluate system reliability
131 and the impact on the operations of the system becomes less accurate when the
132 planning horizon extends out more than five years.

133 Should the Commission agree to expand the study period to 10 years, it is
134 reasonably certain that a proportion of the transmission that was identified as
135 potentially avoided from the 5th to the 10th year will be required anyway.
136 Consequently, ratepayers would have to initially pay for the original avoided
137 transmission cost payments made to QFs and they would also have to pay a
138 further amount for the actual transmission additions and upgrades that are
139 eventually required. This would be in violation of the ratepayer indifference
140 standard.

141 **Q. Does this conclude your testimony?**

142 A. Yes it does.