

POLE ATTACHMENT INSPECTION APPLICATION

Request Number 2253790
 Page 15 of 17
 PPL MAP STRING 11304002.0
 PPL POLE NUMBER 107500
 POLE ADDRESS 6600 W 14600 So
 CITY HERRIMAN
 STATE Utah

File No. 020003

Pole Inspector Bell / L... / E
 Inspection Date 10-7-2003
 Requesting Licensee COMCAST

(Circle Analysis Level Below)

Is Attachment Approved as Requested by Level of Analysis?

Pre Inspection Levels	Yes	No	Post Inspection Levels	Yes	No
1 or 1a	<input type="checkbox"/>	<input type="checkbox"/>	4 or 4a	<input type="checkbox"/>	<input type="checkbox"/>
2 or 2a	<input type="checkbox"/>	<input type="checkbox"/>	5 or 5a	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3 or 3a	<input type="checkbox"/>	<input type="checkbox"/>	6 or 6a	<input type="checkbox"/>	<input type="checkbox"/>

(If Attachment needs work to be approved, Post Inspections, or has an NESC Infraction, fill out lower section)

	Yes	No
Can Serviceman Modify Service?	<input type="checkbox"/>	<input type="checkbox"/>
Need to go to Estimator	<input type="checkbox"/>	<input type="checkbox"/>
Is Make Ready Work Required By Licensee?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Is Make Ready Work Required By Another Utility?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Is There a 12" Separation Violation Between Utilities?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Is There a Climbing Space Violation?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Is There a Mid Span Violation?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Does Pole have an NESC Infraction?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Need to Route to Another Utility for corrections (see notes)	<input type="checkbox"/>	<input type="checkbox"/>

Pole Attributes
 Pole Height 40'
 Pole Class _____
 Pole Circumference _____

239
 224

 75

see
 19'9" R.d.

ATTACHMENT HEIGHTS

Licensee Proposed Attachment Ht.	Grounded	Mid Span Clr.	To Pole No#.	Violation
Lowest <u>Secondary</u> or Neutral <u>23'9"</u>	<input checked="" type="checkbox"/> 24'	<u>23'9"</u>	<u>107401</u>	<input type="checkbox"/>
Streetlight Mast _____	<input type="checkbox"/>	_____	<u>20'3"</u>	<input type="checkbox"/>
Streetlight Drip Loop _____	<input type="checkbox"/>	_____	<u>17'</u>	<input type="checkbox"/>
CATV <u>20'2" OK</u>	<input type="checkbox"/>	<u>18'10"</u>	<u>106500</u>	<input checked="" type="checkbox"/>
TELCO <u>22'4" ①</u>	<input type="checkbox"/>	_____	<u>106500</u>	<input type="checkbox"/>
FIBER _____	<input type="checkbox"/>	_____	<u>106500</u>	<input type="checkbox"/>
OTHER #1 _____	<input type="checkbox"/>	_____	<u>106500</u>	<input type="checkbox"/>
OTHER #2 _____	<input type="checkbox"/>	_____	<u>106500</u>	<input type="checkbox"/>

Service Drops

Drop Ht.	Ht. Over Rd.	Violation	Leads	Guy Size	JA
Secondary <u>Neut →</u>	<u>23'9"</u>	<input type="checkbox"/> Primary	_____	_____	<input type="checkbox"/>
CATV _____	<u>18'10"</u>	<input type="checkbox"/> Lowest Secondary	_____	_____	<input type="checkbox"/>
TELCO _____	_____	<input type="checkbox"/> TELCO	_____	_____	<input type="checkbox"/>
FIBER _____	_____	<input type="checkbox"/> FIBER	_____	_____	<input type="checkbox"/>
Other #1 _____	_____	<input type="checkbox"/> Other	_____	_____	<input type="checkbox"/>
Other #2 _____	_____	<input type="checkbox"/>	_____	_____	<input type="checkbox"/>

Does Licensee Need Breaker In Guy? Yes No
 Does Another Utility Need Breaker In Guy? Yes No

NOTES:

① UPTL 2" Riser sec
 ① Telco 40" clearance Violation at Pole