

ROCKY MOUNTAIN POWER

A DIVISION OF PACIFICORP

Customer & Regulatory Liaison
1407 West North Temple
Salt Lake City, Utah 84116

May 21, 2007

Utah Public Service Commission
Heber M. Wells Building
160 East 300 South, Suite 400
Salt Lake City, Utah 84111

Attention: Steven F. Goodwill
Administrative Law Judge

Re: Utah Docket No. 06-035-148
Formal Complaint of Tim Vetere

This letter is provided to update the parties regarding Mr. Vetere's request regarding the "maximum amount" of additional capacity available to him at this time.

On May 16, 2007, Rocky Mountain Power completed its study that determined Mr. Vetere could connect an additional 250 HP load at his site without additional upgrades to the company's system. In order to accommodate this additional load, Mr. Vetere must limit his motor start current to 430 amps at 460 volts to avoid objectionable fluctuations in voltage which may be seen by other area customers. The available capacity is subject to change if other customers in the area increase their individual load prior to Mr. Vetere's decision to move forward with his request. The company cannot "reserve" capacity for Mr. Vetere for any length of time.

The company contacted Mr. Vetere by telephone on May 16, 2007, and provided this information to him directly. Rocky Mountain Power will provide periodic updates regarding voltage recordings as they become available.

Sincerely,

Carole Rockney,
Director Customer & Regulatory Liaison

cc: Ms. Rea Petersen, Division of Public Utilities
Mr. Dennis Miller
Mr. Tim Vetere