

**BEFORE THE PUBLIC SERVICE COMMISSION OF UTAH**

---

In the Matter of the Application of	)	
PacifiCorp for Approval of Power Purchase	)	Docket No. 06-035
Agreement Between PacifiCorp and	)	
Spanish Fork Wind Park 2, LLC	)	
	)	
In the Matter of the Petition of Wasatch	)	
Wind, LLC for Approval of a Contract for	)	Docket No. 06-035
the Sale of Capacity and Energy from	)	
Their Proposed QF Facilities	)	
	)	

---

**TESTIMONY OF MARK G. ADAMS**

January 31, 2007

1 **Q. Please state your name, business address and position with PacifiCorp dba**  
2 **Rocky Mountain Power.**

3 A. My name is Mark G. Adams. My business address is 1407 W. North Temple  
4 Street, Suite 270, Salt Lake City, Utah 84116. I am the Manager of Area  
5 Planning for Rocky Mountain Power, and my department is responsible for  
6 developing all conceptual planning improvements to the transmission and  
7 substation system for Rocky Mountain Power.

8

9 **QUALIFICATIONS**

10 **Q. Please briefly describe your education and business experience.**

11 A. I have a B.S. in Electrical Engineering from the University of Utah. I have been  
12 employed with Rocky Mountain Power and its predecessor companies for about  
13 thirty years doing different kinds of electrical system planning in the distribution,  
14 transmission and area planning groups. During the last twenty years I was  
15 responsible for doing transmission system planning in various areas through Utah,  
16 Wyoming, Idaho, Montana, Washington and Oregon. I currently manage all area  
17 planning work within the Rocky Mountain Power service territory. My group is  
18 responsible for evaluating the capacities and capabilities of the PacifiCorp  
19 electrical system.

20

21

22 **TESTIMONY**

23 **Q. What is the purpose of your testimony?**

24 A. I will be responding to the direct testimony of Mr. Rich Collins and Mr. Michael  
25 Unger. In particular, I will be addressing technical and engineering related issues  
26 as they pertain to the methodology proposed by Mr. Collins.

27

28 **Q. Please describe any power flow studies you performed in conjunction with**  
29 **the docket.**

30 A. In the direct testimony of Mr. Collins on page 4 line 14, he stated “this makes the  
31 calculation conceptually difficult. Even when a method is chosen, the modeling  
32 and data requirements make the process very time consuming and expensive”. In  
33 spite of this, Mr. Collins did ask Rocky Mountain Power to perform multiple  
34 studies, even though Mr. Collins could easily have contracted with a third party or  
35 performed the studies himself. Rocky Mountain Power was not planning on  
36 performing any studies since it did not believe the studies were necessary to  
37 calculate line losses according to the methodology recommended by witness Paul  
38 Clements in his direct testimony in this case. However, in the spirit of  
39 cooperation, Rocky Mountain Power did perform a study which provided a  
40 preliminary look at the proxy wind project and the Spanish Fork Wind Park 2  
41 project in preparation for a technical conference in August 2006. The study  
42 assumed heavy and light 2006 loading levels using a heavily modified WECC  
43 power flow base case and studied the effect of each project being out of service  
44 and in-service. At the technical conference, the company shared the results of the  
45 study to all members of the conference. The study results indicated two  
46 significant conclusions: 1) the losses in both projects were very small and

47           approached the accuracy of the model, and 2) the Spanish Fork Wind Park project  
48           avoided fewer losses than the proxy project.

49

50   **Q.    In your previous response, you mention a “WECC power flow base case.”**

51           **Can you provide a summary of what this is and how it is used?**

52    A.    WECC is an acronym for Western Electricity Coordinating Council. It is a part of  
53           the North American Electric Reliability Corporation. WECC’s mission of  
54           maintaining a reliable electric power system in the Western Interconnection and  
55           assuring open and nondiscriminatory transmission access among members is  
56           accomplished through thousands of hours of labor contributed by WECC’s 159  
57           members. The work of the membership is supported by a staff of 24. One of the  
58           members is PacifiCorp. One of WECC’s tasks is to prepare computer models of  
59           the Western electrical grid from data supplied by the 159 members. This data is  
60           then provided to all of the members for use in various analyses. The “WECC  
61           power flow base case” I mentioned in the previous question is the starting data set  
62           for the power flow analysis performed by the company.

63

64   **Q.    Did you modify the WECC power flow base case? If so, why?**

65    A.    Yes, I did modify the base case. The WECC base cases will primarily only model  
66           the high voltage transmission system (generally greater than 230 kV but  
67           sometimes including 138 kV), as well as the large system generators for all  
68           companies in the western United States. Since both the proxy facility and the  
69           Spanish Fork Wind Park 2 facility are or will be connected to the sub-

70 transmission system, the WECC base cases do not have enough detail to  
71 accurately track line and system losses caused by these small wind projects.  
72 Rocky Mountain Power does model the sub-transmission facilities (between 12.5  
73 kV and 161 kV) to more accurately gather the loss effects, and therefore modifies  
74 the WECC base case model to include the impedance those thousands of miles of  
75 lower voltage lines and transformers would add to the system.

76

77 **Q. Did Mr. Unger modify the WECC base case model for his studies?**

78 A. No. Based on the responses to PacifiCorp's data requests received on January 26,  
79 2007, Mr. Unger did not modify the WECC base case.

80

81 **Q. Can Mr. Unger get accurate data results without modifying the WECC base**  
82 **case for his studies?**

83 A. No. With no sub-transmission representation in the base cases, more than half of  
84 all of the system and line losses in the case would be ignored. The purpose of the  
85 model is to calculate losses from the source to the distribution loads. If the  
86 distribution loads were not included in the model it would be impossible to  
87 calculate those losses.

88

89 **Q. Do you have comments on the first line loss methodology Mr. Collins**  
90 **described on page 6 line 4 of his direct testimony?**

91 A. Yes, I have several comments. First, the method Mr. Collins used can get quite  
92 complex. More importantly, Mr. Collins made some incorrect assumptions that

93 skewed his results. For example, on page 6 line 3, he states that Spanish Fork  
94 Wind Park 2 is only 4.5 miles from the Mapleton load. While he is correct in  
95 regards to distance, the Mapleton load is never large enough to absorb all of the  
96 Spanish Fork Wind Park 2 generation. PacifiCorp's response to Wasatch Wind  
97 data request 1.13 states that during peak periods, the Mapleton load is only 10.1  
98 MVA. The Spanish Fork Wind Park 2 nameplate capacity is 18.9 MW. In order  
99 to complete Mr. Collins' analysis, his calculations should have also assumed that  
100 the either the Orem city load served by the Hale substation, the Santaquin city  
101 load served by the 138 kV Summit Creek substation, or the Goshen (Utah) load  
102 would also be needed to absorb the wind park generation. Hale is located about  
103 17 miles from Spanish fork or about 19 miles from the Spanish Fork Wind Park 2  
104 project. Goshen is located about 19 miles from the project and Summit Creek is  
105 located about 25 line miles from Spanish Fork. Furthermore, during light loading  
106 levels it may require all three locations to absorb the full generation from the  
107 project. In his calculation for the proxy facility, Mr. Collins made a significant  
108 error when he included the 14 mile Wolverine Creek – Goshen 161 kV line in his  
109 calculations. Since this line is customer-owned and on the customer side of the  
110 primary metering point, any losses incurred across this line would be absorbed by  
111 the project owner, not PacifiCorp, and should not be included in the loss  
112 calculations. In addition, Mr. Collins also failed to include the presence of the  
113 Goshen (Idaho) distribution peak load of 20 MVA that is located right at the  
114 Goshen bus (see Wasatch Wind data request 1.10) in his calculations. Had Mr.  
115 Collins performed his analysis with this correct information I have outlined

116 above, the results would have shown the proxy project output has zero miles to  
117 travel to be absorbed while the Spanish Fork Wind Park 2 project output must  
118 travel 15 to 20 miles to be absorbed.

119 **Q. Is there a better line loss methodology that could be used?**

120 A. Yes. As Mr. Clements stated on Page 6 line 100 of his direct testimony, there is a  
121 fairly simple methodology that can be used. This methodology traces the  
122 impedance path from the generator interconnection source back to a major  
123 transmission source. In the case of the proxy generator, the interconnection point  
124 and the transmission source point are both at the Goshen substation, so there is no  
125 line distance to calculate losses. In the Case of Spanish Fork Wind Park, the line  
126 distance between the inter-connection point and the transmission source point is  
127 about 2.2 miles. This method is discussed formally in Mr. Clements' testimony  
128 on pages 6-7.

129

130 **Q. Do you have comments on the line loss methodology Dr. Abdulle described**  
131 **on page 4 line 1 of his direct testimony?**

132 A. Dr. Abdulle included in his calculations the effect of having to absorb the entire  
133 64.5 MW proxy wind project in his calculations. If we were to consider the proxy  
134 plant to be the same size as the Spanish Fork Wind Park 2 project, as Mr. Collins  
135 did in his direct testimony page 9 line 17, Dr Abdulle's calculations would need  
136 to be revised to 0 miles / MW for the proxy project, since there is 20 MVA of  
137 distribution load in the Goshen substation. In the case of doing the calculations  
138 for the Spanish Fork Wind Park 2 project, he assumed the distance correctly from

139 Spanish Fork to Santaquin. However, Santaquin is now a 46 kV switching  
140 station, which no longer has a transformer to serve distribution loads. The  
141 Santaquin load is served by the 138 kV substation at Summit Creek, as I  
142 mentioned above. Dr Abdulle’s revised calculations for the Spanish Fork Wind  
143 Park 2 would be 15.55 miles / MW. I would also submit that during light loading  
144 conditions, the average line distance required to absorb the Spanish Fork Wind  
145 Park 2 generation is closer to an average of 17-20 line miles plus a 46-138 kV  
146 transformation impedance for Hale and a 46-138 kV transformation impedance in  
147 the case of Summit Creek (Santaquin). While not entirely consistent with  
148 PacifiCorp’s proposed methodology described in Mr. Clements’ direct testimony,  
149 Dr. Abdulle’s methodology supports PacifiCorp’s recommendation that no  
150 adjustment be made to the Spanish Fork Wind Park 2 pricing to account for  
151 avoided line losses.

152

153 **Q. On page 9 line 16 Mr. Collins states “this crude method does not measure**  
154 **where the power actually flows or the impacts on the system as a whole and**  
155 **therefore is not recommended for use.” What is your opinion?**

156 A. Mr. Collins is absolutely correct that this method is crude and does not measure  
157 where the power actually flows. Unfortunately, there is no cost effective or  
158 sufficiently accurate method available to meter actual line losses or to project  
159 what line losses will be over the 20 year term of the contract. The available  
160 methodologies must resort to theoretical calculations or computer models with  
161 complex assumptions to reach any conclusions. Since the goal is to predict the



162 future line losses over the life of a project, it is impossible to arrive at an answer  
163 with scientific confidence. We have already discussed two theoretical calculation  
164 methodologies, one by Mr. Clements and one by Dr. Abdulle, and mentioned a  
165 more complex computer model algorithm that in each case have concluded that  
166 the Spanish Fork Wind Park 2 project would avoid fewer line losses than the  
167 proxy project.

168

169 **Q. Mr. Collins discussed the relative merits of using power flow models to**  
170 **calculate line losses for the life of a project in his direct testimony on pages**  
171 **10-13 starting in line 1. What is your opinion?**

172 A. Mr. Collins is correct when he said on page 7 line 12 “Unfortunately, the models  
173 will not give us an unequivocal answer to the issue of line losses. There are a  
174 number of issues that must be resolved”. Dr Abdulle is also correct when he said  
175 on page 2 line 11, “Line loss is a physical reality whenever electric energy flows  
176 in a conductor”. So line losses are a continuous phenomena. Power flow studies  
177 are used to calculate electrical system conditions (including losses) for an instant  
178 in time, based largely on the assumptions made by the user. The studies will  
179 calculate voltage drops, current flows and interpolate system losses. In the case  
180 of using power flow studies to predict line losses for the life of a project, it would  
181 take an infinite series of studies in an attempt to calculate line losses during the  
182 project’s life. Also, it would require significant assumptions regarding load  
183 growth, resource additions, and system upgrades over the term of the QF contract  
184 – in this case 20 years. Gathering the exact system loads and generation

185 requirements and then modeling them in a large series of power flow cases has  
186 been done to track real time situations (such as the East coast blackout of a couple  
187 of years ago.) However, the use of power flow studies to determine avoided line  
188 losses for QFs is expensive and time consuming. To try to predict the future  
189 would introduce a great number of uncertainties to the equation and will introduce  
190 errors. For example, inaccuracies will occur as you calculate the system load and  
191 generation levels (by substation) as they cycle through seconds, minutes, hours,  
192 days and years of the future life of a project, especially as we try to predict the  
193 various wind generation outputs for these projects. In addition, other variables  
194 such as area load growth, economic dispatch, equipment failures, other new  
195 facilities, maintenance etc., will affect the power flow study results if incorrect.

196

197 **Q On page 8 line 18, Mr. Collins describes some of the mechanics that were**  
198 **used to produce the loss studies. Can you comment on the methodology?**

199 **A** Mr. Collins indicated that “we decided to back down 19 MWs of power produced  
200 at Wolverine and inject it into the Spanish Fork substation. We then compared  
201 these line losses with the base case.” Running the studies with this method  
202 introduces a couple of questions. There is no indication that off system devices  
203 were “frozen” to eliminate the possibility of other devices introducing additional  
204 system losses or reduction of system losses to the system. These devices could be  
205 capacitor switching, phase shift transformers changing states, transformer taps  
206 changing, or other events. Any of these devices will change voltage states and  
207 current flows and modify system losses. The key point is these studies should not

208 be trying to capture all system losses in the western United States, as we are only  
209 trying to capture those losses or reduction of losses (identified by that snapshot in  
210 time) that PacifiCorp would incur as a result of the two generation projects. We  
211 have already discussed the fact that the customer owned 14 mile Wolverine Creek  
212 – Goshen 161 kV line will incorrectly introduce additional losses to the power  
213 flow case as performed by Mr. Collins. Since those losses will not be incurred by  
214 PacifiCorp, they would need to be discounted from the results. Again there is no  
215 indication that these loss reductions were made by Mr. Collins. Next, Mr. Collins  
216 indicated that he did his loss comparison work by backing down Wolverine  
217 Creek’s last 19 MW and adding 19 MW to Spanish Fork Wind Park 2. To get an  
218 equivalent comparison should dictate comparing the first 19 MW at the proxy site  
219 with 19 MW at the Wind Park site. Even so, this type of analysis or study would  
220 do no more than determine if the Idaho transmission *system* would have more or  
221 less loss capability than the Utah transmission *system*. It does not measure what  
222 line loss increases or line loss reductions PacifiCorp would have to absorb for  
223 each project. To measure what line loss increases or line loss reductions  
224 PacifiCorp would have to absorb, you would have to assume one project is on and  
225 adjust other discretionary generation units, then compare that result with the other  
226 project. As would be expected, there are limitations to this methodology as well.  
227 A power flow program designates that one of the system generating units be set as  
228 the swing machine to track loads for convenience, but in real life, the company  
229 adjusts generation output by economics. So, knowing with a certainty which  
230 generator would be offset by either project would be impossible to do on a

231 forward looking basis. The answer might indeed change over the course of a day  
232 depending on economic or system conditions. Again, this shows the limitations  
233 of using power flow studies to calculate line losses over the life of a project.

234

235 **Q Mr. Collins introduced power purchases and sales transactions in his**  
236 **testimony on page 9 line 9, as another way to analyze the effects of the wind**  
237 **projects to gather line losses, with generation dropped at COB, Mid**  
238 **Columbia and Four Corners, rather than dropping PacifiCorp generation.**  
239 **Please comment.**

240 A. I have difficulty understanding the advantage of picking arbitrary locations like  
241 COB (a location near the California-Oregon Border), Mid-Columbia (a location in  
242 central Washington) and Four Corners (a location near the corner of Utah,  
243 Arizona, New Mexico and Colorado) to attempt to do loss calculations using  
244 power flow studies. These are locations used to make power sales between  
245 various western electric utilities, but for the most part they are not generation  
246 sites. Mr. Unger in his direct testimony Exhibit 2.1 indicated that he studied  
247 generators at Rocky Reach (Washington), Shasta (California), and Cholla  
248 (Arizona.) Obviously expanding the model did require further assumptions to be  
249 made. Unfortunately, those assumptions have not been outlined. Reviewing his  
250 study results, I note that with eleven cases run using various WECC models, total  
251 system losses ranged from 3700 MW to 5551 MW. In all cases except one, where  
252 the study claimed 25% loss savings, the loss change was less than 1 MW, or from  
253 .02 -.03% of the total – a level that may be towards the accuracy of the model

254 itself. Of the total, four cases showed the losses increased as a result of Spanish  
255 Fork Wind Park 2 and six cases showed the losses decreased. In more than half  
256 of the cases, the loss change was a few hundred kilowatts, which I believe might  
257 be outside the accuracy of the model, especially because they are spread through  
258 out the Western United States. Again, I must stress that the model results were  
259 not adjusted to account for the fact that PacifiCorp does not incur losses over the  
260 project-owned 14 mile line from the proxy project to the Goshen substation  
261 delivery point.

262 **Q. Are power flow studies the preferred method to calculate line losses?**

263 A. No, I would agree with Mr. Collins assessment of the limitations of power flow  
264 studies when he said on page 7 line 14, “To definitely measure line losses, one  
265 would have to run the model for every hour in every year that the resource would  
266 be operating. In this case it would be every hour for twenty years. In addition,  
267 one would want to run different load scenarios to capture the range of possible  
268 future events. Plus, the results are only valid if the assumptions of the base case  
269 prove true in reality. Unfortunately, every run is expensive, thus a definitive  
270 conclusion may cost more than the value of the avoided line losses.” I would  
271 submit that the method that would get the best results for effort produced would  
272 be the “transmission source” method discussed briefly by me on page 5 line 81  
273 and by Mr. Clements in his testimony beginning on Page 6 line 100.

274

275 **Q. Does this conclude your testimony?**

276 A. Yes.