

Richard S. Collins  
Gore School of Business  
Westminster College  
1840 South 1300 East  
Salt Lake City, UT 84105  
Telephone: 801-832-2665  
Facsimile: 801-832-3106  
Email: rcollins@westminstercollege.edu  
Representing Wasatch Wind

---

**BEFORE THE PUBLIC SERVICE COMMISSION OF UTAH**

---

IN THE MATTER OF THE PETITION OF  
WASATCH WIND, LLC FOR APPROVAL  
OF A CONTRACT FOR THE SALE OF  
CAPACITY AND ENERGY FROM THEIR  
PROPOSED QF FACILITIES

DOCKET NO. 06-035-42

IN THE MATTER OF THE APPLICATION  
OF PACIFICORP FOR APPROVAL OF  
POWER PURCHASE AGREEMENT  
BETWEEN PACIFICORP AND SPANISH  
FORK WIND PARK 2, LLC

DOCKET NO. 06-035-76

---

**PREFILED PRELIMINARY DIRECT TESTIMONY OF RICHARD S. COLLINS**

---

—

Wasatch Wind hereby submits the Prefiled Testimony of Richard S. Collins in this docket.

DATED this 12<sup>th</sup> day of January, 2007.

Richard S. Collins

/s/ \_\_\_\_\_  
Richard S. Collins  
Representing Wasatch Wind

## CERTIFICATE OF SERVICE

I hereby certify that a true and correct copy of the foregoing was sent by United States mail, postage prepaid, or by email this 12 day of, January 2007, to the following:

Michael Ginsberg  
Patricia Schmid  
Utah Division of Public Utilities  
Heber M. Wells Bldg, 5th Floor  
160 East 300 South  
Salt Lake City UT 84111  
[mginsberg@utah.gov](mailto:mginsberg@utah.gov)  
pschmid@utah.gov

Reed Warnick  
Paul Proctor  
Committee of Consumer Services  
Heber M. Wells BLDG, 5<sup>th</sup> Floor  
160 East 300 South  
Salt Lake City, UT 84111  
[rwarnick@utah.gov](mailto:rwarnick@utah.gov)  
pproctor@utah.gov

Paul Clements  
PacifiCorp C&T  
201 S Main St. Suite 2300  
SLC, UT 84111  
Paul.clements@pacificorp.com

Christine Watson Mikell  
3658 E Golden Oaks Dr  
Salt Lake City, UT 84121  
[christine@isotruss.com](mailto:christine@isotruss.com)

Dean Brockbank  
PacifiCorp  
201 S Main St. Suite 2300  
Salt Lake City, UT 84111  
dean.brockbank@pacificorp.com

Sarah Wright  
1014 2nd Avenue  
Salt Lake City, UT 84103  
sarah@utahcleanenergy.org

Tracy Livingston  
357 W 910 S  
Heber City, UT 84032  
tracy@wasatchwind.com

**PREFILED TESTIMONY**

**Of**

**RICHARD S. COLLINS**

On behalf of Wasatch Wind

---

IN THE MATTER OF THE PETITION OF WASATCH WIND, LLC FOR APPROVAL OF A  
CONTRACT FOR THE SALE OF CAPACITY AND ENERGY FROM THEIR PROPOSED  
QF FACILITIES

Docket No. 06-035-42

IN THE MATTER OF THE APPLICATION OF PACIFICORP FOR APPROVAL OF POWER  
PURCHASE AGREEMENT  
BETWEEN PACIFICORP AND SPANISH FORK WIND PARK 2, LLC

Docket No. 06-035-76

---

January 12, 2007

1 **Q. Please state your name and occupation.**

2 A. My name is Richard S. Collins. I am an Associate Professor of Economics and  
3 Finance at Westminster College located at 1840 South 1300 East, Salt Lake City,  
4 UT 84108.

5 **Q. On whose behalf are you filing testimony in this Docket?**

6 A. Wasatch Wind, LLC

7 **Q. Have you submitted testimony to this Commission before?**

8 A. Yes. I submitted testimony in Docket 03-035-14, the QF avoided cost docket that  
9 determined a method for calculating avoided costs and its reconsideration hearing  
10 that addressed transmission issues. I also submitted testimony in the QF related  
11 Docket No. 05-035-08 and 05-035-09. In addition, I have filed testimony in  
12 Docket No. 06-035-42 which led to a stipulated Power Purchase Agreement  
13 between Wasatch Wind and Rocky Mountain Power on the Spanish Fork Wind  
14 Park 2.

15 **Q. Do you have experience in utility regulatory matters?**

16 A. Yes. Prior to my position at Westminster College, I worked for the Public Service  
17 Commission of Utah for approximately 13 years.

18 **SUMMARY OF TESTIMONY**

19 **Q: What is the purpose of your testimony in this docket?**

20 A: I briefly explain the difficulties associated with determining avoided transmission  
21 line losses for a small QF. Unfortunately there is no plain and simple way to  
22 determine line losses without using complex methods and models that require

1 simplifying assumptions which inevitably will be disputed by parties. I briefly  
2 review the previous testimony on avoided line losses that has been presented to  
3 the Commission as of this date.

4 I outline different methods for estimating line losses and provide results  
5 of our findings on avoided line losses associated with the Spanish Fork 2 Wind  
6 project. I address the strengths and weaknesses of these methods and present our  
7 conclusions. In addition, I offer a simple method for determining avoided line  
8 losses for small Utah QFs under 20 MWs that will minimize administrative time  
9 and preserve regulatory resources as well as provide appropriate price signals on  
10 where QFs should locate their facilities.

11 **BACKGROUND**

12 **Q: Can you briefly review the previous testimony on avoided line losses and**  
13 **explain why the Commission did not provide a decision on this issue.**

14 **A:** I will try. On February 24, 2006, the Commission heard testimony on avoided  
15 transmission line losses in its reconsideration hearing in Docket No. 05-035-14.  
16 The Commission found that the evidence on the record was insufficient to  
17 determine a generic method for determining avoided line losses and deferred  
18 judgment on the issue. In that proceeding, the Commission heard testimony from  
19 the Company and Wasatch Wind that the determination of line losses on an  
20 individual case by case basis is extremely difficult and burdensome, a simplified  
21 method is preferred. (See Testimony of Bruce Griswold and Richard Collins)

22 The Company recommended a method that uses PacifiCorp's FERC

1 OATT calculation of average line losses to determine the adjustment for QF line  
2 losses. The Company recommended eligibility for line losses be determined by  
3 comparing the QFs distance to the Utah Load to the proxy plants distance to the  
4 Utah Load. If the QF is located closer than the proxy resource to the Utah load  
5 then the QF receives line loss compensation based on the Company's FERC  
6 OATT tariff rate. If the QF delivers at the transmission level it receives the  
7 OATT transmission rate and the OATT distribution tariff rate if it delivers at the  
8 distribution level. The Company further recommended that only firm thermal  
9 resources be eligible for line losses, a recommendation that the Commission  
10 rejected. The Commission found that all QFs are eligible for line losses. The  
11 Division recommended a similar method based on the differential distance  
12 between the QF and load and the proxy resource and load. However, the  
13 Commission found that distance criteria as proposed were inexact; it questioned  
14 whether such methods would insure ratepayer neutrality.

15 **Q: Did Wasatch Wind encounter any difficulties in securing expert witnesses in**  
16 **this case?**

17 **A:** As described in our petition for delay of proceedings, we found that highly  
18 qualified local engineering consulting firms who were very acquainted with the  
19 Rocky Mountain's transmission system could not represent us because of conflict  
20 of interest clauses or fear of jeopardizing their business relationship with Rocky  
21 Mountain Power. We had a difficult time finding expertise that was acquainted  
22 with Utah's transmission system. We stress that we are not accusing Rocky

1 Mountain Power of any mal-intent or wrongdoing, but we feel that it is important  
2 for the Commission to be aware of this fact and that other QFs may well  
3 experience the same situation.

4 **Q: Were you able to secure some expert consultants for this proceeding?**

5 **A:** Yes, we were able to sub-contract with Michael Unger of Elcon Associates to  
6 direct the running of some of the power flow models and compile results. Mr.  
7 Unger will submit written direct testimony in this proceeding that shows our  
8 modeling results. We will have him available by telephone at the hearing.

9 **Q: What has Wasatch Wind discovered in its attempt to analyze line losses for**  
10 **its project?**

11 **A:** Our discussions with a number of consulting firms have led us to conclude that an  
12 industry standard for calculating line losses does not exist. This is particularly  
13 true when the issue is placed within the context of PURPA which requires  
14 comparing a QF facility to the utility's avoided resource. This makes the  
15 calculation conceptually difficult. Even when a method is chosen, the modeling  
16 and data requirements make the process very time consuming and expensive. The  
17 time and effort to engage in these studies appears to be cost prohibitive  
18 particularly for a small QF under 20 MWs.

19 **Q: Did you request that the Company run certain power flow studies?**

20 **A:** Yes, we did. In Data Request 5.2, 5.3 and 5.4 we requested that the Company  
21 make a series of runs that could provide information to calculate the lines losses  
22 associated with Spanish Fork project. We requested that they perform a summer

1 and winter scenario with and without the Spanish Fork wind project and with and  
2 without the Wolverine wind project. However, the Company answered the data  
3 requests with the following. “PacifiCorp has not performed the requested study  
4 and therefore has none of the requested results.” In addition, we requested the  
5 results of any power flow studies that they perform in the future on these two  
6 facilities, to date we have not received any response.

7 **Q: Why did you ask the Company to perform these studies rather than perform**  
8 **them yourself?**

9 **A:** That is a legitimate question; first Wasatch Wind does not own a power flow  
10 model. To gain access to one requires paying consultants to run the model, this is  
11 expensive. In addition, there are several different WECC base cases that can be  
12 used and they span a number of years. It is our understanding from the technical  
13 conference on line losses with PacifiCorp that it either owns a power flow model  
14 or has access to one. We felt that having one set of power flow runs performed by  
15 the Company with input from both parties on the assumptions and base models  
16 would avoid controversy about such issues. These issues and attendant expenses  
17 are precisely the reason why FERC has avoided case by case calculation of  
18 transmission line losses and uses a simplified generic method based on average  
19 system losses.

20

21

22



1 **LINE LOSS METHODS AND RESULTS**

2 **Q: What methods did you investigate to estimate the line losses associated with**  
3 **the Spanish Fork project?**

4 **A:** We looked at a number of methods to try to estimate line losses. First, we tried to  
5 determine the path and the distance from the point of interconnection of the wind  
6 facility to Rocky Mountain's load. This requires tracing the power as it steps up  
7 and steps down to different voltages which in and of itself creates line losses. The  
8 Spanish Fork wind project is 4.5 miles from Mapleton (Rocky Mountain load)  
9 and connects at 46kV level and is not stepped up or down. The Wolverine wind  
10 project, the QF proxy, runs 14 miles to its point of interconnection with the  
11 PacifiCorp system at Goshen and is stepped up to 161kV. According to the  
12 Company's answer to data request 2.1, power travels from Goshen to four  
13 different locations. It travels 4 miles to Spud with a step down to 46kv. From  
14 Spud to travels an additional mile to Shelley. In addition, power flows from  
15 Goshen to Idaho Falls which is 12 miles away and the step down is to 46kV and  
16 power flows to Ammon some 16 miles away with a step down to 69kV. With  
17 this crude comparison of distances and step downs between Spanish Fork and  
18 Wolverine one can conclude that the Spanish Fork facility incurs fewer losses.  
19 However, it should be stated that this crude method does not measure where the  
20 power actually flows or the impacts on the system as a whole and therefore is not  
21 recommended for use.

22

1 **Q: Aren't there power flow models that would provide a better estimate of line**  
2 **losses?**

3 **A:** Yes, there are a number of proprietary computer models designed to simulate the  
4 actual flow of electricity with the electrical system. Generally these programs  
5 rely on input data from a transmission organization such as the Western Electrical  
6 Coordinating Council, WECC. These models can simulate the flow of electricity  
7 with or without a given resource. One can then compare the delivered power with  
8 and without the resource and thus calculate the line losses. This provides a much  
9 more precise and dynamic analysis.

10 **Q: Will the output of these models produce unambiguous results that will lay to**  
11 **rest this perplexing problem of calculating line losses?**

12 **A:** Unfortunately, the models will not give us an unequivocal answer to the issue of  
13 line losses. There are a number of issues that must be resolved. First, the model  
14 results only provide a snapshot of the system at a moment in time. To definitely  
15 measure line losses, one would have to run the model for every hour in every year  
16 that the resource would be operating. In this case it would be every hour for  
17 twenty years. In addition, one would want to run different load scenarios to  
18 capture the range of possible future events. Plus, the results are only valid if the  
19 assumptions of the base case prove true in reality. Unfortunately, every run is  
20 expensive, thus a definitive conclusion may cost more than the value of the  
21 avoided line losses.

22

1                   The second issue concerns the critical assumptions made regarding which  
2                   generator gets backed down when a new resource is placed on the system.

3                   Different assumptions will produce very different results.

4       **Q: Did Wasatch Wind perform any power flow studies to estimate the avoided**  
5       **line losses associated with the Spanish Fork project.**

6       **A:** Yes, under Mike Unger’s direction we ran a number of model runs. The results  
7       are presented in his Exhibit 2.1. A power flow model developed by Power World  
8       was used along with various Western Electric Coordinating Council (“WECC”)  
9       base case models. The WECC has a number of base case models that contain  
10       various assumptions about loads and resources. Base cases have been constructed  
11       for a specific year, season and load condition. For example, we employ a base  
12       case that assumes heavy load conditions in the summer of 2010 and 2006. In  
13       another run we employed a base case for heavy load conditions in the winter of  
14       2006 and 2011. These models provide a snapshot of the conditions on the system  
15       and how changes in resources can affect the system and attendant line losses.

16       **Q: How did your team decide what generators to back down when the Spanish**  
17       **Fork wind project’s output was added to the system?**

18       **A:** In our first model run, we decided to back down 19 MWs of power produced at  
19       Wolverine and inject it into the Spanish Fork substation. We then compared these  
20       line losses with the base case. We found that this led to a reduction in line losses  
21       ranging from 4.68 to 1.79 depending on the year, season and load conditions. We  
22       believe that this provides a direct comparison of resulting line losses associated

1 with power delivered at Wolverine versus power delivered at Spanish Fork.

2 **Q: Were other models runs made that backed down other generators?**

3 **A:** Yes, they were. To get a more realistic view of which generators to back down  
4 we relied on information provided by the Company's GRID model runs in  
5 response to our data request 2.2 and 2.3 We requested a Grid model run with and  
6 without the output from our Spanish Fork wind project and with and without  
7 Wolverine. The GRID output indicates which generators will be backed down.  
8 The results show that either thermal resources, generally located in Utah, i.e.,  
9 Hunter, Huntington, Current Creek, etc. or purchases and sales transactions are  
10 changed to accommodate the additional wind power. The avoided market  
11 transactions generally occurred at one of three locations: COB, Mid Columbia or  
12 Four Corners. To simulate the system we assumed that if a purchase or sale was  
13 made at one of these trading hubs then a generator close to the hub would be  
14 backed down.

15 **Q: What were the results of the model runs and what conclusions do you draw**  
16 **from the results?**

17 **A:** As shown in Exhibit 2.1, when a direct comparison was made of taking 19 MWs  
18 of power from the Wolverine interconnection and injecting it into the Spanish  
19 Fork interconnection, the results show that the PacifiCorp eastern control system  
20 experiences fewer line losses. Based on the five runs made, the average avoided  
21 line loss is 3.2%.

22 To compare the line losses associated with backing down other generation,

1 we ran two separate model runs; one for Spanish Fork with and without the power  
2 from its facility and one for Wolverine with and without its power. We then took  
3 the differences between the two estimated line losses to determine the avoided  
4 line loss for Spanish Fork wind project. This procedure was done twice for each  
5 of the three generators, once for summer and once for winter, for a total of six  
6 model runs. In five out of the six comparisons, Spanish Fork wind project  
7 provided significantly fewer line losses than Wolverine. The highest differential  
8 was over 8% with an average of 3.37% in line loss savings. Only for the winter  
9 of 2010 under heavy load conditions did the model indicate that Wolverine would  
10 lower line losses for the PacifiCorp system compared to our project.

11 **Q: What do you conclude from these model results?**

12 **A:** The results show that Spanish Fork wind project will produce fewer line losses  
13 than Wolverine wind project and therefore its avoided cost rate should be changed  
14 to reflect the added value that our facility provides to the system. We recommend  
15 that an adjustment to rates be made that reflects the average avoided line loss  
16 produced by our study.

17 **Q: You mentioned a simplified alternative that the Commission could adopt to**  
18 **eliminate many of these controversies and minimize the regulatory burden**  
19 **on all parties. Could you explain your alternative?**

20 **A:** Yes, even if model is accepted by parties as a legitimate method to estimate  
21 avoided line losses on a case by case basis, there would still be the issue of which  
22 year, which base case, which load conditions should be used. In addition, all

1 parties involved will expend significant resources performing model runs. This  
2 puts the small developer at a severe disadvantage. The alternative I recommend is  
3 to simplify the process so that resources are preserved and yet ratepayers are  
4 protected and the Commission sends appropriate price signals regarding preferred  
5 location of generating facilities. The simple solution is to grant QFs that are  
6 located within a load bubble, such as the Wasatch load bubble, credit for line  
7 losses at the FERC OATT transmission level.

8 **Q: Do you have any exhibits to present at this time?**

9 **A:** Yes, Exhibit 2.1 presented in Michael Unger's testimony provides the output of  
10 our line loss power flow model runs.

11 **Q: Does this conclude your preliminary direct testimony?**

12 **A:** Yes.