

BEFORE THE PUBLIC SERVICE COMMISSION OF UTAH

In the Matter of the Application of)	Docket No. 07-035-93
Rocky Mountain Power for Authority to)	
Increase Its Retail Electric Service Rate in)	Direct Testimony of
Utah and for Approval of Its Proposed)	Randall J. Falkenberg
Electric Service Schedules and Electric)	On Behalf of the
Service Regulations, Consisting of a)	Utah Committee of
General Rate Increase of Approximately)	Consumer Services
\$161.2 Million Per Year, and for Approval)	
Of a New Large Load Surcharge)	

REDACTED

REDACTED CONFIDENTIAL INFORMATION INDICATED BY *****

April 7, 2008

TABLE OF CONTENTS

I.	INTRODUCTION AND SUMMARY	1
II.	GRID STRUCTURE AND LOGIC ISSUES.....	10
	GRID Overview and Issues	10
III.	CONTRACT MODELING IN GRID	33
	Call Option Contracts	33
	SMUD Contract Modeling.....	39
	Hermiston Losses.....	41
	SMUD Pricing, QF Contracts and Wind Resources	42
	Arbitrage and Trading Profits in GRID	42
IV.	PLANNED OUTAGE SCHEDULE.....	45
V.	GRID HYDRO MODELING	57
VI.	THERMAL DERATION FACTORS	68
	Monthly Outage Rates	73
	Thermal Ramping	76
VII.	CURRENT CREEK AND LAKE SIDE MODELING	79
VII.	GENERATING UNIT REPRESENTATION IN GRID	82
	Station Service Modeling.....	86
IX.	OTHER ISSUES	87
	Wind Integration Expense.....	87
	Reserve Requirements for Non-Own Generators	89
	Transmission Wheeling Expense.....	89
X.	CONCLUSION	91

1
2 **DIRECT TESTIMONY OF RANDALL J. FALKENBERG**
3
4

5 **Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.**

6
7 **A.** Randall J. Falkenberg, PMB 362, 8351 Roswell Road, Atlanta, Georgia 30350.

8 **Q. PLEASE STATE YOUR OCCUPATION, EMPLOYMENT, AND ON**
9 **WHOSE BEHALF YOU ARE TESTIFYING.**

10 **A.** I am a utility regulatory consultant and President of RFI Consulting, Inc. (“RFI”).

11 I am appearing on behalf of the Utah Committee of Consumer Services
12 (“Committee”).

13 **Q. WHAT CONSULTING SERVICES ARE PROVIDED BY RFI?**

14 **A.** RFI provides consulting services related to electric utility system planning, energy
15 cost recovery issues, revenue requirements, cost of service, and rate design.

16 **Q. PLEASE SUMMARIZE YOUR QUALIFICATIONS AND**
17 **APPEARANCES.**

18 **A.** My qualifications and appearances are provided in Exhibit CCS 4.1. I have
19 participated in and filed testimony in numerous cases involving PacifiCorp net
20 power cost issues over the past ten years.

21
22 **I. INTRODUCTION AND SUMMARY**
23

24 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY?**

25 **A.** My testimony addresses PacifiCorp’s Generation and Regulation Initiatives
26 Decision (“GRID”) model study of normalized Net Variable Power Costs
27 (“NVPC”) for the projected test period, January 1 through December 31, 2008. I
28 also incorporate NVPC adjustments proposed by Committee witness Mr. Philip
29 Hayet into the GRID model as well.

30 **Q. PLEASE SUMMARIZE YOUR TESTIMONY.**

31 A. We have identified and quantified approximately 30 adjustments to the
32 Company's GRID study (and overall revenue requirements) summarized in more
33 detail below and on Table 1 shown later in this testimony. Utah Jurisdictional
34 impacts are shown in parenthesis.

35 **Net Variable Power Costs (GRID)**

36

37

38

39

40

1. PacifiCorp's request for \$1050.7 million in (total Company) NVPC is overstated by \$59.5 million. I recommend NVPC of \$991.2 million, resulting in a reduction to Utah allocated NVPC of \$25.0 million.

41

GRID Commitment Logic (Uneconomic Operation)

42

43

44

45

46

47

48

49

50

51

52

53

54

55

56

57

58

59

60

61

62

63

64

65

66

67

68

69

70

2. GRID portrays the PacifiCorp system as being heavily constrained by firm transmission and market capacity limits. Such constraints increase NVPC by preventing the sale of surplus generation and result in generators running inefficiently at minimum loading levels.
3. In actual operation these constraints may not exist because non-firm transmission capacity is often available. However, the Company excludes non-firm transmission from GRID for purposes of establishing normalized power costs. For this reason, GRID modeling results may differ substantially from actual results. The Commission has already ordered the Company to include non-firm transmission for purposes of computing avoided costs. I recommend the Commission require the Company to do the same for the purpose of computing NVPC for its next general rate case.
4. Although GRID is intended to simulate the least cost operation of the PacifiCorp system, it fails to do so. GRID makes unit commitment (start up and shut down) decisions ignoring transmission and market capacity limits. In contrast, the subsequent dispatch of units in the Linear Programming ("LP") module recognizes these constraints. As a result, GRID commits units to make undeliverable sales, increasing NVPC.
5. The Company has tried a variety of ad-hoc remedies to address this problem. These include logic changes, data adjustments, and acceptance of a variety of rate case adjustments. However, the GRID model still manifests the same problem even after the Company's various corrections. Unfortunately, the Company continues to address the symptoms of this problem rather than the cause.

- 71
72
73
74
75
76
77
78
79
80
81
6. I present an interim solution to this problem. My proposed solution is to systematically de-commit resources during periods of uneconomic generation. These adjustments impact the West Valley, Lake Side and Currant Creek units as well as certain call option contracts. The solution I propose is simple, but effective. Items 1-3 (summing to -\$8,519,156 Utah) on Table 1 implement my corrections. Because these adjustments result in additional starts for the combined cycle units I also reflect increase overhaul and start up fuel costs in NVPC. These additional costs are shown as item 4 (+\$3,951,914 Utah) on Table 1.

82 **Long Term Firm (“LTF”) and Short Term Firm (“STF”) Contract Adjustments**

- 83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
7. PacifiCorp includes several uneconomic call option contracts in the GRID study. The Company proposed to remove certain costs of these contracts in the 2007 Oregon case,¹ but has not done so in this proceeding. I recommend the Company’s Oregon proposal be applied after reversing uneconomic generation of these call options. This reduces NVPC by the amount shown as item 5 (-\$1,053,407 Utah) on Table 1.
8. The Company overstates the level of losses resulting from the wheeling of Hermiston generation over the BPA network. This adjustment is presented in Table 1 as item 6 (-\$440,407 Utah).
9. The Company incorrectly models the Sacramento Municipal Utility District (“SMUD”) contract. The Company assumes SMUD will take power at only the highest cost hours of the year ignoring the historical pattern of delivery. Also, the Company overstates SMUD annual energy requirements. Correcting these problems results in the adjustments shown on Table 1 as items 7 (-\$1,091,920 Utah) and 8 (-\$14,239 Utah).
10. Mr. Hayet’s proposes adjustments related to the SMUD contract pricing, the Sunnyside contract, cost savings from non-generation agreements with the Biomass qualified facilities (QF) and the Schwendiman contract delay . These adjustments are also reflected in Table 1 as items 9-12 (summing to -\$2,779,239 Utah).
11. I recommend imputation of STF arbitrage and trading profits, based on historical results for the period 2004-2007.² Table 1 shows the value of this adjustment as item 13(-\$1,508,883 Utah).

¹ 2007 Oregon NVPC update case (Docket UE 191).

² The Oregon Commission also adopted this adjustment in UE 191.

115 **Planned Outage Schedule**

116

117

118

119

120

121

122

123

124

125

126

127

128

129

130

131

132

133

134

135

136

137

138

139

140

141

142

143

144

145

146

147

148

149

150

151

152

153

154

155

12. The planned outage schedule used in GRID is based on arbitrary and unrealistic assumptions. Coal unit outages are scheduled in high cost periods in the winter and early fall in GRID, rather than predominately in lower cost periods in the spring, contrary to actual practice. I propose a lower cost outage schedule that is more consistent with the actual outage patterns. My proposed schedule also better addresses constraints faced by the Company in developing its outage schedule. Item 14 (-\$4,627,055 Utah) on Table 1 quantifies the value of this adjustment

Hydro Modeling

13. The Company uses inconsistent data series, spanning different time periods, to develop the hydro inputs for GRID. This reduces hydro generation available compared to a consistent data set for the most recent forty water years (1964 to 2003) available.

14. The Company's hydro modeling methodology uses three scenarios representing Wet, Median, and Dry hydro conditions. However, the Company greatly overstates the likelihood of the Wet and Dry hydro scenarios. At a minimum, I recommend use of the Company's median hydro scenario only.³ The best solution, however, would be to correct the weights used in the GRID model to more accurately reflect the relative probabilities of the three scenarios. Item 15 (-\$1,461,392 Utah) on Table 1 shows the reduction to NVPC based on use of the proper weights.

15. The Company uses arbitrary and unsupported input parameters to overstate hydro reserve allocations. Reversing this input reduces NVPC by the Company shown on Table 1 as item 16 (-\$489,430 Utah).⁴

Forced Outage Rate Modeling

16. The Company computes outage rates for GRID based on actual outages for the 48 months ended June 30, 2007. However, the Company proposes to model monthly variations in unplanned generator outage rates based on four years of historical data. This approach is contrary to standard industry practice and is unsupported on any statistical or engineering basis. Reversing this data change increases NVPC by the amount shown on Table 1 as item 17 (+\$374,121 Utah).

³ This is an approach recommended by the Company in Docket No. 04-035-42. It would result in a reduction to NVPC of \$664,362 on a Utah basis.

⁴ While I present this issue for the Commission's, I do not currently deduct it from my recommended total NVPC. This will be discussed subsequently in my testimony.

156 **17. Over the past decade, outage rates for PacifiCorp units have substantially**
157 **increased, resulting in much higher power costs. Based on review of Root**
158 **Cause Analysis (“RCA”) reports and data the Company files with NERC,**
159 **I’ve determined that a single plant, Jim Bridger, is responsible for over**
160 **half of the outages reported as being due to employee or contractor**
161 **errors. Outages of this type at Bridger greatly exceed NERC averages. I**
162 **recommend the Commission reduce outages at Bridger to bring them in**
163 **line with NERC averages. Item 18 (-\$525,855 Utah) on Table 1 quantifies**
164 **this adjustment.**

165
166 **18. The Company proposes to include an adjustment for ramping of**
167 **generators after shutdowns. This adjustment is not industry standard**
168 **practice and was recently rejected by the Washington Utilities and**
169 **Transportation Commission. Further, the Company calculation of its**
170 **ramping adjustment is demonstrably wrong and greatly overstates any**
171 **energy that might be lost due to ramping. Item 19 (-\$1,675,929 Utah) on**
172 **Table 1 quantifies the impact of reversing the Company’s ramping**
173 **adjustment.**

174 175 **Currant Creek and Lake Side Modeling**

176
177 **19. The Company has ignored the reserve carrying capability of Currant**
178 **Creek when operating in duct firing mode. Further, GRID allows duct**
179 **firing to operate before the steam generator is running at full load. This**
180 **is an unrealistic and inefficient mode of operation. Addressing this**
181 **problem reduces NVPC by the amount shown as item 20 on Table 1 (-**
182 **\$1,509,336 Utah).⁵**

183
184 **20. The Company has used an incorrect and unsupported formula to**
185 **compute the Currant Creek outage rate. The Company has also**
186 **incorrectly computed the planned outage requirements for Currant**
187 **Creek. Correcting these problems reduces NVPC by the amount shown**
188 **on Table 1 as item 21 (-\$92,565 Utah).**

189 190 **Generating Unit Representation in GRID**

191
192 **21. GRID derates maximum generator capacities to reflect unplanned**
193 **outages. While this is an industry standard technique, the Company**
194 **must also derate unit minimum capacities, and make an adjustment to**
195 **heat rates to properly model the impact of unit outages on generator cost**
196 **and performance. These adjustments result in a reduction to NVPC by**
197 **the amount shown on Table 1 as items 22 (-\$1,517,855 Utah) and 23 (-**
198 **\$455,858 Utah).**

199

⁵ Id.

200 **22. I recommend the Commission remove the station service transaction**
201 **from GRID. This adjustment models station service during outages as a**
202 **zero revenue sale. The Company's approach is contrary to industry**
203 **standard practice and differs from the method already used in GRID to**
204 **model over 99% of station service energy. The industry standard**
205 **technique is to adjust heat rates to reflect station service requirements.**
206 **Making this correction to GRID reduces NVPC by the amount shown on**
207 **Table 1 as item 24 (-\$641,121 Utah).**
208

209 **Other NVPC Adjustments**
210

211 **23. The Company has substantially overstated wind integration costs. The**
212 **Company incorrectly applied a formula from the IRP basing the wind**
213 **integration costs on 2000 MW of installed wind capacity, rather than Test**
214 **Year levels which are far below 1000 MW. Correcting this problem**
215 **results in the adjustment shown as item 25 (-\$711,400 Utah) on Table 1.**
216

217 **24. The Company has included reserve requirements in GRID for certain**
218 **generators in its control area that self supply reserves or provide no**
219 **compensation to the Company. Removing these reserve requirements**
220 **from GRID results in the adjustment shown as item 26 (-\$920,295 Utah)**
221 **on Table 1.**
222

223 **25. I correct transmission wheeling expense pro-forma adjustments related to**
224 **the Goodnoe wind project and the Borah-Brady transmission upgrade.**
225 **Further, transmission expense escalations in GRID have been overstated.**
226 **Finally, the Company has ignored the benefit of transmission imbalance**
227 **charges it collects, which provides a source of below market energy.**
228 **These adjustments are shown as item 28-30 on Table 1 (summing to -**
229 **\$1,312,839 Utah).**

Table 1
Summary of Recommended Adjustments
\$1000

	Total Company	Est. Utah Jurisdiction
		SE 41.700% SG 42.482%
I. GRID (Net Variable Power Cost Issues)		
1 PacifiCorp Request NPC - GND-15	1,050,698,899	
A. GRID Commitment Logic		
1 Uneconomic West Valley Operation	(664,752)	(279,801)
2 Uneconomic Currant Creek Operation	(11,513,988)	(4,846,353)
3 Uneconomic Lakeside Operation	(8,061,112)	(3,393,003)
4 Incremental Start Up Costs CC and LS	9,388,977 *	3,951,914
B. STF and LTF Contract Adjustments		
5 Call Options	(2,502,690)	(1,053,407)
6 Hermiston Loss Adjustment	(1,046,320)	(440,407)
7 SMUD Contract Normalization	(2,594,189)	(1,091,920)
8 SMUD Leap Year Adjustment	(33,829)	(14,239)
9 SMUD Contract Repricing	(2,382,720)	(1,002,911)
10 Biomass Non Gen Agreement	(457,702)	(192,651)
11 Sunnyside Contract	(3,642,330)	(1,533,093)
12 Schwendiman Contract Deferral	(120,176)	(50,583)
13 STF Arbitrage and Trading Profits	(3,584,812)	(1,508,883)
C. Planned Outage Schedule		
14 Planned Outage Schedule	(10,992,980)	(4,627,055)
D. Hydro Modeling		
15 Proper Hydro Weighting	(3,471,982)	(1,461,392)
16 Hyrdo Reserve Input Parameter**	(1,162,790)	(489,430)
E. Outage Rate Modeling		
17 Monthly Outage Rate	888,839	374,121
18 Bridger Error Outages	(1,249,330)	(525,855)
19 Ramping	(3,981,680)	(1,675,929)
F. Currant Creek and Lakeside Modeling		
20 Duct Firing Reserve Capability/Combine CC+DF**	(3,585,888)	(1,509,336)
21 Currant Creek Outage Rates	(219,917)	(92,565)
G. Generating Unit Representation in GRID		
22 Heat Rate Modeling Adjustment	(3,606,126)	(1,517,855)
23 Minimum Loading Deration	(1,083,029)	(455,858)
24 Station Service in Heat Rate Curve	(1,523,178)	(641,121)
H. Other NVPC Adjustments		
25 Wind Integration Charges	(1,690,147)	(711,400)
26 Remove Self Supply Non-Owned Reserve	(2,186,441)	(920,295)
27 Goodnoe Transmission Pro Forma	(1,072,352)	(451,364)
28 Borah Brady Transmission Pro Forma	378,805	159,443
29 Transmission Cost Escalation	(1,543,645)	(649,736)
30 Transmission Imbalance	(881,832)	(371,172)
Subtotal Power Cost Adjustments -	(59,450,639)	(25,023,369)
Allowed - Final GRID Result*	991,248,260	
	5,296,977	2,208,840

* Includes start up fuel in the amount of

** Adjustment not deducted from Final GRID Result

230
231
232
233

234 **Q. PLEASE DESCRIBE YOUR ANALYSIS OF NVPC IN THIS CASE.**

235

236 A. Mr. Hayet and I have performed a comprehensive “model audit” of GRID and the
237 database used in this case. We have participated in every PacifiCorp Utah general
238 rate case since 1998, directing our attention to the reasonableness of the
239 Company’s determination of NVPC using various power cost models. To
240 perform this project, we obtained the current version of the GRID model and
241 associated documentation, and conducted numerous model runs and analyses of
242 the input and output data. We issued approximately 275 data requests, and on
243 February 14 and 15, 2008 conducted on-site interviews with Company personnel
244 from the Net Power Cost group, the Commercial and Trading Department, the
245 Fuels Department, and the Operations Department.

246 **Q. IN GRID, DOES THE SEQUENCE IN WHICH ADJUSTMENTS ARE**
247 **RUN MATERIALLY IMPACT THE RESULTS PRODUCED BY THE**
248 **MODEL?**

249

250 A. No. The final results do not matter on the order of adjustments. However, the
251 sequence in which individual adjustments are run in GRID can result in
252 differences in their impact. This is due to changes in “balancing” of the system.

253 **Q. HAVE YOU INCLUDED THE EFFECT OF BALANCING ON THE**
254 **ADJUSTMENTS YOU PROPOSE?**

255

256 A. For adjustments that can be computed within the model, I have. Certain
257 adjustments, such as the short-term firm arbitrage and trading profits adjustment,
258 are computed external to GRID.⁶ As a result, there should not be any substantial
259 balancing effects remaining. However, it is important for the Commission to

⁶ These include adjustments 4, 5, 13, 15, a small part of 18. These adjustments are computed externally with data outputs from GRID. Adjustments 9 and 28-30 are simply adjustments to fixed cost figures that are reported in GRID, and don’t require a model run to implement.

260 recognize that the level of these adjustments is not only dependent on the order in
261 which they are performed, but also on the adjustments ultimately allowed. As a
262 result, the figures shown on Table 1 are indicative of results that would be
263 obtained in a final GRID run for this case, but to the extent the Commission
264 doesn't accept all of the proposed adjustments, or the order of adjustments is
265 changed, there will likely be changes to individual adjustments.

266

II. GRID STRUCTURE AND LOGIC ISSUES

267

268

269 **Q. WHAT ARE “NET VARIABLE POWER COSTS” AND WHY ARE THEY**
270 **IMPORTANT TO THIS PROCEEDING?**

271 A. Net variable power costs are the variable production costs related to fuel and
272 purchased power expenses and net of sales revenue. The Company estimated
273 these costs for the Calendar Year 2008 test period using the GRID model. NVPC
274 comprise a substantial portion of the overall revenue requirement and therefore
275 are a significant component of PacifiCorp’s proposed base rates.

276

GRID Overview and Issues

277 **Q. WHAT IS THE PURPOSE OF GRID?**

278 A. The purpose of the GRID model is to estimate NVPC by modeling the least cost
279 operation of the PacifiCorp resources, subject to serving load and all applicable
280 constraints. This is clearly stated in the GRID Algorithm Guide:

281 **“GRID (Generation and Regulation Initiative Decision Tools) is a production**
282 **cost model that *dispatches PacifiCorp resources to serve load obligation***
283 ***through the most economic means. Core functions include:***

284

285

286

287

288

289

290

291

292

- **Committing thermal generating units against market price**
- **Shaping hydro generation against net system load**
- **Shaping long-term firm contract energy per contract terms against market price**
- **Calculation and satisfaction of reserve requirement**
- ***Balancing and optimization of the Company’s resources given transmission and market constraints, including market purchases and sales”*** (emphasis added) ¹

293

294

295

The above stated description is typical of the mainstream utility production cost models in use in the industry today. As a matter of course such models assume system operating costs are minimized subject to operational constraints, such as

¹ GRID Algorithm Guide, V6.2, dated December 2007, as supplied by PacifiCorp on the GRID computer, page 4.

296 transmission limitations. Simulation of the “least cost” operation of the system is
297 the paradigm assumed by all industry standard production cost models and is the
298 stated goal of the GRID model.

299 **Q. DOES GRID SIMULATE ALL OF THE RESOURCES AVAILABLE TO**
300 **THE COMPANY?**

301 A. No. Most notably, the Company ignores available non-firm transmission
302 resources. In its response to CCS Data Request 2.10, the Company stated that it
303 did not include non-firm transmission because it is “*not known-and-measurable*
304 *under normalized rate-making.*” Further, in the responses to CCS 2.11 and 2.12,
305 the Company indicated it could not distinguish between the firm and non-firm
306 flows, and instead represents only firm transmission rights in GRID. The
307 Company further stated that it had performed no studies to estimate the amount of
308 non-firm energy that could flow over the transmission links modeled in GRID.

309 **Q. WHAT ARE THE IMPLICATIONS OF EXCLUDING NON-FIRM**
310 **TRANSMISSION?**

311 A. First of all, the transmission flows modeled in GRID will be quite different from
312 those that actually take place and the two are not comparable. (See, again, the
313 response to CCS 2.11). This implies that the distribution of generation among the
314 Company’s resources may be quite different from actual results as well. In effect,
315 the Company is separating the actual operation of the system from its normalized
316 modeling results in GRID. In this, and many other instances, the Company’s
317 approach to GRID actually deviates from the intended purpose of normalization.

318

319 **Q. IS THIS REASONABLE?**

320 A. No. Certainly, it is not known exactly what non-firm transmission will be
321 available to the Company during the Test Year. However, the same is true of
322 nearly any other input in GRID. For example, market availability and the price
323 for non-firm balancing power are not known and measurable either. For that
324 matter, we do not know what customer loads will be, what unplanned generator
325 outages will occur, or what fuel costs will be. Despite this uncertainty, the
326 Company performs power cost studies with GRID using historical data as a guide
327 to prepare inputs and (hopefully) make sound choices about each and every data
328 input. It makes no sense to perform highly detailed projections of the generation
329 system using literally hundreds of thousands of data inputs, yet ignore a vital
330 element of the resources available.

331 Further, excluding non-firm transmission will certainly serve to increase
332 NVPC because, like market purchases, the Company need only avail itself of
333 these resources when they enable cost savings. The lack of non-firm transmission
334 capacity also may result in certain constraints arising in GRID, which may not
335 exist in real-time operations. These issues will be discussed in depth shortly.
336 Failure to model non-firm transmission presents a source of systematic bias in
337 GRID, and limits the usefulness of comparisons of GRID results to historical data.

338 **Q. WHAT IS YOUR RECOMMENDATION TO THE COMMISSION?**

339 A. In a recent avoided cost case, Docket No. 03-035-14, the Commission required
340 the Company to start calculating avoided costs using a 48 month history of non-
341 firm transmission. (Order, Docket No. 03-035-14, page 14.) I recommend the

342 Commission order the same requirement for GRID studies used in the next Utah
343 general rate case.

344 **Q. DOES GRID ACTUALLY ACCOMPLISH ITS GOAL OF SIMULATING**
345 **COST MINIMIZATION GIVEN THE SYSTEM CONFIGURATION IT**
346 **MODELS?**

347 A. No. GRID frequently fails to develop the least cost operation of resources. In
348 fact, there are thousands of hours per year when gas-fired generators are not
349 operating economically within the model. This results in a spillover effect to
350 coal-fired generation. Frequently, the uneconomic operation of gas plants forces
351 lower cost coal units to have their output curtailed. I estimate the model produces
352 additional costs of nearly \$11 million dollars due to this problem alone, or about
353 1% of total NVPC.

354 **Q. DO UTILITIES ALWAYS SUCCEED IN MINIMIZING COST IN REAL**
355 **TIME OPERATION?**

356
357 A. No. There are always instances where forecast errors, unexpected outages or
358 other problems result in suboptimal real time operation. However, the goal is to
359 minimize costs to customers.

360 **Q. DO INDUSTRY STANDARD MODELS ASSUME OPTIMAL**
361 **OPERATION OF RESOURCES AND COST MINIMIZATION DESPITE**
362 **THE FACT THAT IT CAN'T ALWAYS BE ACHIEVED IN PRACTICE?**

363 A. Yes. All of the significant production cost models in use by the industry assume
364 optimal scheduling and dispatch of all resources. There are at least three reasons
365 for this. First, utilities have a fiduciary responsibility to minimize costs for
366 ratepayers. Models assume this responsibility is met.

367 Second, there is no evidence demonstrating that utilities have consistently
368 failed to minimize costs. While cost minimization may not be perfectly achieved,

369 there is nothing to suggest utilities systematically “miss the mark.” In cases
370 where they don’t succeed in cost minimization, forecast errors (factors not
371 considered in GRID) are almost always the cause.

372 Finally, in a modeling context, cost minimization is the only possible
373 objective target. Building logic into models that systematically assumes costs are
374 not minimized is even more problematical and is far too subjective. For example,
375 should we assume in the model that system operation is only 99% or even less
376 successful? Where would one draw the line? It becomes a very slippery slope
377 once one begins to assume that performance of the system operators will be
378 systematically deficient.

379 In cases where it is systematically impossible to optimize the operation of
380 a given resource within the model, the proper approach is to identify the cause
381 (such as a constraint), and insert additional logic to address the problem. Mr.
382 Hayet and I have both worked on such issues at various times over the years.

383 **Q. DO YOU BELIEVE THAT IN ITS REAL TIME OPERATIONS THE**
384 **COMPANY DOES SEEK TO MINIMIZE OPERATING COSTS,**
385 **SUBJECT TO CONSTRAINTS?**

386
387 A. Yes. Mr. Hayet and I interviewed personnel from PacifiCorp’s real time
388 operations staff in Portland on February 15, 2008. We discussed, in depth, the
389 techniques used by the Company to optimize unit commitment and dispatch
390 decisions and did follow up discovery. It was stated that the Company believes
391 instances of incorrect commitment and uneconomic generation, while possible,
392 are rare events. I have no reason to doubt this. Indeed, I expect the Company
393 makes every effort to achieve the least cost operation of the power system, subject

394 to applicable constraints. It was also noted during this meeting that availability of
395 non-firm transmission is a key element in the cost minimization process.

396 **Q. WHAT CONSTRAINTS ARE MOST SIGNIFICANT IN GRID?**

397 A. The most serious constraints are imposed by firm transmission limits and market
398 caps.⁸ These are significant because without the free flow of power across the
399 transmission network or liquid markets for transactions, the Company cannot
400 always sell available excess generation, purchase the least cost energy available,
401 or operate units at their most efficient loading levels. The figure below shows a
402 copy of the current GRID Transmission Topology Map.⁹ This map shows the
403 system is quite complex and all transmission paths have limited capacities.

404 In addition, there are various operating constraints, including unit
405 minimum loading levels, reserve requirements, minimum up and down times for
406 generators, and market liquidity limits (market caps). All of these factors are
407 simulated in GRID, and are interrelated. For example, if the Company has excess
408 generation, but is unable to sell the energy due to transmission constraints, units
409 are required to reduce output. In such instances units may be dispatched in GRID
410 at their minimum loading levels, which is typically their least efficient loading.

411

412


413

⁸ Market caps represent limits on the amount of energy that can be sold in a given market. In GRID market caps are applied during the hours 1-6 am, based on historical data. I have concerns about the development of this data, but did not address that in this case.

⁹ MDR 2.52-1.

414

Figure 1: GRID Transmission Topology Map MDR 2.52-1



415

416 **Q. PLEASE PROVIDE EXAMPLES OF TRANSMISSION LIMITATIONS**
 417 **THAT RESULT IN OPERATIONAL CONSTRAINTS WITHIN GRID IN**
 418 **TERMS OF RUNNING GENERATION RESOURCES?**

419 **A.** GRID simulations reveal that several of the key transmission links are heavily
 420 constrained. As shown in Exhibit CCS 4.2: the Utah South to Four Corners link
 421 is constrained 5478 hours per year; the Cholla 4 to APS link is constrained 4517
 422 hours per year; the Bridger to Idaho link is constrained 2870 hours per year; and
 423 Colstrip to West Main is constrained 6306 hours per year. Further, owing to
 424 market capacity limits assumed in GRID, there are additional constraints that
 425 occur (and are generally binding) every day for five hours, from 1 am until 6 am.

426 The net result of these constraints in GRID is that PacifiCorp generators
427 frequently run at minimum loading levels. For example, Currant Creek is
428 assumed to be operating at its minimum loading (340 MW) more than 4200 hours
429 per year, or more than 60% of the time the unit is running. Lake Side is shown to
430 be operating at minimum more than 2100 hours per year (28% of all operating
431 hours). The Gadsby and West Valley combustion turbines are shown as running
432 at minimum 67% to 91% of the time they are operating. The above examples are
433 provided in Exhibit CCS 4.3.

434 Even coal plants are shown to frequently be operating at minimum
435 loadings in GRID. For example, GRID results show Carbon 1 operating at
436 minimum loading more than 2000 hours per year (24% of total operating hours),
437 Hayden 2 operating at minimum loading for more than 2100 hours (26% of total
438 operating hours) and Naughton 2 operating at minimum loading for more than
439 1600 hours (20% of total operating hours).

440 **Q. ARE THESE GRID RESULTS REALISTIC?**

441 A. No. Exhibit CCS 4.3 also shows that in actual operation, the Company generators
442 run at minimum loadings far less often than is portrayed by the GRID model. It is
443 also quite telling that GRID also shows the Currant Creek and Lake Side duct
444 firing capabilities operating for hundreds of hours, when the steam generators are
445 being dispatched at minimum loadings. All of this suggests a serious problem
446 with the dispatch and commitment logic in GRID.

447 **Q. EXPLAIN HOW YOU COMPUTED THE HOURS OF OPERATION AT**
448 **MINIMUM LOADING IN EXHIBIT CCS 4.3.**

449 A. For the GRID model it is quite simple to compare the hourly dispatch of units to
450 their minimum loading input. In actual operation, it's more complicated because
451 units don't run exactly at the minimum loading over even a single hour, due to
452 varying conditions, ramping and hourly load swings. As a result, I established
453 upper and lower limits, centered on the GRID minimum loading input, and
454 counted how many hours units operated within that range. I looked at both a 10%
455 and 20% range, which provide a very broad window. For example, for Cholla
456 (with an assumed minimum loading of 250 MW in GRID) the 10% range was 225
457 MW to 275 W. Anytime the hourly dispatch fell in that range, it was counted as
458 an hour at minimum loading. The 20% range was even larger (200-300 MW.)
459 Even with these expanded ranges, the actual hours of operation at minimum
460 loading generally fell well below the GRID model results. This clearly indicates
461 the GRID model is portraying far more hours of operation at minimum loadings
462 than actually occurs. This provides indirect evidence of uneconomic operation in
463 GRID. However, there is direct evidence of this problem that is readily available
464 that demonstrates GRID does not "normalize" unit operations as compared to
465 actual experience.

466 **Q. DESCRIBE THE DIRECT EVIDENCE OF UNECONOMIC**
467 **GENERATION IN GRID.**

468 A. As I previously discussed, GRID is supposed to simulate the *least cost* operation
469 of system resources. If it costs less to *not* run a particular unit for a particular
470 period of time, the model should simply not commit it in the first place. This is
471 particularly true of gas-fired units, which have the ability to cycle on a daily basis.
472 To provide a proper modeling, the daily decision to start up a unit (in GRID)

473 should reduce not increase NVPC, unless it is needed for purposes of meeting
474 reserve requirements. Yet, I found that when certain resources are removed from
475 GRID in certain months or at certain times, NVPC actually declined. In GRID
476 units are started up (or left running) that are not needed for reliability purposes,
477 and which are not part of the least cost operation of the PacifiCorp system. This
478 is a clear cut error in the implementation of the model.

479 **Q. PLEASE PROVIDE EXAMPLES OF THIS PROBLEM?**

480 A. The most significant problem concerns the modeling of Currant Creek. While
481 GRID shuts down the Currant Creek plant more than 200 nights of the year, it
482 does leave the plant running the remaining nights. A run that required the Currant
483 Creek plant to shut down every night produces substantially lower NVPC.
484 Further, a run performed without the West Valley CT units produced NVPC
485 lower than the run including those units in April and May 2008. Removal of the
486 NEBO heat rate contract energy from GRID (while retaining the contract demand
487 charges) produced lower NVPC in March 2008. A GRID run removing the
488 Constellation 257687 Call Option Contract (while retaining the contract demand
489 charges) produces equal or lower NVPC every single month from June to
490 September 2008. Finally, removal of the Duct Firing capability of Currant Creek
491 produced lower NVPC in certain months. In all of these cases, GRID would
492 produce lower production costs if the resources were simply not available to run
493 during the time periods discussed. These examples clearly show that a serious
494 problem relating to uneconomic generation exists in GRID.

495 **Q. IS OPERATION OF THESE UNITS REQUIRED FOR MEETING**
496 **RELIABILITY REQUIREMENTS IN GRID?**

497 A. No. In GRID, reliability requirements are modeled by specifying an hourly
498 reserve capacity requirement. GRID computes hourly “Reserve Shortage” if there
499 is not enough capacity on line to meet reserve requirements.

500 The Company assumes that the NEBO and Constellation contracts and
501 duct firing capability of Currant Creek do not provide any spinning reserve
502 capability. Consequently, there is no reliability basis for starting these units. In
503 the case of Currant Creek, it makes little sense to assume the plant needs to run at
504 night for reliability purposes. Further, review of the Reserve Shortage results
505 from the GRID model shows no impact on reserves when these resources are
506 removed. GRID simply uses other (already available) capacity to meet reserve
507 requirements when these units are removed from the model. Therefore, the
508 increased cost cannot be tied to a need to meet reserve requirements.

509 **Q. IS IT POSSIBLE THIS PROBLEM IS RELATED TO OTHER**
510 **OPERATING CONSTRAINTS, SUCH AS MINIMUM UP OR DOWN**
511 **TIMES?**

512 A. No. Again, all of the resources in question can cycle on a daily basis. Review of
513 the GRID hourly dispatch results, shows that all applicable constraints were met.

514 **Q. DO YOU KNOW WHY THIS PROBLEM IS OCCURRING?**

515 A. The problem is occurring because the logic in GRID separates the decision to
516 commit (start up or shut down) a resource from the operating constraints
517 (transmission limits and market capacity limits) imposed in the model. However,
518 these operating constraints are later used to determine the optimal dispatch of

519 resources. The simplest explanation is the model unrealistically assumes energy
520 produced by a generator can always be sold in various markets when making the
521 commitment decision. As a result, units are running when there is no market for
522 the energy they produce.

523 **Q. EXPLAIN THE DIFFERENCE BETWEEN COMMITMENT AND**
524 **DISPATCH IN GRID.**

525 A. Commitment is the determination of which units are (or should be) running in a
526 particular hour. Once the model determines a unit is committed (i.e. running), a
527 unit must run at least at its minimum loading level. Dispatch is the determination
528 of the level at which each of the committed units will actually run. Units
529 generally are most efficient at or near full loading, and least efficient at minimum
530 loading. The Linear Programming (“LP”) module in GRID determines the
531 dispatch of committed resources that minimizes total cost, subject to the
532 constraints imposed. However, that the LP module does not decide which units
533 *should* be running and cannot reverse an incorrect commitment decision made
534 previously by the model.

535 **Q. EXPLAIN HOW GRID SIMULATES THE COMMITMENT AND**
536 **DISPATCH OF UNITS.**

537 A. This is a two-step process. The model first develops a list of “committed” units
538 for each hour. Once that step is completed, the LP module solves for the most
539 efficient dispatch of resources, subject to transmission and other operating
540 constraints (such as minimum loading requirements). Frequently, there are too
541 many units committed during a specific hour and the model produces a dispatch
542 that exceeds the least possible cost. As a result, removing certain units from the

543 entire dispatch and commitment sequence can actually lower NVPC because
544 GRID makes a mistake in deciding which units to start up in the first place.

545 This occurs because the commitment logic is premised on a comparison of
546 market prices to the dispatch cost of individual resources. In effect, the model
547 assumes that if a resource is started up, all of the additional energy produced by
548 the unit can be sold at market prices or will offset Company owned generation
549 costing that much or more.¹⁰ However, transmission constraints and market caps,
550 frequently limit the amount of energy that can be sold in the market, particularly
551 the energy from resources in the Utah North and Utah South transmission areas.¹¹
552 This is the major source of uneconomic generation in the GRID model.

553 **Q. EXPLAIN THE PROBLEMS RELATED TO THE UTAH TRANSMISSION**
554 **AREA RESOURCES.**

555 A. As shown in the topology map above, there is a vital transmission link available
556 between the Utah resources and the Four Corners market hub. In GRID, the
557 Company uses Four Corners as the reference market price for resources in the
558 Utah transmission area.¹² GRID assumes that if a unit is started up, it will either
559 be able to sell its energy in the Four Corners market (or will enable another, lower
560 cost, unit to do so.)

561 **Q. IS THAT A REALISTIC ASSUMPTION?**

¹⁰ GRID Algorithm Guide, V6.2, dated December 2007, as supplied by PacifiCorp on the GRID computer, pages 47-53.

¹¹ While these are modeled as two separate areas in GRID, they have a very large transfer capability, thus constraints between these two areas are not a significant problem.

¹² Some resources, such as the NEBO contract use Mona as the reference price. However, market caps limit the ability to make sales in this area as well.

562 A. No, far too often it is a completely *unrealistic* assumption. As shown on Exhibit
563 CCS 4.2, the Utah South to Four Corners link is constrained 5478 hours per year
564 by transmission limitations. Further, market caps limit the ability to sell into this
565 market 1465 hours per year (during the “graveyard shift” hours). Combined, this
566 means there is no market for incremental sales to Four Corners 6943 hours during
567 the test year, or close to 80% of the time. In effect, GRID starts up units in order
568 to make additional sales, but there is no way to actually deliver that energy to the
569 Four Corners market 5478 hours per year and no market another 1465 hours per
570 year. For example, sales at night to Four Corners are limited by market caps to
571 approximately 55 MW on average. However, the model frequently allows
572 Currant Creek to continue to run at night, under the false assumption that it would
573 be possible to sell output from the plant at market prices. This leads to a
574 substantial and costly mistake in the simulation of Currant Creek operations, that I
575 do not believe actually happens in real-time operations.¹³

576 **Q. CAN YOU ILLUSTRATE THIS PROBLEM USING DATA FROM THE**
577 **GRID MODEL?**

578 A. Yes. The confidential graph below illustrates the problem, using Currant Creek.

579

580

581

582


583

584

¹³ In real –time operation the availability of non-firm transmission capacity may enable sales to other markets, thereby avoiding the need to reduce energy from, or shut down, Currant Creek.

585

CONFIDENTIAL***Figure 2*******



586

*

587

The graph shows the Four Corners market price, and the running cost of the Currant Creek unit as simulated in GRID for December 4, 2008. It further shows that the cost of energy from Currant Creek is quite close to the Four Corners market price every hour during the night time hours, and far below the Four Corners market price the rest of the day. Because start up fuel and O&M costs¹⁴ are considered, and the plant must have a minimum six hour shutdown, GRID decides to keep the unit running at night. As such, GRID *commits* the resource for the entire day.

595

In GRID once the list of committed units is developed for each hour, the LP module develops the least cost dispatch subject to the transmission and market capacity constraints. Based on the final LP solution, the Four Corners market capacity is constrained to the market size limit of 67 MW. Consequently, the maximum sales to the Four Corners market are made without Currant Creek, and

596

597

598

599

¹⁴ These costs amount to approximately \$***** per start.

600 additional generation from Currant Creek does not result in additional sales.
601 Rather, if additional generation is committed (or in this case remains committed),
602 it simply means that generation from other units must be reduced. This means the
603 “avoided cost” of Currant Creek would equal the cost of the units whose capacity
604 has been reduced, not the *much higher cost* of the energy transacted in the Four
605 Corners market. As the chart shows, these avoided costs are much lower
606 indicating that during the five nighttime hours limited by the market cap, the
607 impact of running Currant Creek is to reduce the output of lower cost coal units,
608 not to increase sales to the Four Corners market. As a result, it actually costs
609 much more (in this case, \$48,000 for the day based on my calculations)¹⁵ to run
610 Currant Creek at night, than to shut the plant down.

611 **Q. EXPLAIN HOW THE FIGURES IN THE CHART WERE DERIVED.**

612 A. The figure above computes the hourly avoided cost for Currant Creek by
613 comparing the hourly sum of fuel and purchased power expenses, net of sales
614 revenues in GRID runs with and without the resource. The graph above shows
615 that from 6 am to 11 pm (hours that are not constrained by the market capacity
616 limit) the Currant Creek avoided cost tracks the Four Corners market price, and
617 both exceed the cost of energy from Currant Creek. It obviously makes great
618 sense to run Currant Creek during these daytime hours. However, for “graveyard
619 shift hours”, the Currant Creek avoided cost is far below the value of Four
620 Corners market energy. Consequently, running the plant at night does not

¹⁵ Net of the cost of an additional start up.

621 produce additional sales during these hours, but instead, only serves to reduce the
622 output of lower cost resources, *increasing* total NVPC.

623 **Q. HAS THIS PROBLEM EXISTED IN THE MODEL FOR SOME TIME?**

624 A. I believe so. However, its nature has not been fully understood in the past,
625 perhaps not even by the Company. Further, the problem has recently gotten much
626 worse due to load growth (resulting in increasing constraints on the system) and
627 the addition of various resources on the system, including certain call options,
628 Currant Creek and Lake Side. In fact, the Company has actually exacerbated the
629 constraint problem because of the high minimum loadings assumed in GRID for
630 Currant Creek, NEBO and Lake Side. Because GRID does not consider operating
631 constraints when committing resources, Currant Creek, Lake Side and NEBO
632 resources are operated in an uneconomic manner.

633 **Q. PLEASE DISCUSS SOME OF THE PRIOR INDICATIONS OF THIS**
634 **UNECONOMIC GENERATION PROBLEM.**

635 A. As early as Wyoming Docket No. 20000-ER-03-198, Company witness, Mr.
636 Widmer, acknowledged that combustion turbines were dispatched incorrectly in
637 GRID and agreed in his rebuttal testimony to a \$1 million disallowance to address
638 the problem.¹⁶ Similar issues have been raised in subsequent PacifiCorp cases,
639 though most have been settled with regards to power cost issues.

640 In the most recent Oregon NVPC update case (UE-191), the OPUC
641 adopted \$9.96 million in disallowances directly or indirectly related to addressing

¹⁶ Re PacifiCorp, Wyoming Public Service Commission Docket No. 20000-ER-03-198, Final Order at ¶ 35 a2 (Feb. 28, 2004).

642 the uneconomic generation problem. Exhibit CCS 4.4 shows the November 7,
643 2007 GRID update in the Oregon case referenced above. The final three
644 adjustments listed in this exhibit (Uneconomic CT operation, Call Options and
645 Carbon at 80% CF) are all symptomatic of the problem of uneconomic generation
646 in GRID.

647 **Q. HAS THE COMPANY ACKNOWLEDGED A NEED TO CHANGE THE**
648 **GRID LOGIC IN ITS FILING IN THIS CASE?**

649 A. Yes. In the Company's direct testimony, Mr. Widmer (replaced now by Mr.
650 Duval) testified that a change made in GRID "*enhances the system balancing*
651 *logic to better recognize economic displacement by decommitting eligible thermal*
652 *units. Previously, the Company used a manual workaround.*"¹⁷ In a subsequent
653 telephone conversation in December 2007, Mr. Widmer confirmed the purpose of
654 the logic change was to address the problem of too many units running at
655 minimum loadings because commitment decisions in GRID did not consider
656 operating constraints.

657 **Q. DOES THE NEW LOGIC IN GRID 6.2 SOLVE THE UNECONOMIC**
658 **GENERATION PROBLEM?**

659 A. No. The new logic has done little to address the uneconomic generation problem.
660 Indeed, GRID runs that I just discussed clearly show that the problem remains,
661 even with the Company's latest "fix" invoked.

662 The new logic change does not address the problem of the failure to
663 connect the commitment logic with operating constraints. Rather, it makes yet

¹⁷ Utah PSC Docket No. 07-035-93, Widmer Direct Testimony, page 7. The "manual work around" is related to use of a "commitment fuel tier" to be discussed shortly.

664 another ad-hoc adjustment by de-committing units once a certain (judgmentally
665 determined) level of capacity “displacement” is reached.¹⁸ In this context
666 “displacement” is the amount of capacity committed in excess of the actual
667 requirement.

668 **Q. PLEASE EXPLAIN THE OTHER DATA AND LOGIC CHANGES THE**
669 **COMPANY HAS MADE TO ADDRESS THE UNECONOMIC**
670 **GENERATION PROBLEM.**

671 A. For some time the Company has prevented GRID from running combustion
672 turbines during night time hours. Further, in the recent Wyoming case, the
673 Company made a new ad-hoc adjustment to the commitment fuel cost in GRID in
674 order to “trick” the model into reducing the number of starts of certain gas units.
675 This is the “manual work around” discussed in Mr. Widmer’s (Duval’s) testimony
676 in this case. Finally, the Company uses a “reserve credit” designed to stimulate
677 the start up of certain units to free up lower cost units from providing reserves. I
678 believe this calculation has been changed in recent GRID versions, but fails to
679 solve (and may even exacerbate) the problem of uneconomic generation.

680 **Q. IS THERE A LONG -TERM SOLUTION TO THIS PROBLEM?**

681 A. Yes. The Company needs to change the GRID logic to harmonize the
682 commitment decision process with the operating constraints. This may be rather
683 difficult given the structure of the model. However, I recommend the Commission
684 require the Company do so before it files its next Utah general rate case.
685 Alternatively, if the Company files a GRID study using non-firm transmission

¹⁸ See the response to CCS 6.39.

686 capabilities and this minimizes the impact of the uneconomic generation problem,
687 new logic *may* not be as critical.

688 **Q. HAVE YOU DEVELOPED AN INTERIM SOLUTION FOR THIS CASE?**

689 A. Yes. For purposes of this case, I have developed an interim solution. My solution
690 is illustrated in Exhibit CCS 4.5. Note that I am proposing the application of this
691 methodology to the final GRID model adopted by the Commission, rather than
692 just the specific inputs that I developed using this method. This will require that
693 the Company make all other Commission-approved adjustments to the model, and
694 then implement my proposed methodology in their final GRID runs.

695 **Q. DESCRIBE THE METHODOLOGY YOU PROPOSE.**

696 A. This solution rests on comparison of two GRID runs, with and without a specific
697 resource, or group of resources. In Exhibit CCS 4.5, I show the calculation used
698 for the West Valley units based on several days of operational data. On some
699 days, West Valley is economic for the entire day, whereas in other days it would
700 save money if the unit never ran. For simplicity purposes in this case only, I have
701 decided to limit the analysis of the West Valley units and call option resources to
702 a daily analysis. These are all resources for which the daily modeling technique
703 works well. The Currant Creek and Lake Side are optimized reasonably well by a
704 simple night time shut down screen (the approach the Company already uses for
705 the less efficient gas-fired units.) I will discuss the approach used for the
706 combined cycle units later in my testimony.

707 The proposed solution compares the daily cost of fuel, purchased power,
708 imbalance and transmission energy costs net of sales revenue in the “with” and
709 “without” West Valley cases.¹⁹ To ensure that this provides the correct analysis
710 of the GRID results, I took care to reconcile my annual sum of the daily cost
711 results (based on GRID daily outputs) with the annual results computed “inside”
712 the model provided in the GRID annual output reports (such as GND-1S). In the
713 end, I was able to decompose the annual change in costs into individual daily
714 components. Thus, I was able to ensure that daily cost variations are consistent
715 with the total cost variations produced by the model. I also reviewed the reserve
716 shortage outputs from GRID to ensure that there were no significant reliability
717 impacts resulting from removal of these units.²⁰

718 For each day, I was able to determine the impact on NVPC of including or
719 removing specific resources. As a result, I identified the specific days when the
720 resource (in this case West Valley) should not have been running. In this
721 example, it can be seen that GRID is erroneously committing West Valley on
722 New Years day, and weekends in January. My solution simply removes West
723 Valley from operation on those days. In effect, this amounts to manually de-
724 committing the resource. *This is nothing more than what GRID should be doing*
725 *correctly in the first place.*

726 Because all of the improperly committed resources can cycle daily, there
727 is no reason why they could not be shut down on specific days. As a result of this

¹⁹ These items represent the variable costs modeled in GRID in most circumstances. In cases where call options are modeled, then variable energy costs from those contracts are included as well.

²⁰ The same process was applied on an hourly basis for the combined cycle units.

728 analysis, I was able to identify the specific days when the units should not have
729 been committed by the model.

730 **Q. HOW WAS THE APPROACH DIFFERENT FOR THE COMBINED**
731 **CYCLE PLANTS?**

732 A. For Currant Creek and Lake Side I used an hourly cost analysis, comparing the
733 case with and without the resources. There are many months when GRID does
734 not show Currant Creek operating at night. In the remaining months, however, it
735 was quite apparent that turning the plant off at night would produce lower annual
736 NVPC. As a result, I developed a night time shut down screen (similar to that
737 used by the Company for CT's) for Currant Creek and Lake Side. I did not
738 attempt to optimize the screen on a daily, weekly or monthly basis. Having done
739 so would likely produce a lower total NVPC (because it might be possible to pick
740 up nights when it would be lower in cost to run the combined cycle plants), but
741 would complicate the analysis somewhat. I used the same approach, but ended up
742 with a slightly different screen for Lake Side.

743 **Q. DISCUSS THE RESULTS OF YOUR SCREENING ANALYSIS.**

744 A. Exhibit CCS 4.6 shows the days and hours when the units examined were
745 removed from the GRID dispatch.

746 **Q. WHY IS IT REASONABLE TO SIMPLY "TURN OFF" SPECIFIC UNITS**
747 **AT SPECIFIC TIMES?**

748 A. This is nothing more (or less) than what the GRID model is attempting to do (and
749 should be doing correctly) anyway. GRID is trying to decide which days each
750 unit should be started up, and how long they should run. GRID does not start any

751 of these units every day. However, the model fails to determine the correct days
752 and hours when the various units should be running. This procedure corrects that
753 problem. In the end, I've done nothing more than the Company did with its night
754 time shut down screen for peaking units, which has been applied now for several
755 cases. However, I've applied it much more systematically to other units to
756 produce a more economic dispatch of generation resources.

757 **Q. DID YOUR ANALYSIS ELIMINATE ALL OF THE UNECONOMIC**
758 **GENERATION COSTS IN GRID?**

759 A. No. I did not eliminate all uneconomic generation costs for a number of reasons.
760 First, I did not attempt to develop the most economic screens on a daily basis. To
761 do so would have been much more time consuming. Second, I did not fully
762 examine all of the units that may have been impacted by the problem. For
763 example, I did not apply the methodology to the Gadsby units. My preliminary
764 analysis, however, suggested these resources were not impacted by the problem to
765 the degree that the other units were, particularly after the adjustments to the other
766 units were made. Third, my approach only eliminated periods of uneconomic
767 generation from the model. I did not attempt to determine if GRID was failing to
768 start up units when they were otherwise should have been running, although there
769 is some evidence that such circumstances do exist in the model. Finally, I
770 sometimes departed from the most optimal daily screens to simplify the GRID
771 inputs I developed as a concession to time constraints. I would note that such
772 departures should not be taken as an endorsement of sub-optimal modeling of
773 system resources.

774 **Q. EXPLAIN THE ADJUSTMENTS YOU COMPUTED IN TABLE 1.**

775 A. In Table 1, I present the results of GRID runs performed with these adjustments
776 invoked on a sequential basis. Thus, the table reflects the balancing effects of
777 these adjustments in tandem. Were they applied individually the impact would
778 likely be greater. I also reflect the incremental start up fuel and O&M expenses
779 resulting from daily cycling of the combined cycle units. It is my understanding
780 that the Company already accounts for these costs using historical data in other
781 components of its test year, rather than using GRID outputs. However, because
782 there are more starts for the combined cycle units²¹ than the Company presumed
783 in the test year, I am reflecting them in my results.

784

785 **III. CONTRACT MODELING IN GRID**

786

787

788 **Q. DOES GRID MODEL POWER CONTRACTS?**

789 A. Yes. The Company includes the costs and energy produced by its long-term and
790 short-term contracts in GRID, along with its thermal generation resources, in
791 order to project normalized NVPC. I will discuss issues related to certain of
792 PacifiCorp's long-term contracts as well as short-term contract modeling.

793

794 **Call Option Contracts**

795 **Q. WHAT IS A CALL OPTION CONTRACT?**

796

797 A. These are contracts that allow the Company the right to obtain additional energy
798 on a daily basis when the market price exceeds the contract strike price. There are

²¹ There are also fewer starts for West Valley in my GRID study, though I did not make any adjustment for this because the start up costs for these units are quite small.

799 two basic types of call option contracts used by the Company in this case: Fixed
800 Strike Options (with a fixed strike price) and Power/Gas Spread Options (where
801 the strike price is based on the cost of gas).

802 The Company has included many call option purchases in its GRID study.
803 I have concerns about several of them: Constellation contracts 257677, 257678
804 and 268849; the NEBO Heat Rate Option; and UBS 268848. NEBO is the only
805 Power/Gas Spread option contract. The others are all fixed strike price contracts.

806 The demand charges (\$*** million in the Test Year) of these contracts are
807 reflected in GRID; however, the contracts seldom reduce operating costs by any
808 substantial margin based on the forward curves used in GRID. As a result, once
809 the demand charges are included, these contracts simply add cost to the GRID
810 study. In fact, Constellation 257678 contract *increases* NVPC in GRID even
811 *without* removing the demand charges. Further, in GRID the NEBO and
812 Constellation 257677 contracts increase NVPC (without removing the demand
813 charges) in at least one month. This is, again, symptomatic of the uneconomic
814 generation problem in GRID discussed above.

815 **Q. PLEASE EXPLAIN.**

816

817 A. Confidential Exhibit CCS 4.7 shows results of GRID runs and other information
818 produced by the Company in the GRID database. Four of the contracts
819 (Constellation 257677, 257678 and 268849 as well as NEBO) reflect costs related
820 to uneconomic operation. This means that the contract should not have been
821 dispatched in GRID on certain days. Based on my analysis, the Constellation
822 257678 contract should *never* have been dispatched any day during the test year.

823 Further, the NEBO and Constellation contracts were committed incorrectly about
824 half the time in GRID.

825 **Q. WERE THESE CALL OPTIONS ADDRESSED IN THE RECENT**
826 **OREGON CASE, UE 191?**

827
828 A. Yes. The Company proposed to remove these contracts if they failed to dispatch
829 economically in GRID or during months when the contracts did not dispatch at all
830 in the model. I agreed with that proposal, and it was adopted by the Oregon
831 Commission. It is well worth noting that the same test year, CY 2008, was used
832 in the Oregon case as is being used in this case.

833 **Q. EXPLAIN THE PROCEDURE THE COMPANY PROPOSED IN**
834 **OREGON TO ADDRESS THESE CONTRACTS.**

835
836 A. In Oregon, the Company proposed to remove the contracts from GRID, if the
837 dispatch benefits of the contracts were negative.²² This was determined by
838 performing GRID runs with and without the contract, while retaining contract
839 demand charges in the “without” case. The difference between the two runs is the
840 value of the energy (positive or negative) net of the cost of that energy. If the
841 value was negative, the contract was removed from GRID. The Company also
842 proposed to remove demand charges for contracts during months they did not
843 dispatch in the model.

844 **Q. DO YOU RECOMMEND THE COMPANY’S OREGON PROCEDURE BE**
845 **ADOPTED BY THE COMMISSION IN THIS CASE?**

846 A. I do, but with a minor modification that should ultimately benefit the
847 Company. I believe the best approach is to first eliminate any uneconomic

²² Note that this was a proposal made in testimony by the Company, not as part of a settlement negotiation.

848 generation associated with these contracts from GRID.²³ Then, if a specific
849 contract fails to provide meaningful dispatch benefits during a month, I would
850 remove it from the model. The primary effect of removing the contracts after
851 uneconomic generation is removed is to eliminate the contract demand charges in
852 months when the contract is not dispatched in the model.

853 This was a basic element of the Company proposal in Oregon. Under the
854 Oregon method, however, the Company would not recover operating costs on
855 economic operation days, if they were outweighed by days of uneconomic
856 generation.

857 I believe that my slightly different approach in this case fosters a better
858 outcome for the Company and customers because in some instances a contract
859 may have more days of uneconomic generation than economic operation. In this
860 manner, the Company would recover the contract operating costs, but only for the
861 days when it makes sense to exercise the option.

862 **Q. WHAT ARE THE RESULTS OF THIS PROPOSAL?**

863 A. Exhibit CCS 4.7 shows the development of this adjustment. Constellation 257678
864 is completely removed from GRID because it never dispatches economically in
865 the model and serves only to increase costs. The NEBO heat rate option should
866 be removed for March, 2008 because it doesn't dispatch economically during that
867 month. In the case of Constellation 257677, I propose to remove the contract in

²³ As will be discussed shortly, the Company did agree in the most recent Wyoming case to remove uneconomic generation associated with specific contracts, even though it later reversed its position regarding the overall application of its Oregon proposal in that case.

868 June and September 2008. In June, it should never be dispatched in GRID. In
869 September, it is only economical to exercise the option for three days, producing
870 an inconsequential benefit compared to the monthly contract demand charge.

871 **Q. DOES THE COMPANY AGREE TO USE ITS OREGON PROCEDURE IN**
872 **THIS CASE?**

873 A. No. In response to CCS 6.25, the Company indicated it believed that similar
874 regulatory treatment should not be applied in Utah because the Oregon approach
875 was based on a prior case precedent in that state and that the call options provide
876 reliability benefits to customers.

877 **Q. IS THERE ANY COMPELLING REASON WHY THE OREGON**
878 **PROCEDURE SHOULD NOT BE APPLIED IN THE CURRENT UTAH**
879 **RATE CASE?**

880 A. No. The Company's Oregon proposal provides a reasonable framework to
881 determine the rate treatment of call option contracts. There is no reason it should
882 not be applicable to Utah as well.

883 **Q. IN ITS RESPONSE TO CCS 6.25 THE COMPANY STATED THAT CALL**
884 **OPTIONS PROVIDE RELIABILITY BENEFITS TO CUSTOMERS. IS**
885 **THIS RESPONSE ACCURATE?**

886 A. No. Call options do not provide any reliability benefits to customers because in
887 GRID they are not allowed to carry reserves.

888 **Q. WHY SHOULD CALL OPTION CONTRACTS BE TREATED**
889 **DIFFERENTLY FROM OTHER KINDS OF CONTRACTS?**

890 A. Call option contracts present modeling challenges and policy issues that need to
891 be considered. As shown above, GRID frequently fails to make economic
892 commitment decisions for these resources. Even if that problem can be

893 addressed, a deeper problem is that the contracts are frequently not even expected
894 to provide overall benefits when compared against the Company's official
895 forward price curve. Instead, the Company enters into such contracts on the basis
896 of their option, or extrinsic value, as opposed to their intrinsic (i.e. forward curve
897 economics) value. In short, these contracts are intended to provide price
898 protection for the Company, but in most cases, they fail to produce ratepayer
899 benefits in GRID. Under normalized market price conditions, many call options
900 are not "in the money." Therefore, shareholders rather than customers are the
901 primary beneficiaries of call options; particularly if customers bear the costs of
902 the options, but are precluded from receiving any of the benefits under normalized
903 ratemaking.

904 **Q. DID THE COMPANY AGREE TO ITS OREGON PROCEDURE IN THE**
905 **RECENT WYOMING RATE CASE?**

906 A. The Company did agree to it in an initial data response answer, but later changed
907 position. Eventually, the Company agreed to eliminate the cost of uneconomic
908 generation associated with its call options in GRID.²⁴ Assuming it would at least
909 do the same in this case, I have computed the costs of uneconomic generation in
910 GRID. The results, shown on Exhibit CCS 4.7, support a disallowance of
911 \$922,660 on a total Company basis. This is less than my proposed adjustment of
912 \$3.59 million shown on Table 1 and is far below the \$5.1 million disallowance the
913 Company proposed (and used) in the Oregon case for the same test year.²⁵

²⁴ See WIEC 4.45 and WIEC 4.45 First Supplemental Response in Wyoming PSC Docket No. 20000-ER-278-07. Note in this passage, I am not referring to agreements made as part of the overall settlement in that case, which did not address this issue specifically.

²⁵ See again, Exhibit CCS 4.4.

914

SMUD Contract Modeling

915 **Q. ARE THE CALL OPTION PURCHASES DISCUSSED ABOVE THE**
916 **ONLY CALL OPTIONS MODELED IN GRID?**

917

918 A. No. The Company models a “call option sale” for the Sacramento Municipal
919 Utility District. (“SMUD”) I address the modeling of this contract while Mr.
920 Hayet addresses what pricing should be use for the contract.

921 **Q. EXPLAIN THE MODELING OF CALL OPTION SALES IN GRID.**

922 A. For such sales GRID applies the contract energy to the highest cost hours of the
923 year. Since the contract has an annual load factor of approximately 40%, this
924 means GRID assumes SMUD will call the energy from the contract during the
925 highest cost²⁶ 3504 hours²⁷ in the year. As a result, GRID assumes no energy is
926 requested by SMUD during the low cost months from March to June. Based on
927 historical data, however, this assumption is flawed. In fact, the Company’s
928 assumptions amount to determining the “worst case scenario” when it comes to
929 the SMUD contract.

930 **Q. PLEASE EXPLAIN.**

931 A. The table below shows the actual monthly distribution of SMUD energy for the
932 four-year period (2003-2007) as compared to the GRID result.²⁸ It is quite
933 apparent that SMUD takes energy at substantially different times than predicted
934 by GRID. This is not surprising since SMUD is attempting to optimize the use of
935 the contract for its own purposes rather than using the contract to impose the
936 maximum amount of cost on PacifiCorp (as is assumed in GRID). For whatever

²⁶ Based on COB market prices.

²⁷ 8760*.4 = 3504.

²⁸ Source: CCS 13.8.

937 reasons, SMUD is not using the contract in the “maximum cost” manner assumed
 938 by the Company in GRID. The historical data presented in the table below shows
 939 that SMUD takes energy associated with the contract in a much lower cost pattern
 940 than assumed in GRID.

941 **Table 2**

942 **SMUD LTF Contract: Actual vs. GRID MWH**

Month	4 Yr. Avg	GRID	2001 Case
1	50,352	39,600	20,538
2	46,325	21,300	7,704
3	31,371	-	19,973
4	30,754	-	27,327
5	30,039	-	23,674
6	35,056	-	17,123
7	44,879	35,400	28,378
8	34,914	52,800	27,941
9	0	45,600	72,004
10	18,349	46,800	33,286
11	17,696	46,100	31,918
12	10,665	63,800	40,533
Total	350,400	351,400	350,400

943

944 **Q. HOW DID YOU ADDRESS THIS PROBLEM?**

945 A. I developed the monthly energy for SMUD for the Test Year based on the four-
 946 year average from 2003 through 2007. I then assumed that on a monthly basis,
 947 SMUD would optimize the contract based on maximizing COB market revenues.
 948 This approach is likely to still overstate the cost of serving SMUD, since they
 949 may not do a “maximum cost” dispatch on a monthly basis any more than they do
 950 on an annual basis. Nonetheless, this adjustment provides a reasonable means of
 951 rectifying this problem. This adjustment is shown on Table 1.

952

953

954 **Q. ARE THERE ANY OTHER ISSUES RELATED TO SMUD MODELING?**

955

956 A. Yes, there are two additional issues. First, in the 2001 case where the SMUD
957 pricing was last decided by the Utah Commission, the Company also assumed a
958 less costly distribution of sales to SMUD than is currently assumed by the
959 Company. Should the Commission reject Mr. Hayet's proposal to re-price
960 SMUD (and instead retain the 2001 price), at a minimum it should recognize that
961 the \$37/MWh price and the 2001 usage pattern case go hand in hand. In that case
962 the distribution shown on Table 2 above should be used. This would result in a
963 reduction of \$1.426 million on a Total Company basis.

964 Second, the SMUD contract limits annual firm deliveries to 350,400²⁹
965 MWh, making no exception for leap year. However, GRID includes sales of
966 351,400 because it allows extra energy to be delivered due to the extra day
967 included in 2008. This additional adjustment is shown on Table 1.

968

Hermiston Losses

969 **Q. PLEASE EXPLAIN THE HERMISTON LOSS ADJUSTMENT IN GRID.**

970

971 A. The Company wheels Hermiston power over the Bonneville Power
972 Administration ("BPA") transmission system. As a result, the Company imposes
973 losses on the BPA system that it must later return to BPA. The Company models
974 these losses as a zero revenue sale in GRID.

975 **Q. DO YOU AGREE WITH THE LEVEL OF LOSSES ASSUMED IN GRID?**

976

977 A. No. The workpapers computing the losses included in GRID (See MDR 2.63.-1)
978 is premised on an assumed loss level of 75,000 MWh per year allegedly occurring

²⁹ The SMUD contract also provides for additional provisional energy, which is later returned to the Company. On a normalized, annual, basis, there is no additional energy available to SMUD from this aspect of the contract.

979 during the period October 1999 to January, 2005. We inquired about this figure
980 during the on-site interviews and in CCS data request 15.2. In neither case could
981 the Company explain the source of the figure used and indicated only that it was
982 an estimate. Exhibit CCS 4.8 shows excerpts from the Company workpapers and
983 my correction to it.

984 **Q. PLEASE EXPLAIN YOUR CORRECTION TO THE LEVEL OF**
985 **HERMISTON LOSSES?**

986
987 A. No. In discovery in the current Wyoming PCAM case I obtained a letter from
988 BPA to PacifiCorp showing the monthly losses during this period. Exhibit CCS
989 4.9 shows a copy of a letter from BPA to PacifiCorp indicating the actual losses
990 that occurred during the period in question. My calculation shows that the correct
991 level of losses for the period was only 55,000 MWh per year. Reducing the losses
992 in GRID to the appropriate level produces the adjustment shown on Table 1.

993 **SMUD Pricing, QF Contracts and Wind Resources**

994 **Q. PLEASE DISCUSS THE OTHER ADJUSTMENTS SHOWN ON TABLE 1**
995 **FOR SMUD PRICING AND QF CONTRACTS.**

996
997 A. I have incorporated SMUD pricing and QF contract adjustments sponsored by Mr.
998 Hayet in his testimony into Table 1.

999 **Arbitrage and Trading Profits in GRID**

1000 **Q. EXPLAIN THE DIFFERENCE BETWEEN BALANCING, ARBITRAGE**
1001 **AND TRADING AS REGARDS SHORT-TERM FIRM TRANSACTIONS.**

1002 A. Balancing is the process of matching supply and demand. The Company
1003 constantly engages in short-term firm transactions to effectuate a more optimal
1004 balancing of the system. The goal of balancing is to match supply and demand
1005 and minimize costs, but not necessarily to make profits on transactions.

1006 Arbitrage occurs when the Company is able to take advantage of price
1007 differences between counterparties.³⁰ Profit generation is the goal of arbitrage
1008 and when the right opportunities are present, it is not a risky endeavor.

1009 Trading is when the Company takes a position (long or short) at one price,
1010 and then closes that position later at a (hopefully) better price.³¹ The goal of
1011 trading is also to generate profits; however, it involves an element of risk because
1012 expected price changes may or may not occur. Over the period 2004-2007, 87%
1013 of the Company's short term transactions were related to balancing while 13%
1014 were for arbitrage or trading purposes.³²

1015 **Q. HAS THE COMPANY INCLUDED ANY ARBITRAGE OR TRADING**
1016 **PROFITS IN GRID STF TRANSACTIONS?**

1017 A. The Company has included some arbitrage and trading profits in the short-term
1018 firm (STF) transactions it modeled in GRID. My analysis of the 2nd
1019 Supplemental Response to CCS 2.49 shows the Company has included
1020 approximately \$205,000 in STF arbitrage profits and \$579,000 in STF trading
1021 profits in GRID. These levels, however, fall far short of historical averages,
1022 because the Company only included STF transactions that it had arranged by the
1023 time of the December 2007 filing. Many more transactions will actually occur
1024 during the test year, based on history.

1025

1026

³⁰ See attachment to CCS 2.40-1, pages 133-134.

³¹ Id., page 134.

³² 1st Supplemental Response to CCS 2.48

1027 **Q. HOW SHOULD GRID RESULTS BE MODIFIED TO REFLECT STF**
1028 **ARBITRAGE AND TRADING PROFITS?**

1029 A. I recommend imputation of the four-year average for STF arbitrage and trading
1030 profits. Over the four-year period 2004-2007, the Company's arbitrage and
1031 trading profits averaged approximately \$4.4 million. Exhibit CCS 4.10 shows the
1032 development of this adjustment based on the responses to CCS 2.48 and CCS
1033 2.49. I recommend the STF profits currently included in GRID be reversed and
1034 these normalized profits be imputed instead. The impact of this adjustment is
1035 shown on Table 1.

1036 **Q. HAVE OTHER COMMISSIONS ADOPTED THIS ADJUSTMENT?**

1037 A. Yes. In the most recent Oregon NVPC update case (UE 191) the OPUC stated:

1038 Thus, we accept Staff's premise that the GRID model systematically
1039 understates the extent of Pacific Power's wholesale market activities.
1040 From that premise Staff infers that Pacific Power receives a systematic
1041 positive return on its net short-term wholesale transactions that are not
1042 included in the GRID runs. Staff attributes that return to Pacific Power's
1043 ability to leverage the flexibility of its diversified system.

1044
1045 * * *

1046
1047 The remaining 13 percent of Pacific Power's short-term wholesale
1048 transactions are properly attributed to Pacific Power's arbitrage and
1049 wholesale trading activities. The Company calculated that the Oregon
1050 allocated margins on such activities averaged \$0.8 million annually (from
1051 2003 through 2006). There is no evidence that those results are included in
1052 the GRID model results. However, we conclude that such revenues are
1053 properly considered in the calculation of NVPC and the model results
1054 should be adjusted as necessary to incorporate those revenues. (OPUC
1055 Docket No. UE 191, Order 07-446 pages 10-11.)
1056
1057
1058
1059

1060

1061

1062

IV. PLANNED OUTAGE SCHEDULE

1063

1064 **Q. WHAT ARE PLANNED OUTAGES?**

1065

1066 A. Planned outages represent times where generators are taken out of service for

1067

routine scheduled repairs and maintenance. Plants are typically taken down once

1068

per year for scheduled work. During the on-site interviews we conducted on

1069

February 15, 2008 we learned this work is normally scheduled in the spring when

1070

demand and market prices are at their lowest levels.

1071 **Q. DOES THE COMPANY USE THE ACTUAL GENERATOR**1072 **MAINTENANCE SCHEDULE FOR THE TEST YEAR IN GRID?**

1073 A. No. The Company uses a “normalized” maintenance schedule, with outage

1074

durations based on a four-year average. Given that the planned maintenance

1075

schedule can be changed in response to forced outages and other events, and the

1076

four-year average outage rate may not coincide with actual outages planned for

1077

the test year, use of a normalized maintenance schedule is reasonable. However, I

1078

do not believe that the schedule actually used in GRID is a reasonable

1079

representation of a normalized maintenance schedule. The figure below

1080

illustrates the problems with the planned outage schedule assumed in GRID.

1081


1082

1083

1084

1085

Figure 3



1086

1087 **Q. PLEASE EXPLAIN THIS FIGURE.**

1088

1089 **A.** This graph shows the percentage of coal-fired scheduled outage energy³³ for each
 1090 month of the calendar year due to planned outages based on the 48-month period
 1091 ended June 30, 2007. For example, during the 48 month period, nearly 40% of
 1092 annual scheduled outage energy occurred in May. Superimposed on the chart is an
 1093 index showing the market price assumptions used in GRID. Also included are the
 1094 comparable figures for the test year based on the GRID inputs and Committee’s
 1095 proposed planned outage schedule.

1096 It is apparent from the chart that actual planned outages have traditionally
 1097 been scheduled to coincide with the low market price periods in the spring and
 1098 fall. The chart shows April, May and June have the lowest market prices, and the

³³ This would be the amount of coal-fired energy the Company would need to replace in order to make up the generation lost due to planned outages.

1099 Company traditionally has performed most of its maintenance (nearly 75%)
1100 during these months.

1101 In contrast, the Company assumes in GRID that more outages will occur
1102 in the winter months and in September and October. In GRID, it is assumed coal
1103 plants will have 15% of scheduled outage energy in January and 13% in February.
1104 It is notable that, during the four-year historical period, the Company did not
1105 schedule *any* significant coal plant outages in January or February. Nor does it
1106 have any plans to actually do so in 2008 or 2009. The Company further assumes
1107 in GRID that about 13% of coal planned outage energy will occur in September
1108 and that 22% of planned coal outage energy will occur in October. Both figures
1109 substantially exceed the actual historical outages as well (10% or less) for those
1110 months.

1111 In all these cases, the GRID planned outages are assumed to occur during
1112 periods when higher market prices prevail, as compared to actual and expected
1113 planned outage schedules.

1114 **Q. DID YOU ALSO EXAMINE THE PLANNED OUTAGES ACTUALLY**
1115 **SCHEDULED FOR THE 2008 TEST YEAR?**

1116
1117 A. Yes. The confidential response to CCS 2.38 provided both the 2008 and 2009
1118 planned outage schedule. Since the answer is confidential, I didn't include it in
1119 the chart above. However, a careful review of the response to CCS 2.38 shows it
1120 follows a pattern comparable to those used during the four-year period. Thus, any
1121 conclusions regarding outage schedules are reinforced by the outages presently
1122 planned for the next two years.

1123 **Q. WHY DO YOU USE THE FOUR YEARS ENDED JUNE 30, 2007 AS THE**
1124 **REFERENCE POINT FOR ACTUAL HISTORICAL OUTAGES?**

1125
1126 A. The duration of planned outages in GRID is based on this four-year period.
1127 Therefore, the Company considers this period to define normalized results. For
1128 this reason it is a useful reference point to compare to the GRID planned outage
1129 schedule. I also have data on all PacifiCorp generator outages (planned and
1130 unplanned) going back to 1979. These data follow essentially the same pattern as
1131 discussed for the four-year period.

1132 **Q. HOW DOES THE COMPANY DEVELOP THE PLANNED OUTAGE**
1133 **SCHEDULE FOR GRID?**

1134
1135 A. The approach actually used in GRID is an arbitrary and essentially mechanical
1136 process that and does not appear to be based on historical or expected outage
1137 schedules, market price curves or other scheduling considerations. The response
1138 to MDR2.57-1 provides the workpapers used to develop the schedule for planned
1139 outage in GRID. Included in those workpapers is a page called "Considerations"
1140 listing factors allegedly used by the Company in developing the planned outage
1141 schedule in GRID. These considerations are listed below:

1142 **Work crew availability** - long lead times required for contractors generally can
1143 only work on one unit per plant hard to get workers during hunting season

1144 **Capacity on outage** - in addition to system total, watch balance in transmission
1145 areas

1146 **Peak loads / High prices** - avoid early July to mid September and late November
1147 to mid February

1148 **Sales in transmission constraint areas** - for Cholla and UPL plants, avoid
1149 scheduling when delivering the APS Exchange (15 May to 15 September)

1150 **Open design / High altitude** - avoid scheduling in cold weather for plants like
1151 Wyodak, Hunter, ...

1152 **Single unit per plant** - allow for delay in startup when scheduling another unit at
1153 same plant (expect when scheduling "normalized", which case schedule them
1154 back to back.)

1155 **Co-owner / Co-generator** - for Bridger, avoid IPC fall hydro season work around
1156 schedule for plants like Craig, Hayden, ...coordinate with Fort James, GSLM, ...
1157 **Non owned plants in control area** - include plants like River Road, Bonanza,
1158 DG&T Hunter share in capacity outage totals don't schedule Hermiston at the
1159 same time as River Road
1160 **Unit contingent purchases** include unit contingent purchases from plants like
1161 Sunnyside, San Juan Unit 4 in capacity outage totals
1162 **Weekend** outages generally begin on Saturday or Sundays so parts are cooled by
1163 Monday (see above exception for "normalized")
1164

1165 **Q. ARE THESE REASONABLE CONSIDERATIONS FOR THE**
1166 **SCHEDULING OF PLANNED OUTAGES?**
1167

1168 A. Yes. On February 15, 2008 we discussed the process used to develop actual plant
1169 outage schedules with Mr. Mark Mansfield, PacifiCorp's VP of Operations
1170 Support and other Company personnel. Regarding the development of plant
1171 outage schedules, some of the above considerations were mentioned by the
1172 Company representatives. It should be noted, however, that the first thing
1173 mentioned in this meeting was that outages were scheduled in the spring (mid
1174 March to late May) to take advantage of low cost power in the market. It was also
1175 discussed that a second, though less preferable, window for outages occurs in the
1176 fall. As the historical data shown above indicates, the Company strongly prefers
1177 to actually schedule outages in the spring.

1178 **Q. HOW DOES THE COMPANY ACTUALLY APPLY THESE FACTORS IN**
1179 **DEVELOPING THE NORMALIZED OUTAGE SCHEDULE FOR GRID?**
1180

1181 A. The actual application in GRID differs substantially from the items listed above.
1182 In the response to CCS 6.15 the nexus between these factors and the GRID outage
1183 schedule was explained:

1184 **Response to CCS 6.15:**
1185

1186 The tab "Considerations" has a list of items that were considered when
1187 developing the planned outages schedule for ratemaking purposes. As suggested

1188 by the title on the page, “**General** considerations for scheduling annual
1189 maintenance,” *the list provides guidelines rather than scheduling requirements.*³⁴

1190
1191 **Work crew availability** – Unit planned outages are not stacked, Units are
1192 scheduled sequentially.

1193
1194 **Capacity on outage** – the tab “PO Daily” was used to review planned outages by
1195 transmission areas.

1196
1197 **Peak loads / High prices** - Maintenance is avoided during the summer months
1198 and *during some winter months.*³⁵

1199
1200 **Open design / High altitude** - *Wyodak is scheduled in October.*³⁶

1201
1202 **Single unit per plant** - Units are scheduled sequentially.

1203
1204 **Co-owner / Co-generator** - Bridger is scheduled in the spring.

1205
1206 **Non owned plants in control area** – Clark River Road, Bonanza and DG&T’s
1207 portion of Hunter are included in scheduling analysis totals. Clark River Road
1208 and Bonanza contracts have expired.

1209
1210 **Unit contingent purchases** – Sunnyside and San Juan Unit 4 are included in
1211 schedule analysis totals.

1212
1213 **Weekend** – Units are scheduled sequentially.

1214
1215 It should be rather obvious that many of the criteria actually used in GRID
1216 are substantially simplified from the considerations set forth in the workpapers
1217 attendant to MDR 2.57-1.

1218 **Q. DOES THE COMPANY ACTUALLY CHECK TO DETERMINE**
1219 **WHETHER THE GRID OUTAGE SCHEDULE IS CONSISTENT WITH**
1220 **THESE GUIDELINES OR WITH ACTUAL PRACTICE?**

1221
1222 **A.** It does not appear that the Company attempts to reconcile the GRID outage
1223 schedule with these guidelines or actual (and expected) plant outage schedules.

1224 For instance, several coal units have outages scheduled in January and February

³⁴ Italics added.

³⁵ Italics added. In reality the only winter month when outages are avoided was December.

³⁶ Italics added.

1225 in GRID. This includes units at Cholla, Craig, Hayden, Hunter and Naughton. In
1226 the answer to CCS 6.15 discussed above, the Company admits that the
1227 requirement related to avoiding outages in cold weather for open design/high
1228 altitude plants was limited to scheduling Wyodak in October.³⁷ This is a highly
1229 questionable simplification because in CCS 6.16 the Company acknowledged that
1230 all of its coal plants are “high altitude/open design” resources. Thus, compliance
1231 with the actual practices and stated guidelines would clearly exclude scheduling
1232 of outages for any of the coal plants in the winter months.

1233 **Q. DID YOU ASK THE COMPANY WHY IT APPARENTLY VIOLATED**
1234 **ITS OWN CRITERIA IN ESTABLISHING THE NORMALIZED OUTAGE**
1235 **SCHEDULE FOR GRID?**

1236
1237 A. Yes. In an attempt to allow the Company to explain why the GRID outage
1238 schedule included these winter outages for coal plants we explored the matter in
1239 Data Request CCS 5.1:

1240 **CCS Data Request 5.1**

1241
1242 **NPC GRID Modeling.** MDR-2.57 contains a worksheet that lists considerations
1243 related to planned outage scheduling. It states the cold weather/high load months
1244 are to be avoided for planned outages for Hunter, Wyodak and other plants, and
1245 that the period late November through mid February are to be avoided. However,
1246 the GRID data base shows planned outages for Cholla, Craig, Hayden, Hunter and
1247 Naughton in the months of January and February 2009. Further, during the four-
1248 year period ended June 2007 none of these units actually had outages scheduled in
1249 January or February. Given the criteria delineated in the worksheet provided as
1250 part of MDR-2.57, does the Company believe that the normalized outage schedule
1251 included in the GRID database is reasonable?

1252
1253 **Response to CCS Data Request 5.1**

1254
1255 Yes. For normalized ratemaking purposes, GRID is required to schedule planned
1256 outages for all plants during a one year period. To do otherwise would result in
1257 planned outages at certain generating units being ignored in the determination of

³⁷ This is by itself unrealistic because during the four year period only 4% of energy lost due to Wyodak planned outages occurred in the fall.

1258 normalized power costs. In actual practice, planned outages can be staggered
1259 across multiple years; however this cannot be reflected in GRID without skewing
1260 normalized power costs.

1261
1262 In developing the normalized outage schedule for GRID, the Company ensures
1263 that (1) the months of July and August have no scheduled maintenance; (2) the
1264 overlapping of unit outages is minimized; and, (3) outage periods include as much
1265 time over the weekend as is possible given the length of the outages defined by
1266 the 48-month period.

1267
1268 **Q. IS THIS REASONABLE?**

1269
1270 A. No. First, I examined the planned outage schedules used in GRID in the most
1271 recent Wyoming and Oregon cases, as well as the prior Utah case. In none of
1272 these cases did the Company find it necessary to schedule planned outages for
1273 coal-fired power plants in January in GRID.³⁸ Consequently, it is difficult to
1274 understand why the Company now believes it would “skew” normalized power
1275 cost results if it did not schedule planned outages in January.

1276 Second, the answer makes little sense numerically. Major outages for
1277 generators don’t occur every year and certainly there will be fewer numbers of
1278 units on outage during a specific year than would be the case in a normalized test
1279 year. However, this does not mean that normalized scheduling of outages must
1280 extend into the high cost cold weather months. For example, consider a plant
1281 with four single units, such as Bridger. A typical outage schedule might show
1282 each of the four units on outage for four weeks once every four years. On a
1283 normalized basis this would amount to four one-week outages for a single test
1284 year. If a single unit of the plant normally goes on outage for four weeks in May,
1285 for example, there is no reason why the four one-week outages could not be

³⁸ The Company did schedule some planned outages for coal plants in February which I disagreed with as well. I filed testimony addressing this problem in the recent Wyoming case.

1286 modeled in GRID for May as well. The Company's argument about "skewing"
1287 the results is clearly unfounded.

1288 **Q. DO ANY OF THE OTHER SCHEDULING CRITERIA DISCUSSED**
1289 **ABOVE PROVIDE JUSTIFICATION FOR THE GRID OUTAGE**
1290 **SCHEDULE?**

1291
1292 A. No. This topic was explored in depth in discovery. In CCS 6.17 we inquired as
1293 to whether the Company performs any analysis to determine if the criteria related
1294 to "system totals" or "transmission area balances" was satisfied. The Company
1295 responded "There is no analysis of whether they were met."

1296 In CCS 6.18 we inquired regarding how the Company determined whether
1297 the criteria related to avoidance of outages in late November to mid-February was
1298 satisfied. Again the Company responded that "There was no analysis of whether
1299 they were met."

1300 In CCS 6.19 we inquired regarding the work crew availability limitation
1301 issue. Again, the response was that "There was no analysis of whether they were
1302 met."

1303 Based on my analysis of this issue, I concluded that the Company has
1304 devised a purely mechanical process to develop an outage schedule in GRID that
1305 is unrelated to the scheduling considerations cited by the Company. Were GRID
1306 to actually apply the criteria discussed above, it would produce a schedule that
1307 looks much more like the actual schedule, and result in lower NVPC.

1308 **Q. PLEASE EXPLAIN THE TABLE BELOW.**

1309
1310 A. This table is based on a correlation analysis I performed and provides the
1311 correlation coefficients between the individual variables related to planned

1312 outages. The correlation coefficient (“*r*”) is a statistical measure of how closely
 1313 two variables track each other. A high correlation means two variables move
 1314 nearly in lock-step, while a low correlation indicates that they move
 1315 independently of each other. A negative correlation means two variables move in
 1316 opposite directions, such as historical outages and market prices.

1317 This table shows that the actual historical schedule is negatively correlated
 1318 with market prices (*r*=-77% for the four-year actual.) This demonstrates that the
 1319 Company does attempt to minimize cost by scheduling outages during low market
 1320 price periods, and by avoiding planned outages when market prices are high.

1321 The GRID “normalized” outage schedule, however, has only a weak
 1322 negative correlation to market prices (*r*=-32%) and a weak positive correlation to
 1323 the actual four year historical schedule (*r*=29%.) This demonstrates that the
 1324 GRID outage schedule methodology deviates from a credible normalization
 1325 process and bears almost no relationship to actual practice, historical data or
 1326 market prices.

1327 **Table 3: Statistical Correlations**

Correlation	Actual	GRID – TY	CCS	Mkt Price
Actual (4 YR Period)	100%	29%	90%	-77%
Test Year (GRID)	29%	100%	58%	-32%
CCS	90%	58%	100%	-69%
Market Price	-77%	-32%	-69%	100%

1328

1329 **Q. WHAT IS YOUR RECOMMENDATION REGARDING THE PLANNED**
 1330 **OUTAGE SCHEDULE ISSUE?**

1331

1332 A. I recommend the Commission adopt my adjustment related to a more realistic
 1333 planned outage schedule. My adjustment shifts the winter-spring coal plant
 1334 outages forward to better match historical and planned outages. I also moved the

1335 Colstrip outages (assumed in GRID to take place in the fall) to the spring. I did so
1336 because Colstrip planned outages have not traditionally occurred in fall months.
1337 This proposed schedule has a much better correlation with the four-year actual
1338 outages ($r=90\%$). It also demonstrates a much more reasonable negative
1339 correlation to market prices ($r=-69\%$). As a result, the NVPC using this more
1340 realistic schedule is lower than the Company's result. As can be seen from the
1341 earlier graph, this revised schedule still places more outage energy in the fall than
1342 have actual schedules. Further, no single month has an excessive amount of
1343 maintenance planned. Because this pattern is more consistent with the actual
1344 planned and historical schedules used, it is clearly a feasible solution and it
1345 produces far more optimal results than the suboptimal schedule assumed by the
1346 Company. The results of this adjustment are shown on Table 1.

1347 **Q. IN DEVELOPING YOUR PROPOSED OUTAGE SCHEDULE HOW DID**
1348 **YOU APPROACH THE CRITERIA LISTED ABOVE?**

1349
1350 A. I used the schedule already in GRID as the starting point. I also avoided overlaps
1351 of outages at a single plant, attempted to schedule outages (where possible) to
1352 start on a weekend, and I developed graphs to show the number of units and MW
1353 of capacity on outage each week during the year. Naturally, I avoided the winter
1354 months, and tried to maximize spring outages without putting too much capacity
1355 or too many units on outage at the same time.

1356 In developing this analysis, it became rather apparent that the Company
1357 really ignored the problem of outage overlaps in its scheduling methodology. For
1358 example, in one week during October 2008, the Company showed 1200 MW and
1359 as many as six units on outage. This is substantially higher than actual plant

1360 outage history, which averaged no more than 400 MW and less than 2 units on
1361 average for the same period. Likewise, in January and February, the Company
1362 scheduled 3-6 units on outage representing roughly 600 MW of capacity. In the
1363 four-year historical period, the Company normally scheduled only a few gas units
1364 for outage during those months. In contrast, the Company scheduled more
1365 capacity and more units on outage in January in GRID than it did in May. This
1366 analysis demonstrates that the amount of capacity and number of units in my
1367 proposed schedule follow historical patterns rather well, while the Company's
1368 schedule does not.

1369 **Q. IS THERE AN ALTERNATIVE METHOD THE COMMISSION MAY**
1370 **WISH TO CONSIDER FOR MODELING OF PLANNED OUTAGES?**

1371
1372 A. Yes. Another alternative would be to simply reflect the actual history of planned
1373 outages in the computation of forced outage rates. While forced and planned
1374 outages are fundamentally different, in GRID modeling, they both result in
1375 removal of a specific amount of capacity at a specific time from the model.
1376 Therefore, there is no technical reason why they need to be modeled in different
1377 ways within GRID. This approach would result in each unit having the correct
1378 amount of scheduled outage energy on a monthly basis. While I object to the use
1379 of monthly unplanned outage rates because there is no underlying basis for using
1380 them (to be discussed shortly), for planned outages there definitely is a systematic
1381 monthly and seasonal pattern.³⁹ There is no reason why this method would not
1382 produce realistic results. In particular, if the Commission retains the use of
1383 monthly unplanned outage rates, it should be consistent and adopt this adjustment

³⁹ The Company acknowledged as much in its response to CCS 21.1.

1384 as well. However, the Commission need not adopt monthly unplanned outage
1385 rates in order to adopt this adjustment. Use of this approach would reduce NVPC
1386 by \$10.6 million, which is comparable to my results using the revised outage
1387 schedule. This analysis further demonstrates the reasonableness of my adjustment
1388 to the Company's planned outage schedule.

1389 V. GRID HYDRO MODELING

1390

1391 **Q. DID YOU REVIEW THE GRID HYDRO INPUT DATA SOURCES?**

1392

1393 A. Yes. As part of my review of the VISTA modeling technique (to be discussed
1394 shortly), I requested the historical data underlying the actual GRID inputs and the
1395 most recent forty years of consistent hydro data (CCS 2.3 and CCS 2.4). I also
1396 obtained a forty-year hydro weekly input file for GRID for the test year ended
1397 June 30, 2008 from the recently filed Washington case. This investigation
1398 showed problems related to the inconsistencies in the data periods used for
1399 different resources.

1400

The Company's storage resource inputs were based on the three different
1401 time periods: 1959-2003 for Lewis River resources; 1964-2003 for Klamath River
1402 resources; and 1962 to 2003 for the Umpqua River projects. Run of river
1403 resources were based on yet another forty-year period: 1967 through 2006. Mid-
1404 Columbia resources were based on a sixty-year period from 1928 through 1988.
1405 A consistent forty-year data set for all resources for the period 1964 through 2003
1406 was provided in the response to CCS 2.3. This data was selected for the same
1407 period of time as the Company uses in its Washington state filings.

1408

1409

1410 **Q. WHAT IS THE PROBLEM WITH USING THE INCONSISTENT DATA?**

1411

1412 A. The use of varying time periods tends to understate the amount of hydro energy
1413 that would be available to serve load when compared to the more conventional
1414 multiple water year analysis the Company used in prior cases. It is hard to justify
1415 use of a sixty-year period for some hydro resources and forty to forty-five for
1416 others based on differing time periods.

1417 **Q. HAS PACIFICORP CHANGED ITS HYDRO MODELING METHOD IN RECENT UTAH RATE CASES?**

1418

1419 A. Yes. The last Utah rate case where NVPC was fully litigated was Docket No.01-
1420 035-01. In that case (and all prior cases), the Company used a traditional multiple
1421 water year modeling methodology. In the first case involving use of the GRID
1422 model, Docket No. 03-2035-02, the Company continued to use conventional
1423 multiple water year modeling.
1424

1425 In the 2004 case, Docket No. 04-035-42, the Company significantly
1426 changed its hydro modeling, and began relying upon a new model called VISTA.
1427 The same approach has been used in all subsequent cases, though none of those
1428 cases were litigated past the stage of the Company filing rebuttal testimony as was
1429 the case in 2004. In all of those cases disputes surrounding use of these new
1430 modeling techniques occurred, but were not resolved. Consequently, the
1431 Commission should recognize that this is a case of first impression regarding
1432 GRID hydro modeling.

1433 **Q. HOW DOES VISTA DIFFER FROM THE HISTORICAL MULTIPLE**
1434 **WATER YEAR MODELING APPROACH?**

1435 A. Traditionally the Company used multiple water years (normally forty to sixty
1436 years) to simulate normalized net power costs.⁴⁰ VISTA does not rely on these
1437 traditional water year simulations. Rather in the current implementation, VISTA
1438 produces a set of three “exceedence”⁴¹ levels representing Wet, Median and Dry
1439 (“W-M-D”) hydro conditions. These scenarios are intended to represent
1440 exceedence levels corresponding to the 25th, 50th, and 75th percentiles.
1441 (Widmer/Duval Direct, page 24). The VISTA model develops the hydro
1442 generation scenarios for each resource based on historical stream flows. As
1443 discussed above, the data used by the Company does not correspond to the same
1444 historical periods for all resources.

1445 **Q. DO YOU HAVE ANY CONCERNS ABOUT THIS APPROACH?**

1446 A. Yes. The method produces a numerically reasonable result for median hydro
1447 conditions, but greatly overstates the likelihood of extreme (wet or dry) hydro
1448 conditions. In particular, the Company’s approach to estimating the exceedence
1449 levels is incorrect and is based on two fallacies.

1450 The first fallacy is that the Company assumes that generation from all of
1451 its hydro resources are perfectly correlated across river systems and throughout
1452 the year. This means that all of the hydro resources are assumed to experience
1453 their wet, median, and dry conditions simultaneously. Indeed, it is assumed that
1454 generation from all hydro resources moves in lockstep. For example, the
1455 Company assumed that if the western system hydro resources were having a “dry”
1456 year, the same would be true for the Mid-Columbia and even the eastern hydro

⁴⁰ The Company still relies on forty water year modeling in Washington state rate cases.

⁴¹ This is a term coined by the Company, and as far as I know, is not used anywhere else.

1457 resources. Consequently, the “dry” (25th percentile) case assumes that all five
1458 major river systems will experience a drought. The same is true for the “median”
1459 and “wet” hydro scenarios.

1460 Even more problematic is the second fallacy, concerning the manner in
1461 which the Company constructed various scenarios on an annual basis. In the
1462 “dry” cases, it was assumed that every generator experienced “dry” conditions
1463 every single week of the year. The same is true for “median” and “wet” cases.
1464 This process produces highly unrealistic results and overstates the likelihood of
1465 extreme conditions, because the “dry” and “wet” scenarios will not happen for all
1466 river systems at the same time and certainly will not all occur every single week
1467 of the year.

1468 **Q. COULD YOU PROVIDE A SIMPLE EXAMPLE TO ILLUSTRATE THE**
1469 **FIRST FALLACY DISCUSSED ABOVE?**

1470
1471 A. Yes. Consider a simple game involving six throws of a pair of fair dice. One can
1472 easily compute the expected value outcome of a throw, by assuming each side of
1473 a single die would have chance of one in six of occurring. One would compute a
1474 probability level of 16.66% for a score of one on a single die; 33.33% for a score
1475 of two or less; 50% for 3 or less; 66.66% for four or less; 83.33% for five or less;
1476 and 100% for six or less.

1477 In the VISTA method, for a roll of a pair of dice, it is equivalent to
1478 assuming that the two dice (like two river systems) are perfectly correlated. This
1479 would imply a probability of 16.66% to roll a pair of ones; 33.33% for a pair of
1480 twos or a pair of ones; 50% for a pair of threes, twos or ones and so on. It should
1481 be fairly obvious that probability levels computed under the VISTA assumption

1482 are completely unrealistic. Indeed, simple probability theory shows that the
1483 chances of rolling a pair of any number is $(1/6)*(1/6)$ or $1/36$. If the river
1484 systems, like individual dice, are independent, the VISTA methodology
1485 systematically miscalculates the probabilities, even if we assume the underlying
1486 data is perfectly accurate. My analysis of correlation data for the various river
1487 systems has shown that the assumption of perfect correlation is unfounded and
1488 unrealistic.⁴²

1489 **Q. WHAT IS THE FUNDAMENTAL PROBLEM WITH THE VISTA**
1490 **MODEL?**

1491
1492 A. The most substantial problem is that VISTA overstates the likelihood of extreme
1493 events, whether drought or flood conditions. Returning to the dice example, the
1494 probability of a pair of ones (or a pair of sixes) is only 1 in 36. In VISTA it is
1495 assumed the probability is 1 in 6. This means that VISTA would be overstating
1496 the probability of an extreme event (in this case, the roll of a pair of ones or
1497 sixes.) However, VISTA ignores the many more likely scenarios where the two
1498 dice have different face values (e.g., a one and a six).

1499 **Q. IS THERE ANOTHER EASY EXAMPLE THAT ILLUSTRATES WHY**
1500 **THE COMPANY'S ASSUMPTION THAT WET OR DRY CONDITIONS**
1501 **WILL OCCUR EACH WEEK OF THE YEAR (THE SECOND FALLACY)**
1502 **IS WRONG?**

1503
1504 A. Yes. Assume one was trying to develop a wet rainfall scenario for Salt Lake City.
1505 While Salt Lake City is regarded as being rather dry, it does average 90 days per
1506 year of measurable rainfall and 5-10 days per month. If one were to look at all of
1507 the years of recorded history, it would almost certainly be possible to find at least
1508 one year when it rained in Salt Lake City for any specific week of the year. Put

⁴² Shortly, I will show that the Company has already acknowledged as much in earlier cases.

1509 another way, it is quite unlikely that there is a single week, even in dry Salt Lake
1510 City, where it has never rained in recorded history. Likewise, it is also reasonable
1511 to assume that over many years of history, one could always find a year where it
1512 did not rain in a specific week. It is very unlikely that over many years, there is
1513 not a single week where it has rained every single year.

1514 **Q. HOW DOES THIS RELATE TO THE COMPANY'S SELECTION OF A**
1515 **WET (OR DRY) HYDRO SCENARIO?**

1516
1517 A. Unfortunately, the Company's approach to selecting a wet scenario would be akin
1518 to assuming that it rains every week of the year in the wet case, because there was
1519 always some year in history when it did rain during that week in Salt Lake City.
1520 Likewise, the Company's approach to the dry scenario is akin to assuming that it
1521 never rains in Salt Lake City in the dry case (because one can always find at least
1522 one year where it didn't rain during any particular week).

1523 The logic behind the Company's wet case, would suggest that the wet
1524 scenario for Salt Lake City, would be a year where it rains every single week.
1525 This is because the Company would construct its wet scenario by combining the
1526 results for 52 wet weeks (just as it constructed the wet hydro case from 52 wet
1527 weeks – the second fallacy.) I submit that a year where it rains every week is
1528 something that has never been recorded in Salt Lake City. Likewise, the
1529 Company's logic would suggest a dry scenario for Salt Lake City, where it never
1530 rained even during a single week.

1531 The basic problem here is the assumption that a wet (or dry) case should
1532 be constructed by accumulating individual wet (or dry) weeks while ignoring the
1533 annual pattern of wet and dry conditions. The Company constructs its wet (or

1534 dry) hydro scenarios assuming that each week of the year experiences wet (or dry)
1535 hydro conditions. In reality, it never happens that way. Wet years are those
1536 where there are many rainy days or weeks, but not cases where it rains every
1537 single week. Even in the wettest years in history, it likely did not rain every
1538 single week. The same is true in the dry case. However, the Company's
1539 approach ignores common sense and greatly exaggerates the severity of the wet
1540 and dry cases. This makes them very unlikely outcomes. However, in GRID, the
1541 Company assumes the wet and dry cases occur once every three years. The
1542 reality is much different. These scenarios may occur, but only about once every
1543 forty years.

1544 **Q. DO YOU HAVE ANY EVIDENCE THAT DEMONSTRATES THE VISTA**
1545 **DATA USED IN GRID OVERSTATES THE LIKELIHOOD OF**
1546 **EXTREME EVENTS?**

1547 **A.** Yes. Exhibit CCS 4.11 shows a comparison of the exceedence levels for the Wet,
1548 Median and Dry ("W-M-D") cases based on the filed VISTA data in GRID and
1549 W-M-D cases based on the VISTA methodology applied to the 40 water years of
1550 data (1964 to 2003) provided in CCS 2.3 When compared to the actual 40 water
1551 year data, it is apparent the VISTA methodology applied to the GRID input really
1552 produces 1%, 48%, and 98% scenarios, rather than the 25%, 50%, and 75%
1553 scenarios the Company believes is produced. In other words, the Company
1554 greatly exaggerates the probability of the extreme (wet and dry) occurrences,
1555 while understating energy in the median case as well.

1556 **Q. CAN YOU DEMONSTRATE THAT THE USE OF THE WET, MEDIAN**
1557 **AND DRY SCENARIOS IN GRID OVERSTATES NVPC?**

1558 A. Yes. In the current Washington case, the Company filed a forty-year hydro data
1559 set for the June 30, 2008 test year. This is consistent with the Mid-Period test
1560 year prepared by the Company as part of its original filing. A run of the
1561 Washington forty-year hydro data in the Utah version of GRID produced NVPC
1562 approximately \$1 million less than the data used by the Company. Likewise, a
1563 run on the Washington version of the GRID model using the erroneous Wet,
1564 Median and Dry scenarios filed in this case for the same test year produced NVPC
1565 approximately \$1 million higher than the forty-year hydro data. These results
1566 actually underestimate the bias in the GRID data used in this case because the
1567 forward curves used to optimize the GRID dispatch differed in the two
1568 proceedings. Optimizing the hydro dispatch for the proper forward curves would
1569 further lower NVPC.⁴³

1570 **Q. WHAT IS YOUR RECOMMENDATION REGARDING THIS ISSUE?**

1571 A. My recommendations on this issue are threefold:

1572 (1) At a minimum, the Commission should simply use the median hydro scenario
1573 in this case. While I do not agree with the method used to compute the median
1574 hydro case, or the time periods selected, this scenario does produce approximately
1575 the correct amount of energy compared to a proper forty-year analysis using
1576 consistent data. Moreover, as I discuss below, the Company has agreed that a
1577 median hydro scenario is a reasonable approach in a recent Oregon case.

⁴³ In the recent Wyoming case the Company failed to optimize the hydro dispatch in VISTA for the then current forward curve. Optimizing the hydro for the correct forward curve reduced NVPC \$542 thousand.

1578 (2) The Commission should eliminate the bias or deficiencies in the Company's
1579 modeling by changing the weights for the Wet, Median and Dry cases according
1580 to those shown on Exhibit CCS 4.11. I developed these weights using a
1581 histogram based on the forty water year data and determined which of three
1582 blocks (based on the Wet, Median and Dry cases) each single year would fall into.
1583 The results are then used as weights for each of the three GRID scenarios. This
1584 produces the hydro adjustment shown in Table 1.

1585 (3) The Commission should require the Company to use a consistent time period
1586 for development of the hydro data and to address these deficiencies in its
1587 modeling approach in the Company's next rate case filing.

1588 **Q. HAVE SOME OF THESE ISSUES RELATING TO PROPER HYDRO**
1589 **MODELING BEEN ADDRESSED IN PRIOR CASES IN OTHER**
1590 **STATES?**

1591 A. Yes. In the first case where the VISTA method was applied (Docket No. 04-035-
1592 42), the Company originally proposed to use nineteen exceedence levels (5%
1593 through 95% in 5% increments.) I pointed out the problems related to this
1594 modeling and Mr. Widmer agreed that my criticisms had merit and abandoned the
1595 use of multiple exceedence levels in favor of the simple median case:

1596 "The observation concerning the VISTA exceedence levels has some merit. . . To
1597 address this issue the Company proposes to abandon normalizing hydro
1598 availability with 19 exceedence levels in favor of using just the medium (50%)
1599 exceedence level." (UPSC Docket 04-035-42, Widmer Rebuttal, Page 26.)

1600 In subsequent cases, the Company started using the three part (W-M-D)
1601 solution. However, the Company has simply replaced nineteen bad estimates
1602 with three bad estimates. This does not make the final results any more valid.

1603 In the most recent Oregon case (UE 191), Mr. Widmer again
1604 acknowledged that the various river systems underlying the hydro resources were
1605 not perfectly correlated, as assumed by VISTA, and strongly suggested again that
1606 use of the median hydro was an appropriate solution to the problem. (OPUC
1607 Docket No. UE 191, Widmer rebuttal, pages 27-29.) In discovery responses in
1608 Oregon, the Company clearly stated that “the 25% and 75% exceedence levels
1609 may not represent the 25% and 75% for total system hydro...” (OPUC Docket
1610 No. UE 191, ICNU/13.34, available via agreement by the Company in the
1611 response to CCS 2.39). In another data response the Company indicated it was
1612 uncertain whether it should continue to use the 25% and 75% scenarios instead of
1613 the simple median (50% case). (OPUC Docket No. UE 191, ICNU/13.33, again
1614 via the response to CCS 2.39). While I additionally recommend use of the proper
1615 hydro weights in this case, use of the median scenario only is a solution the
1616 Company has supported in past cases.

1617 **Q. ARE THERE ANY OTHER HYDRO MODELING ISSUES?**

1618 A. Yes. The Company uses an arbitrary, non-physical input in GRID called the
1619 “Hydro Reserve Input Parameter.” This represents the fraction of the difference
1620 between the hydro weekly energy and the project maximum capacity that is held
1621 for reserves.⁴⁴ As this input is increased, more hydro capacity is assigned to
1622 carrying reserves. This parameter is not a measurable input, such as the capacity
1623 or ramp rate of the unit. Nor is it a factor actually used in the real time operations.

⁴⁴ GRID V6.2 Algorithm Guide, Page 15.

1624 Rather, it is a judgmentally determined input, without any supporting
1625 documentation provided by the Company.

1626 The Company assumes that this parameter should equal .85 most hours of
1627 the day, but for the period 7 am to 10 am, it is set equal to one. This has the
1628 impact of increasing the amount of hydro generation allocated to reserves, thereby
1629 increasing NVPC. Because these three hours already have reserve allocations to
1630 hydro that exceed the hourly requirements (without the increase in the Reserve
1631 Input Parameter), there is no apparent justification to further increase the reserve
1632 allocation. This simply reduces the value of hydro generation to the Company.

1633 **Q. WHAT IS YOUR RECOMMENDATION?**

1634 A. Discovery regarding this issue produced limited information as of the time this
1635 testimony was prepared. The Company may be able justify these inputs. For that
1636 reason, I have not included this adjustment in my recommended NVPC results.
1637 Absent a meaningful explanation from the Company, I recommend the
1638 Commission reverse this input in GRID. This results in the adjustment shown on
1639 Table 1.

1640

1641

1642

1643

1644

1645

VI. THERMAL DERATION FACTORS1646 **Q. EXPLAIN THE USE OF THERMAL DERATION FACTORS IN GRID.⁴⁵**

1647 A. In GRID, thermal deration factors (also called unplanned outage rates) control the
1648 amount of generation available from thermal units. The more energy available,
1649 the lower net variable power costs. If a generator has an average unplanned
1650 outage rate of 5%, GRID assumes a thermal deration factor of 95%. This means
1651 that only 95% of the unit's capacity is available to produce energy. The
1652 remaining capacity is assumed to be permanently unavailable.

1653 **Q. ARE THERMAL DERATION OR UNPLANNED OUTAGE FACTORS AN**
1654 **IMPORTANT DRIVER IN OVERALL NET POWER COSTS?**

1655 A. Yes. PacifiCorp's thermal unplanned outage rates have increased substantially in
1656 the past decade. Exhibit CCS 4.12 shows that PacifiCorp's four-year rolling
1657 average unplanned outage rates have increased by more than 40% compared to
1658 comparable figures for 1999. Also troubling is the fact that 81% of PacifiCorp's
1659 generating units have seen their unplanned outage rates increase over the past
1660 eight years.

1661 **Q. WHY DID YOU COMPARE CURRENT FIGURES TO THE 1999**
1662 **UNPLANNED OUTAGE RATES?**

1663 A. I have been analyzing PacifiCorp's unplanned outage rates in rate cases dating
1664 back to 1998 and there has been a continued upward trend to the present time.
1665 The 1999 figures were worse than the 1997 four-year average, for example. Both
1666 the 1999 and 2006 four year averages exclude the major Hunter outage that
1667 occurred in November 2000 providing a fair comparison of outage trends.

⁴⁵ Hereafter in this testimony, unplanned outages and outage rates will be discussed, as distinguished from the planned outages discussed above. Even if the text doesn't specify it, I will be discussing unplanned outages.

1668 **Q. IS THIS TREND A RESULT OF PLANT AGING?**

1669 **A.** No. Review of NERC figures shows that, while the national fleet of coal plants
1670 has aged substantially in recent years, outage rates have decreased, not
1671 increased.⁴⁶

1672 **Q. HAS THE INCREASE IN UNPLANNED OUTAGE RATES INCREASED**
1673 **POWER COSTS?**

1674 **A.** Yes. To estimate this cost I used GRID to compute the change in net variable
1675 power costs resulting from a 10 MW change in coal capacity. I then applied this
1676 result to develop an annual average cost of the increased amount of outage
1677 capacity. As shown in Exhibit CCS 4.12, the result is more than \$55 million per
1678 year on a total Company basis. This increase in outages results in an increase in
1679 cost to Utah customers of more than \$23 million per year. An additional problem
1680 is that the increase in outage rates has also led to the need for additional thermal
1681 capacity, further increasing system costs. To put this into perspective, the
1682 increase in outage capacity (189 MW) is nearly equivalent to the total capacity of
1683 the West Valley plant.

1684 **Q. WHICH OF PACIFICORP'S COAL UNITS HAVE THE HIGHEST**
1685 **UNPLANNED OUTAGE RATE?**

1686 **A.** The four Bridger units have the highest outage rates among all the coal plants
1687 owned by the Company.

⁴⁶ See exhibit CCS 4.13.

1688 **Q. COMPARISON OF HISTORICAL AVERAGE FIGURES DOES NOT**
1689 **DIRECTLY ADDRESS WHY UNPLANNED OUTAGE RATES HAVE**
1690 **INCREASED. IS THERE EVIDENCE THAT THE INCREASE IN**
1691 **OUTAGE RATES IS DUE TO POOR OPERATION AND MANAGEMENT**
1692 **PRACTICES?**

1693 A. Yes. To investigate the causes of these outages, I examined numerous “Root
1694 Cause Analysis” (“RCA”) reports for outages that occurred at PacifiCorp’s coal-
1695 fired generators during the 48-month period ending June 30, 2007. I analyzed
1696 these RCA reports and determined whether the cause of the outages was due to
1697 poor management, personnel or maintenance errors, or other avoidable causes. It
1698 is important to point out that in the vast majority of RCA reports I reviewed,
1699 PacifiCorp did not report the outages to NERC as being due to personnel or
1700 maintenance errors⁴⁷ but instead, were reported as having other causes. Despite
1701 this, I found many instances where the RCA reports indicated personnel or
1702 maintenance errors. PacifiCorp should be held responsible for the costs of these
1703 outages because they appear to be contributing to the Company’s increasing
1704 outage costs. It is significant that nearly all of these events occurred at a single
1705 plant – Jim Bridger, the plant that has the highest outage rates on the PacifiCorp
1706 system.

1707 **Q. CAN YOU PROVIDE SOME EXAMPLES?**

1708 A. Yes. Confidential Exhibit CCS 4.14 presents excerpts from RCA reports that
1709 show a substantial number of outages were caused by Company errors,
1710 mismanagement or other avoidable causes. In total, I identified thirteen such
1711 events, eleven of which occurred at Jim Bridger.

^{47/} PacifiCorp coded a very substantial number of outages due to such causes, but these tended to be small events, generally lasting only a few hours. The number of such events has also been increasing substantially over the years.


1712 **Q. THE EVENTS DISCUSSED IN EXHIBIT CCS 4.14 WERE REPORTED**
1713 **TO NERC AS BEING DUE TO CAUSES OTHER THAN EMPLOYEE OR**
1714 **CONTRACTOR ERRORS. DID THE COMPANY ALSO REPORT ANY**
1715 **OUTAGES AS BEING DUE TO SUCH ERRORS?**

1716 A. Yes. For example, during the period ending June 30, 2007, the Company
1717 identified 170 events at coal plants due to causes that it did report to NERC as
1718 being due to operator, maintenance or contractor errors. Review of this data
1719 showed that more than half of these events occurred at the Bridger plant.

1720 **Q. WHAT HAS BEEN THE TREND IN REPORTED ERROR OUTAGES**
1721 **FOR PACIFICORP?**

1722 A. The Company has seen a substantial increase in the number of outages due to
1723 errors since the Utah Power and Light - Pacific Power and Light merger took
1724 place. The chart below shows the number of outages due to errors for the period
1725 1990 to 2006 for PacifiCorp coal plants. These include outages reported to NERC
1726 as due to employee or contractor errors. The NERC average for the most recent
1727 four-year period available is also shown. As the chart shows, the Company has
1728 experienced a tripling of outages due to errors and now has three times the
1729 national average number of errors.⁴⁸ However, over recent years, a growing
1730 proportion of such events have occurred at the Bridger plant. If Bridger were
1731 removed, the remaining plants are closer to (but still somewhat above) the NERC
1732 averages. While the NERC average for error outages at a four-unit plant is two
1733 events per year, the Bridger plant experienced more than 90 events in the four-
1734 year period.

⁴⁸ Based on NERC data a fleet of 26 coal units would experience approximately 14 events per year, or .55 per unit/year.



1735

1736 **Q. WHAT IS YOUR RECOMMENDATION?**

1737

1738 A. I recommend the Commission make an adjustment to reduce the amount of
 1739 energy lost due to both the reported and unreported employee, maintenance and
 1740 contractor errors at Bridger to the NERC average. This would reduce outage-
 1741 related energy in the test year by more than 75,000 MWh, and is equivalent to
 1742 reducing the Bridger outage rates by .75%. The impact of this adjustment is
 1743 shown on Table 1.

1744 **Q. IS IT REASONABLE TO MAKE AN ADJUSTMENT INVOLVING ONLY**
 1745 **THE BRIDGER PLANT AND IGNORE THE COMPANY'S OTHER**
 1746 **PLANTS?**

1747

1748 A. The performance of the Company's remaining plants is comparable to (neither
 1749 well above, or far below) the NERC averages. The Bridger plant is a poor
 1750 performer relative to not only the NERC averages, but also as compared to the
 1751 Company's other coal-fired power plants. Owing to the overall declining trend in

1752 plant availabilities and poor performance of the Bridger plant relative to its peer
1753 group, a disallowance is clearly warranted.

1754 **Monthly Outage Rates**

1755 **Q. HOW DOES THE COMPANY MODEL UNPLANNED OUTAGE RATES**
1756 **IN GRID?**

1757 A. The Company differentiates unplanned outage rate on a monthly basis using the
1758 average monthly outage rate computed from the four-year period. This procedure
1759 marks a significant departure from the modeling methods used by the Company in
1760 Docket No. 01-035-01. In the past, the Company assumed that unplanned outages
1761 would occur with the same probability every month of the year. In this case, the
1762 Company now assumes outage rates will vary by month. As with the hydro
1763 modeling issue, this is development that has been the subject of debate in the
1764 previously settled cases in Utah. Only the Washington Commission has ruled on
1765 this issue, deciding against this new procedure in the most recent case in that
1766 state.⁴⁹

1767 **Q. IS THIS AN INDUSTRY STANDARD PRACTICE?**

1768 A. Most definitely not. PacifiCorp's approach is quite unusual and certainly not
1769 industry standard. While I am aware that a few utilities have briefly experimented
1770 with modeling seasonal outage rates, the vast majority of utilities assume a
1771 constant outage rate throughout the year. The primary reason for this is that there
1772 are few physical factors affecting thermal power plant operation that would result
1773 in outage rates varying significantly on a monthly or seasonal basis. There is

⁴⁹ Washington Utilities and Transportation Commission, Docket No. UE-061546, Final Order Paragraphs 136 – 137. I do acknowledge the WUTC order is rather unclear on this issue, however, in its most recent filing in Washington (Docket No. UE-080220), the Company excluded both its ramping and monthly outage rate adjustments based on that order.

1774 really no engineering or statistical basis to assume a generating unit would be
1775 significantly more reliable in January than July, for example. In its response to
1776 CCS 21.11, the Company could not identify any factors that would result in
1777 monthly variation in unplanned outage rates.⁵⁰

1778 Further, unplanned outages are quite random by nature, and use of
1779 monthly statistics can produce very misleading results. Just one “bad month” can
1780 skew an average computed from only four data points. For example, for Gadsby
1781 Unit 2, the monthly outage rate methodology produces rather absurd results.
1782 Based on Company analysis, Gadsby Unit 2 will be on forced outage 96% of the
1783 weekdays in December, but will be available 100% of the time on weekdays in
1784 January. It makes no sense to assume that on a normalized basis the unit will
1785 almost never be available on weekdays in December, but will always be available
1786 in January. Normalization is supposed to “smooth out” variations for a single
1787 month or year to produce results that are more realistic overall. The Company’s
1788 approach does just the opposite. It “de-normalizes” the outage rate data.

1789 **Q. ARE THESE MONTHLY OUTAGE RATES STABLE OVER TIME?**

1790 A, No. In the recent Wyoming case the Company used the 48 months ended
1791 December 31, 2006 to compute outage rates. In this case, the Company used the
1792 48 months ended June 30, 2007, a change of only six months. However, in
1793 Wyoming, the Company’s method showed a June weekday outage rate for
1794 Gadsby Unit 1 of 99% (without ramping), now the Company computes an outage
1795 rate of only 1% if ramping is excluded.⁵¹

⁵⁰ Mr. Hayet also comments on PacifiCorp’s approach in his testimony.

⁵¹ The reasons ramping should be excluded will be discussed later in this testimony.

1796 **Q. CAN YOU PROVIDE A SIMPLE ANALOGY THAT EXPLAINS THE**
1797 **FALLACY OF THE COMPANY'S APPROACH?**

1798 A. Yes. The Company's approach is similar to assuming that because a random
1799 event occurred in a particular month in the past, it would likely occur at the same
1800 time in the future. If my car broke down in February 2007, does that mean it will
1801 break down again in February 2008? I don't think so, but that's the logic the
1802 Company is using.

1803 **Q. DOES THE COMPANY'S PROPOSED MONTHLY OUTAGE RATE**
1804 **MODELING INCREASE OR DECREASE NVPC?**

1805 A. In this case, it produces a small decrease in NVPC. However, given the lack of a
1806 sound engineering basis, statistical data or common sense argument supporting it,
1807 I believe the Company's approach should be rejected. Accordingly, I recommend
1808 that the Commission reject the monthly modeling of outage rates and increase net
1809 power costs by the amount shown on Table 1.

1810

1811

Thermal Ramping

1812

1813

1814 **Q. EXPLAIN THE THERMAL RAMPING ADJUSTMENT TO GRID**
1815 **OUTAGE RATES.**

1816

1817 A. Ramping represents the energy lost after outages due to the time required to ramp

1818 up a unit to its desired generation level. GRID does not account for this energy

1819 because it uses a constant deration method rather than a simulation of full outages.

1820 The Company proposes to adjust outage rates to reflect the lost energy it assumes

1821 results from ramping.

1822 **Q. DO YOU RECOMMEND THE COMMISSION ACCEPT THIS**
1823 **PROPOSED “CORRECTION”?**

1824 A. No. This adjustment was ostensibly proposed by the Company to better represent

1825 the operation of thermal units. PacifiCorp used this technique in recent cases in

1826 some states, motivated by a specious assumption that GRID was producing an

1827 excess of coal-fired generation.⁵² To address the ramping issue, PacifiCorp

1828 creates “phantom outages,” inflating its outage rates.

1829 I believe it is important to note that many of the Company’s recent cases

1830 in Oregon, Utah, Washington and Wyoming have been settled (at least regarding

1831 this issue) or dismissed, and only the Washington Commission has ruled on this

1832 issue.⁵³ In Docket No. UE-061546, the Washington Commission rejected the

1833 ramping adjustment proposed by the Company. The Company did not include

1834 this adjustment in its most recent Wyoming and Oregon cases, but has stated that

1835 the ramping adjustment was left out by mistake. Along with the hydro modeling

^{52/} Re PacifiCorp, OPUC Docket No. UE 170, Exhibit PPL/604, page 2 (Supp. Direct Testimony of Mark Widmer).

⁵³ Washington Utilities and Transportation Commission, Docket No. UE-061546, Final Order Paragraphs 136 – 137.

1836 and monthly outage rate issues, the thermal ramping issue has never been
1837 presented to the Utah Commission.

1838 **Q. IS MODELING OF THERMAL RAMPING IN THE MANNER USED BY**
1839 **THE COMPANY STANDARD INDUSTRY PRACTICE?**

1840 A. No. Based on my nearly thirty years of experience working with various power
1841 cost models, this approach is extremely unusual and contrary to standard industry
1842 practice. The North American Energy Reliability Council (“NERC”) publishes a
1843 standard formula for computation of forced outage rates, and the approach
1844 proposed by the Company does not use the NERC formula.

1845 **Q. CAN YOU ILLUSTRATE SOME OF THE PROBLEMS WITH THE**
1846 **COMPANY’S RAMPING ADJUSTMENT?**

1847 A. Yes. Exhibit CCS 4.15 provides a copy of the response to CCS 6.11 and
1848 compares that data to data obtained in the response to CCS 2.8. The response to
1849 CCS 6.11 shows the Company’s calculation of the ramping adjustment for
1850 Gadsby Unit 3 for the month of March, 2007. The worksheet shows how the
1851 ramping calculation is performed each hour. The Company’s methodology
1852 assumes that any difference between the actual loading of a unit after it has been
1853 started up and 90% of its available capacity is due to ramping. This is a very
1854 significant adjustment for Gadsby Unit 3 in the calculation of March outage rates
1855 because this is the only March during the four-year period ending June 30, 2007
1856 when Gadsby Unit 3 was actually called upon to run. In total, the unit generated
1857 916 MWh during that month, *but lost 994 MWh due to ramping.*

1858 **Q. PLEASE MORE FULLY DESCRIBE THE PROBLEMS WITH THE**
1859 **COMPANY ANALYSIS.**

1860 A. The first problem is that the Company assumes that unless a unit is running at
1861 90% of its full loading, it must be losing generation due to ramping, no matter
1862 how long it has been running. In the Gadsby Unit 3 example, on March 28, 2007,
1863 the Company assumes that even after the unit ran for eleven hours (when the unit
1864 is cycling down to a reserve shutdown) it was still losing energy due to ramping.
1865 In the last hour of operation on that day, the unit produced only 5 MW (as
1866 compared to available capacity of 100 MW). The Company assumes this resulted
1867 in 95 MW lost due to ramping, even though it acknowledged in response to CCS
1868 6.11 that the unit was only on line part of the hour and heading into reserve
1869 shutdown status.

1870 This is a very flawed approach, however, because there is no basis for the
1871 assumption that the unit would otherwise be dispatched to at least 90% of its full
1872 loading if not for ramping. The real time dispatch may determine, for example,
1873 that the most economic dispatch is something less than full (or even 90% of full)
1874 loading for a unit.

1875 Alternatively, the unit may be assigned to carry reserves. Exhibit CCS
1876 4.15 also shows the hourly allocation of reserves to Gadsby Unit 3 during March
1877 2007 based on the data provided in CCS 2.8. It shows that the unit was assigned
1878 to carry reserves every single hour when the Company assumed it would
1879 otherwise be losing generation to ramping. In this example, 487 MWh which the
1880 Company assumed to be lost due to ramping was actually assigned to reserves.
1881 This amounts to almost half of the ramping adjustment for the month. The fact
1882 that the unit had so much capacity allocated to spinning reserves clearly indicates

1883 that it was never intended to run at full loading. Instead it was started to provide
1884 reserves and therefore operated at much less than full load. Under the Company's
1885 analysis of ramping, all of this was ignored. Were these facts considered,
1886 virtually none of the lost ramping energy should be counted.

1887 **Q. WHAT IS YOUR RECOMMENDATION REGARDING THE THERMAL**
1888 **RAMPING ISSUE?**

1889
1890 A. The Commission should reject the ramping adjustment. It is demonstrably
1891 overstated, it was recently rejected by the Washington Commission and the
1892 Company has not even proposed the adjustment in its two most recently filed
1893 cases. Reversing the Company's proposed ramping adjustment is included in my
1894 Table 1.

1895 VII. CURRANT CREEK AND LAKE SIDE MODELING

1896 **Q. ARE THERE ANY OTHER PROBLEMS WITH THE MODELING OF**
1897 **COMBINED CYCLE UNITS IN GRID?**

1898
1899 A. Yes. In GRID the Company models the duct firing capabilities of Currant Creek
1900 and Lake Side as generation resources that are independent of the underlying
1901 combined cycle plant. This has created problems where the duct firing capacity
1902 runs at times when the combustion turbines and steam generator are not
1903 running.⁵⁴

1904 A more serious problem is that GRID frequently shows duct firing
1905 operation of Currant Creek when the combustion turbines and steam generator of
1906 Currant Creek are operating at their minimum loading. This is neither an
1907 economical nor realistic mode of operation, as duct firing capability has a higher
1908 heat rate than the combined operation of the combustion turbines and steam

⁵⁴ See the response to CCS 6.41

1909 generator. During the on-site interviews conducted on February 15, 2008, the real
1910 time operational staff members indicated this was not the normal mode of
1911 operation. Yet GRID shows this unrealistic operation more than 2300 hours per
1912 year, or 50% of the time that duct firing is in operation.

1913 A further problem is that in GRID, the Company does not allow the duct
1914 firing capacity of Currant Creek and Lake Side to carry spinning reserves, though
1915 they are allowed to carry ready (quick start) reserves. This is again, unrealistic.
1916 When Current Creek is not running, it is impossible for the duct firing to start in
1917 ten minutes, while it can do so if the plant is already running.

1918 **Q. WHAT IS YOUR RECOMMENDATION CONCERNING DUCT FIRING?**

1919
1920 A. The Company needs to develop a modeling enhancement for GRID that allows
1921 proper modeling of all modes of operation for combined cycle generators. I
1922 recommend the Commission require this be done before the next general rate case
1923 is filed.

1924 As an interim solution for the Commission's consideration in this case, I
1925 have combined these resources into a single unit in GRID. Because I would like
1926 to evaluate the Company's response to this proposal from a modeling perspective,
1927 I have not reflected this adjustment in the totals shown on Table 1. However,
1928 absent the Company providing a sound reason not to proceed with the adjustment,
1929 I recommend the Commission adopt it. This produces a reduction to NVPC in the
1930 amount shown on Table 1.

1931 **Q. PLEASE EXPLAIN YOUR PROPOSED INTERIM SOLUTION IN MORE**
1932 **DETAIL.**

1933 A. In reviewing the hourly loadings of the combined Currant Creek resource, I was
1934 able to develop a much more realistic dispatch than the Company's modeling
1935 approach. This approach eliminates the unrealistic operation of the resource and
1936 also reflects the reserve carrying capability when duct firing is in operation.

1937 The Company has already estimated the heat rate curves for combustion
1938 turbines and steam generator combining normal and duct firing modes of
1939 operation. Thus, the input heat rate curve used in GRID reflects operation from
1940 minimum loading to full duct firing operation. Because duct firing is less
1941 efficient, this may overstate the heat rate for conventional operation of the plant,
1942 providing yet one more reason to combine the resources into a single resource in
1943 GRID.

1944 **Q. HAVE YOU EXAMINED ANY ALTERNATIVE APPROACHES?**

1945 A. Yes. Another approach would be to simply allow the Currant Creek duct firing
1946 capability to carry spinning reserves. I've examined the hourly results under this
1947 approach extensively, and believe it provides a more realistic operation than the
1948 Company's modeling as well. While this technique accounts for the reserve
1949 carrying capability of duct firing, it does not eliminate the problem related to
1950 operating duct firing before the steam generator is fully loaded. This adjustment
1951 produces a NVPC reduction of approximately \$2 million.

1952 **Q. HAS THE COMPANY CORRECTLY COMPUTED THE OUTAGE RATE**
1953 **FOR CURRANT CREEK IN GRID?**

1954 A. No. The Company used an unsupported and incorrect formula to compute the
1955 Currant Creek outage rate in GRID. Further, even accepting the formula used by
1956 the Company, it had incorrect inputs for the combustion turbine capacities, using
1957

1958 180 MW rather than 140 MW. The Company calculated an annual average
1959 outage rate of 4.81% compared to my corrected outage rate of 4.75%. Had I
1960 simply corrected the capacities used in the Company's formula, the outage rate
1961 would have been 4.10%. Also, the Company overstated the number of days of
1962 required maintenance for Current Creek because it considered a planned outage of
1963 one CT as resulting in an outage of the entire plant. In reality, when one CT is
1964 down, the plant can still run at half of its capacity. I have corrected the
1965 calculation of Currant Creek's planned and unplanned outage rate in GRID,
1966 resulting in the adjustment shown on Table 1.

1967 VII. GENERATING UNIT REPRESENTATION IN GRID

1968

1969 **Q. EXPLAIN HOW GENERATOR OUTAGES ARE REPRESENTED IN**
1970 **GRID.**

1971

1972 **A.** As discussed earlier, GRID uses what is known as the deration method to model
1973 outages. Outage rates are assumed to reduce the available capacity. This means
1974 that if a unit has 100 MW of capacity, and a 5% outage rate, the unit is
1975 represented in GRID as a 95 MW unit that is available 100% of the time. This is
1976 an industry standard technique. Though dated, this approach has been used in
1977 various models for many years. In effect, GRID replaces the capacity of each unit
1978 with its "expected value." The expected value, MW_e , for a unit is computed as
1979 shown below:

1980

1981 **$MW_e = MW \times (1-EFOR)$, where EFOR = the outage rate of the unit,**
1982 **and MW is the maximum capacity of the unit.**

1983

1984 The above formula is appropriate because it represents a situation where
1985 the unit is fully available (i.e. to MW, the maximum capacity) (1-EFOR)⁵⁵
1986 percent of the time, and available at zero MW (because it is on an outage)
1987 EFOR⁵⁶ percent of the time.

1988 I have no objection to this representation in GRID, even though there are
1989 other, more sophisticated, methods such as Monte Carlo modeling that may
1990 provide more realistic simulations. While it is not immediately obvious, proper
1991 use of the deration method also requires other adjustments to unit characteristics
1992 be made as well. First of all, the unit *minimum capacity*, MW(min), should also
1993 be derated by the same amount as the *maximum capacity*. The expected value of
1994 the minimum capacity, MW(min)_e is given by the formula below:

1995

$$1996 \quad \mathbf{MW(\min)_e = MW(\min) \times (1-EFOR).}$$

1997

1998 The simple, and intuitive, explanation is that unless this adjustment is
1999 made, the unit's *minimum capacity* could exceed its *maximum capacity*. While
2000 this may seem far fetched, it actually did happen in some situations in the GRID
2001 simulations for the test year. For example, in May 2008, Currant Creek was
2002 assumed to have a rather large outage rate. As a result, the derated maximum
2003 capacity (338.5 MW) was less than the assumed minimum capacity (340 MW) for
2004 Currant Creek. Thus, use of the deration method as applied by the Company

⁵⁵ 95% in the example above.

⁵⁶ 5% in the example above.

2005 results in the model violating minimum loading constraints, albeit by a small
 2006 amount.⁵⁷

2007 A more detailed and mathematical explanation is that when simulating
 2008 operation at minimum loadings, it is also necessary to compute the expected value
 2009 of the loading. If the unit is expected to be operating at minimum loading during
 2010 a given hour, the expected value of its generation is MW(min) 1-EFOR percent of
 2011 the time, and zero EFOR % of the time. This is no different than the case
 2012 discussed above involving maximum capacities. While the Company derates the
 2013 maximum capacity for outages in GRID, it does not do so for the minimum
 2014 capacity. Given the substantial number of resources now operating at minimum
 2015 loading, this has become a very serious oversight.

2016 **Q. ARE THESE THE ONLY ADJUSTMENTS REQUIRED?**

2017
 2018 A. No. There must also be a corresponding adjustment to the heat rates, which is not
 2019 being done in GRID either. Generating units are represented in GRID using a
 2020 polynomial heat rate equation:

2021
 2022
$$\text{Heat input (hour h)} = A + B \times mW_h + C \times mW_h^2$$

2023
 2024 Here mW_h is the loading of the unit in hour h.

2025 If, for example, the unit is expected to be running at its maximum
 2026 capacity, GRID will treat it as a smaller unit running at less than full load.
 2027 Returning to the original example of a 100 MW unit, GRID sees it as a 100 MW
 2028 unit that is only running at 95 MW. In this case, the actual heat input of the unit

⁵⁷ While minor in this case, in the Wyoming case, the discrepancy was much larger, as GRID showed Currant Creek running as low as 288 MW, more than 50 MW below its stated minimum.

2029 will be overstated, because units are generally most efficient at their full loading
2030 point. The heat rate curve used in GRID will therefore overstate fuel costs.

2031 This is again related to the concept of expected value. The expected value
2032 of the heat input for the 100 MW unit is as follows:

2033

2034 **Heat input = (A+B x 100 + C x 100²) times 95% + 0 times 5%.**

2035

2036 In effect, the above equation shows that the expected value of the heat
2037 input should be computed as (1-EFOR) times the heat input at full loading.
2038 GRID, however, would compute the heat input as shown below:

2039
$$\text{Heat Input (GRID)} = A+B \times 95 + C \times 95^2$$

2040 While it appears to be a rather minor adjustment in the case where a unit is
2041 fully loaded, it can be very important in some cases. Further, because unit
2042 efficiencies typically decline as unit loadings decrease (moving down the heat rate
2043 curve), ignoring this adjustment will increase NVPC. Even worse, not making
2044 this type of adjustment could produce absurd results in some cases. As discussed
2045 earlier, it is assumed in GRID that one of the Gadsby units would have an outage
2046 rate approaching 100% in December 2008. It is possible in such cases that using
2047 a very large outage rate would result in a dispatch of the unit at a mere fraction of
2048 its actual capacity, even if it was intended to run at maximum loading. Absent
2049 any kind of adjustment to the heat rates, this would result in an absurdly high
2050 operating cost for the resource. While seemingly unlikely, this scenario did occur
2051 in the recent Wyoming case.

2052 **Q. WHAT FURTHER ADJUSTMENT IS NEEDED?**

2053

2054 A. In this case, it is necessary to adjust the heat rate curve so that it produces the
2055 same heat input at the derated maximum and minimum capacities, as the unit
2056 would actually experience in normal operation. The proper adjustment to the heat
2057 rate curve is as shown below:

2058

2059 **Heat Rate Curve Adjusted = A x (1-EFOR)+B x mW_h+ C/(1-EFOR) x mW_h²**

2060

2061

2062 **Q. HAVE YOU PREPARED AN EXHIBIT THAT PROVIDES A MORE**
2063 **DETAILED ANALYSIS JUSTIFYING THESE INPUT CHANGES TO**
2064 **GRID?**

2065

2066 A. Yes, Exhibit CCS 4.16 presents an example that further demonstrates why these
2067 adjustments are necessary. It shows that unless these adjustments are made to
2068 GRID it will overstate NVPC using a series of outage scenarios. The values for
2069 these adjustments are shown on Table 1.

2070

Station Service Modeling

2071

2072 **Q. EXPLAIN STATION SERVICE MODELING IN GRID.**

2073

2074 A. The Company proposes to include a zero revenue sales transaction in GRID to
2075 reflect station service requirements during plant outages, increasing NVPC.

2075

2076 **Q. IS THE PACIFICORP METHOD STANDARD INDUSTRY PRACTICE?**

2076

2077 A. No. Based on my experience in working with production cost models, this
2078 approach is quite novel and contrary to standard industry practice.

2078

2079 **Q. DOES THE COMPANY TREAT ALL STATION SERVICE**
2080 **REQUIREMENTS IN THIS MANNER?**

2080

2081 A. No. More than 99% of station service requirements are reflected in unit heat rates
2082 in GRID. Less than 1% of station service requirements are modeled via this zero

2082 revenue sales transaction. This is a negligible amount of station service and
2083 hardly worthy of a special adjustment. The vast majority of station service
2084 requirements occur when the plant is running, and there is no justification for
2085 treating a tiny fraction of station service requirements differently from the rest. It
2086 is the standard industry practice to reflect all station service requirements in heat
2087 rates because it really amounts to a reduction to the efficiency of generating
2088 plants.

2089 **Q. HOW DO YOU PROPOSE TO TREAT STATION SERVICE**
2090 **REQUIREMENTS IN GRID?**

2091 A. I recommend reflecting all station service requirements in the calculation of unit
2092 heat rates. This is a balanced approach because it does recognize the efficiency
2093 degradation associated with the additional energy requirements during outages.
2094 At the same time, it reflects the efficiency gains when units perform above their
2095 normal ratings. This adjustment is shown on Table 1.

2096 **IX. OTHER ISSUES**

2097 **Wind Integration Expense**

2098
2099
2100 **Q. HAS THE COMPANY MODELED WIND INTEGRATION COSTS IN**
2101 **GRID?**

2102
2103 A. Yes. The Company includes reserve requirements equal to 5% of on-line wind
2104 capacity for contingency (spinning) reserves. It has also modeled an additional
2105 cost of approximately \$1.1/MWh, based on an analysis contained on page 193 of
2106 Appendix J of the PacifiCorp 2007 IRP. This issue was discussed during the on-
2107 site interviews on February 14, 2008. We inquired as to why the Company
2108 modeled wind integration costs in two parts. It was explained that the GRID

2109 model computed the inter-hour reserve requirement, while the \$1.1/MWh charge
2110 was for intra-hour reserve requirements. Based on the analysis contained in the
2111 IRP, the intra-hour wind integration costs are equal to the additional cost.

2112 **Q. DO YOU AGREE WITH THIS APPROACH?**

2113 A. I do not question the IRP analysis at this time. However, the Company did not
2114 correctly apply the IRP findings to GRID. Page 192 of Appendix J to the IRP
2115 shows that the additional reserve requirements for the Company's planned 2000
2116 mW wind portfolio is equivalent to an increase in reserve requirements of 43 MW
2117 (or about 2% of installed wind capacity.) However, during the test year the
2118 Company will have far less than 1000 MW of wind capacity installed. The figure
2119 on page 192 of the Appendix J shows that for less than 1000 MW of wind
2120 capacity installed, the incremental reserve requirement is less than 1% of total
2121 capacity. The formula shown on Page 192 shows that if the lower reserve
2122 requirement is inserted into the equation, much lower wind integration costs
2123 result.

2124 **Q. IS THIS HOW YOU MODELED THESE ADDITIONAL WIND**
2125 **INTEGRATION COSTS?**

2126
2127 A. No. A much simpler approach is to increase the wind resource reserve
2128 requirement from 5% to 6%. So long as installed wind capacity is less than 1000
2129 MW there is less than a 1% change in overall reserve requirements due to intra
2130 hour effects. This correction results in the reduction to NVPC shown on Table 1.

2131

2132

2133 **Reserve Requirements for Non-Own Generators**

2134

2135 **Q. PLEASE EXPLAIN THIS ISSUE.**

2136 A. There are many independent generators inside PacifiCorp's control area and the
2137 Company is required to provide reserves for some of these generators. In some
2138 cases, the generators do not pay the Company for such reserves because they were
2139 reflected in the contract prices for generation provided, such as in the case of QFs.
2140 An issue arises because the Company has included the requirements for certain
2141 generators that self supply reserves, and/or who do not pay the Company for any
2142 reserves where the above stated exceptions don't apply. (See the response to CCS
2143 7.11). In these cases, the associated requirements should be removed from GRID
2144 because the generator doesn't require reserves from the Company and/or are not
2145 compensating the Company for the service. Table 1 shows the impact of
2146 correcting these inputs to GRID.

2147 **Transmission Wheeling Expense**

2148

2149 **Q. PLEASE EXPLAIN YOUR TRANSMISSION WHEELING EXPENSE**
2150 **ADJUSTMENTS.**

2151

2152 A. These adjustments (shown on Table 1) correct four problems in the transmission
2153 costs inputs. First, the Company includes a pro-forma adjustment for the
2154 Goodnoe wind facility for the entire test year. However, Goodnoe has been
2155 delayed and is not now expected to come online until June 2008. As a result, I
2156 removed that pro-forma until June 2008. The Company agreed that the Goodnoe
2157 pro-forma adjustment was incorrect in its response to CCS 21.1

2158 Second, the Company included escalations for several transmission
2159 contracts in the Test Year. Many of these reflect a BPA rate increase that took

2160 place in October 2007. However, the Company developed these escalations from
2161 a rather crude comparison of changes in individual rate components rather than
2162 billing out the actual charges as applied to its requirements.⁵⁸ Based on analysis
2163 of October and November 2007 actual data these escalations were overstated.

2164 Third, the Company acknowledged that it could not support the wheeling
2165 rate assumed in the Borah Brady transmission cost pro-forma adjustment.⁵⁹ I
2166 recomputed this charge based on a rate schedule obtained from the Idaho Power
2167 OASIS.

2168 Finally, I have included the benefit of transmission imbalance charges the
2169 Company collects from third party customers. Under the Company Open Access
2170 Transmission Tariff, the Company charges third party customers when their load
2171 exceeds resources or their load is less than resources. The imbalance charges are
2172 discounted below or marked up above the market price depending on whether the
2173 imbalance results in a purchase or sale. In the end, this amounts to a low cost
2174 source of energy for the Company, which it has not reflected in GRID. Exhibit
2175 CCS 4.17 is a copy of a data request WIEC 5.3 from the current Wyoming PCAM
2176 docket explaining this issue in more detail. I quantified this adjustment based on
2177 data for the 12 months ended December 31, 2007, but would agree to use a four-
2178 year average if the data becomes available.

2179 **Q. WERE THERE ANY OUTSTANDING DISCOVERY REQUESTS AT THE**
2180 **TIME YOUR TESTMONY WAS PREPARED?**
2181

⁵⁸ Telephone conference on March 26, 2008 with Dave Taylor and Hui Shu of the Company.
⁵⁹ Id. The Company provided the Idaho Power OATT in support of the pro-forma in CCS 21.2-2. However, this document contains no actual tariff charges. The Company indicated that the charges used were taken from the Idaho Power OASIS, but the current figures differed from those used by the Company.

2182 A. Yes. The Company's response to CCS 21.5 is late and not available when this
2183 testimony was prepared. CCS 21.5 dealt with modeling of transmission
2184 capabilities in GRID. Further, as a result of discovery posed in another state
2185 (Washington) it seems that the answer to another CCS request in this case was
2186 incomplete. CCS 2.11 requested the Company provide data on non-firm
2187 transmission flows. Based on the answers provided to CCS 2.10 and 2.11 it
2188 appeared that the Company did not have any such analysis and none was
2189 provided. However, we recently obtained a data response in the current
2190 Washington case, which did provide data concerning non-firm transmission
2191 flows. As a result, the Committee reserves the right to supplement my testimony
2192 should further inquiry into these transmission matters identify any significant
2193 issues.

2194

X. CONCLUSION

2195

2196

2197 **Q. PLEASE SUMMARIZE THE CONCLUSIONS OF YOUR TESTIMONY.**

2198

2199 A. I have presented a number of detailed adjustments to the GRID model study, and
2200 recommend the Commission adopt them to properly normalize net power costs.
2201 To provide some perspective, I would point out that while I have identified a
2202 number of adjustments my overall recommended reduction to NVPC is only
2203 about 5.7% of the Company's total request. Further, a significant number of my
2204 recommended adjustments relate to data input assumptions or normalization
2205 procedures rather than problems in the model logic itself. The table below
2206 summarizes the adjustments I recommend and categorizes them to model logic

2207 corrections, data corrections or other issues. Model adjustments are those related
2208 to correcting deficiencies in the model logic, such as those related to uneconomic
2209 generation. Data corrections are items that concern input assumptions. Other
2210 issues include disallowances of specific outages and the pricing of the SMUD
2211 contract.

Table 4
Summary of Adjustments

Basis	Total Co. \$	% of Request	% of Adj.
Model	(19,934,672)	-1.9%	33.5%
Data	(30,719,076)	-2.9%	51.7%
Other	(8,796,891)	-0.8%	14.8%
Total	(59,450,639)	-5.7%	100.0%

2212
2213 **Q. DOES THIS CONCLUDE YOUR TESTIMONY?**
2214 **A. Yes.**