

Exhibit CCS4.12
Comparison of Outage Rates 1999 to 2007.5

===== 2007.5 =====				1999	=Avg Capacity on Outage=		
Unit ID	Current Rated Capacity	Outage Rate	PacifiCorp Share	Outage Rate	2007 Case	1999 Case	
1	CHO-4	380	8.81%	100.0%	6.67%	33.5	25.3
2	COL-3	740	8.65%	10.0%	7.17%	6.4	5.3
3	COL-4	740	8.99%	10.0%	9.57%	6.7	7.1
4	CRB-1	70	10.29%	100.0%	7.51%	7.2	5.2
5	CRB-2	105	7.20%	100.0%	6.33%	7.6	6.6
6	CRG-1	428	7.01%	19.3%	2.40%	5.8	2.0
7	CRG-2	428	4.09%	19.3%	4.23%	3.4	3.5
8	DJ-1	106	6.12%	100.0%	4.93%	6.5	5.2
9	DJ-2	106	6.06%	100.0%	4.31%	6.4	4.6
10	DJ-3	223	8.16%	100.0%	13.62%	18.2	30.4
11	DJ-4	330	11.65%	100.0%	9.66%	38.4	31.9
12	HDN-1	184	6.21%	24.5%	6.43%	2.8	2.9
13	HDN-2	262	3.51%	12.6%	6.98%	1.2	2.3
14	HTG-1	440	11.10%	100.0%	10.22%	48.8	45.0
15	HTG-2	455	10.76%	100.0%	9.47%	49.0	43.1
16	HTR-1	427	9.98%	93.8%	8.97%	40.0	35.9
17	HTR-2	430	11.03%	60.3%	6.23%	28.6	16.2
18	HTR-3	460	11.92%	100.0%	6.35%	54.8	29.2
19	JB-1	530	12.74%	66.7%	7.35%	45.0	26.0
20	JB-2	530	14.16%	66.7%	6.57%	50.0	23.2
21	JB-3	530	15.69%	66.7%	8.93%	55.4	31.6
22	JB-4	526	15.48%	66.7%	8.06%	54.2	28.2
23	NTN-1	160	10.59%	100.0%	1.79%	16.9	2.9
24	NTN-2	210	9.08%	100.0%	3.90%	19.1	8.2
25	NTN-3	330	11.44%	100.0%	10.96%	37.8	36.2
26	WYO-1	335	6.37%	80.0%	5.05%	17.1	13.5
		Average	9.50%		7.06%	660.7	471.5
		Change	34.5%				
		mW Wtd.	10.82%		7.72%		
		Change	40.14%			40%	
		Units with Increasing outage rates			21		
		Total Number of Units			26		
		Percent			81%		
		Increase in Outage Capacity - mW				189.3	
		Savings per mW of added coal generation				\$294,104	
		Test Year Cost				\$55,663,277	
		Utah Allocation				42%	
		Utah Cost				\$23,378,576	