

UE-207/PacifiCorp
September 2, 2009
ICNU 10th Set Data Request 12.44

ICNU Data Request 12.44

Please refer to the response to ICNU 10.40 and 10.41. These responses refer to ICNU 1.53. Does the Company agree that the data referenced in this response (as pertains to Bridger), that some (if not all) of the entries were also provided in ICNU 1.70 in WUTC Docket No. UE-0902065? Does the Company also agree that ICNU 1.17 from the same WUTC docket indicated that the hourly unit data used in ICNU 1.70 was not a reliable measure of hourly unit generation.

Response to ICNU Data Request 12.44

Please refer to the Company's response to ICNU Data Request 12.41. The comment about "not a reliable measure" refers to the fact that a small amount of auxiliary load at the Jim Bridger plant is only captured on the plant basis, rather than on unit basis.