

1 **Q. Please state your name and business address.**

2 A. My name is Lowell E. Alt, Jr. My address is 1396 Wheelwright Court, Mesquite,
3 Nevada, 89034

4 **Q. On whose behalf are you testifying?**

5 A. I am testifying on behalf of Rocky Mountain Power Company (the Company), a
6 division of PacifiCorp.

7 **Qualifications**

8 **Q. Briefly describe your educational and professional background.**

9 A. I received a Bachelor of Science degree in Electrical Engineering and a Master of
10 Business Administration degree from West Virginia University where I became a
11 member of the electrical engineering honorary society Eta Kappa Nu. I am a
12 Registered Professional Engineer licensed in Pennsylvania and a member of the
13 Institute of Electrical and Electronics Engineers (IEEE). I have attended
14 numerous conferences and seminars on various aspects of utility regulation. I
15 retired in December 2005 as Executive Staff Director of the Utah Public Service
16 Commission after a twenty-five year career in Utah utility regulation. I served as
17 Director of the Utah Division of Public Utilities from March 2001 to August
18 2003, Manager of the Energy Section from October 1995 to March 2001, Chief
19 Engineer from 1983 to 1995 and Rate Engineer from 1980 to 1983. I have
20 testified before the Utah Public Service Commission in numerous electric, natural
21 gas and telecommunication cases on various topics including cost-of-service, rate
22 design, customer charges, interim rates, rate case stipulations, mergers, service
23 extensions and return on equity. I was the Division's witness on class cost of

24 service and rate design for every Utah Power rate case from 1983 to 1998. I have
25 completed numerous cost-of-service studies of various utilities including Utah
26 Power, U.S. West Communications, several rural electric cooperatives and two
27 water companies. I previously worked for Pennsylvania Power and Light
28 Company from 1968 to 1980. My last positions there were Distribution Senior
29 Engineer-Substations and Senior Tariff Analyst. Since my retirement in 2005 I
30 published a book, *Energy Utility Rate Setting*, and have done some utility
31 consulting. In April I attended the IEEE 2009 Rural Electric Power Conference,
32 including an all-day seminar on “Critical Elements in the Operation, Installation
33 and Maintenance of Power Transformers” conducted by Waukesha Electric
34 Systems.

35 **Q. Since this case deals with the classification and allocation of distribution**
36 **costs, please elaborate on your utility experience in distribution.**

37 A. I worked as a distribution substation engineer for ten years. During that time my
38 work included calculating substation power transformer thermal loading
39 capabilities; performing factory inspections of new substation power
40 transformers; inspecting failed substation power transformers; preparing
41 substation transformer (and other equipment) operation and maintenance
42 instructions for substation field people; teaching transformer theory, operation and
43 maintenance at substation repairman apprentice programs; and assisting in the
44 development of planning philosophies, major equipment purchases and
45 engineering designs.

46 **Purpose and Summary of Testimony**

47 **Q. What is the purpose of your testimony?**

48 A. The purpose of my testimony is to address classification and allocation issues
49 regarding distribution costs raised in the direct testimony of Mr. Paul Chernick on
50 behalf of the Office of Consumer Services (the Office).

51 **Q. Please provide a brief summary of your testimony.**

52 A. I explain the role of classification and allocation in class cost of service studies. I
53 give a brief history of the Company's Distribution Cost Allocation Study and the
54 classification and allocation of distribution costs. I describe the Company's use
55 of engineering standards and load data in making distribution transformer and
56 conductor investment decisions and how it relates to classification and allocation
57 of distribution costs. I explain why the Commission-approved classification and
58 allocation methods for distribution costs are still reasonable.

59 **Q. Mr. Chernick's position in his direct testimony is that the current**
60 **Commission approved method of allocating distribution costs does not**
61 **reasonably reflect cost causation. Do you agree?**

62 A. No. In order to explain why I do not agree, I will discuss classification and
63 allocation in cost of service studies, how the current approved classification and
64 allocation of distribution costs came about and why they are still reasonable.

65 **Role of Classification and Allocation in Cost of Service Studies**

66 **Q. What is the purpose of classification and allocation in cost of service studies?**

67 A. Most of PacifiCorp's costs of providing utility service are joint costs. Joint costs
68 are the costs of shared facilities such as distribution substations and lines that

69 serve multiple customers. These joint costs must be allocated among customer
70 classes using the facilities. In order to make the allocation step easier and more
71 accurate, a classification step is done first. Utility costs are booked into
72 functional accounts such as distribution station equipment (substations) and
73 overhead and underground lines. Classification is the further division of these
74 functional costs into categories bearing a relationship to a measurable cost-
75 defining service characteristic. Measurable means the service characteristic data
76 is available for use in the allocation step. Cost-defining means a cost-causal
77 relationship exists between the service characteristic and the utility costs to be
78 allocated. Electric utilities traditionally use the classification categories of
79 customer, energy, and demand. Once the costs are classified, they can be
80 allocated to customer classes. Allocation is the apportionment of joint costs
81 among rate classes based on each class's relative share of a measurable cost-
82 defining service characteristic such as kilowatt-hours or peak demand in
83 kilowatts. Costs classified as customer-related are allocated on the number of
84 customers, often weighted by some cost information. Energy-related costs are
85 allocated on relative energy usage. Demand-related costs are allocated on relative
86 demands.

87 **Q. How is a cost-causal link established?**

88 A. A cost-causal link between customer service characteristics and utility costs is
89 established when costs are allocated using service characteristics that are the same
90 or similar to that used by utility engineers in making investment decisions.
91 Sometimes the data used by engineers is not available by rate class or schedule, so

92 surrogate data must be used.

93 **Q. What is the difference between energy and demand costs?**

94 A. Demand-related costs are a function of a customer's maximum demand (measured
95 in kilowatts). This maximum demand is related to the electrical capacity of the
96 customer's connected appliances, since the maximum demand would occur when
97 all appliances are used at the same time. A utility must size the parts of its system
98 to handle the simultaneous peak demand from all its customers at any given hour.
99 Energy-related costs are a function of a customer's duration of use (measured in
100 kilowatt-hours) of any connected appliances. For example, a portable electric
101 heater rated at 1000 watts (equal to 1 kilowatt) would impose an electrical
102 demand of 1 kilowatt on the electric system each time it is turned on. If the heater
103 is left on for two hours, the energy use would be 1 kilowatt (demand) times 2
104 hours (duration) or 2 kilowatt-hours.

105 **Distribution Cost Classification and Allocation Background**

106 **Q. What is the current Commission approved classification and allocation of**
107 **distribution plant?**

108 A. 1. Substation equipment and primary lines are classified as demand and
109 allocated with a factor based on the 12 monthly distribution coincident peaks
110 weighted by the number of distribution substations peaking in each month.
111 2. Line transformers and secondary lines are classified as demand and
112 allocated with a factor based on schedule annual non-coincident peak (NCP)
113 times the design coincidence factor (which takes into account load diversity for
114 schedules with multiple customers on a single transformer).

115 3. Service drops are classified as customer-related and allocated using
116 average service drop cost (for each rate schedule) times the number of customers.

117 4. Meters are classified as customer-related and allocated using average
118 meter cost (for each rate schedule) times the number of customers.

119 **Q. How long has the current classification of distribution costs been approved**
120 **by the Commission?**

121 A. Since January 16, 1980 (over 29 years) when the Commission in Utah Power
122 Case No. 78-035-14 ordered distribution costs to be classified as demand-related
123 (meter and service drops were classified as customer-related).

124 The Commission reaffirmed that classification of distribution costs in its
125 April 12, 1982 order in Utah Power Case No. 79-035-12 and again in its March 7,
126 1983 order in Utah Power Case No. 81-035-13 when it adopted for future use the
127 Division's classification of distribution costs. The Commission stated its intent of
128 the 1983 order is to provide guidelines and policies for future cost of service
129 studies. The Commission further ordered, "...any party who proposes alternative
130 methods, except those specified in this Order for further study, will have the
131 burden to demonstrate that the methods adopted in this Order are unreasonable".

132 **Q. How long has the current allocation of distribution costs been approved by**
133 **the Commission?**

134 A. Since February 9, 1990 (more than 19 years) when, in Utah Power Case No. 89-
135 035-10, the Commission adopted the Company's Distribution Cost Allocation
136 Study allocation methods.

137 **History of the Distribution Cost Allocation Study**

138 **Q. What prompted the Company's Distribution Cost Allocation Study?**

139 A. In Utah Power Case No. 81-035-13 the Division recommended further study to
140 determine proper allocation methods for distribution costs. The Commission in
141 its March 7, 1983 Order in that case stated, "The Company shall develop in
142 consultation with the Division an allocation method that takes into account the
143 design characteristics of the distribution system."

144 **Q. What happened next?**

145 A. In Utah Power Case No. 83-035-01, the allocation of distribution costs was still
146 unresolved with the Division again recommending further study. The
147 Commission in its January 30, 1984 Order directed the Company to conduct a
148 study to determine the proper allocation of distribution costs and to submit the
149 study by January 1985.

150 The Company filed its "Distribution Cost Allocation Study" on January
151 15, 1985. Although the Commission's directive was to determine the proper
152 "allocation" of distribution costs, the Company also addressed the "classification"
153 of distribution costs and confirmed the Commission's 1980, 1982 and 1983
154 classification decisions.

155 In the next Utah Power Case No. 84-035-01, parties presented testimony
156 on the Distribution Cost Allocation Study with the Committee claiming that as
157 much as 20 percent of transformer costs should be classified as energy-related and
158 allocated accordingly. The Commission, in its June 7, 1985 Order stated, "The
159 distribution study was also challenged by the Committee of Consumer Services

160 and the Irrigation Pumpers Association. We believe that a strong and sufficient
161 case was made for the reasonableness of the distribution study by the stipulating
162 parties; however, we will permit additional consideration of this issue in a future
163 proceeding.”

164 In Utah Power Case No. 85-035-06, parties reexamined the Distribution
165 Cost Allocation Study. An exchange of ideas in that case, including input from
166 the Committee, and further work on the study resulted in the final version of the
167 Distribution Cost Allocation Study being submitted in October 1989.

168 **Q. When did the Commission finally adopt the Distribution Cost Allocation**
169 **Study Recommendations?**

170 A. In Utah Power Case No. 89-035-10, the Distribution Cost Allocation Study was
171 again considered. So after 6 years of study and review in multiple cases, the
172 Commission in its February 9, 1990 Order adopted the Distribution Study
173 allocation methods for future cost of service studies. Those allocation methods
174 are the ones used for the past 19 years.

175 **Q. Were you involved in reviewing the Distribution Cost Allocation Study?**

176 A. Yes. I was the Division witness on this issue in all cases that it was considered
177 and testified in support of the final Distribution Cost Allocation Study
178 recommendations regarding distribution cost allocation.

179 **Q. Are you still supportive of the Distribution Cost Allocation Study**
180 **recommendations regarding distribution cost classification and allocation?**

181 A. Yes. I believe the Distribution Cost Allocation Study was an excellent
182 comprehensive study that involved a significant effort and considerable

183 examination and review by parties and the Commission over a period of 6 years.

184 **Company Distribution Investment Decisions**

185 **Q. Although you believe the Distribution Cost Allocation Study was an excellent**
186 **study, have you recently reviewed how the Company's engineers make**
187 **distribution investment decisions?**

188 A. Yes. As I stated earlier, the cost-casual link between customer service
189 characteristics and utility costs is established when costs are allocated using
190 service characteristics that are the same or similar to that used by utility engineers
191 in making investment decisions. The classification and allocation of distribution
192 costs should be based on a similar type of analysis. The important information
193 then is what distribution design engineers use in making investment decisions,
194 since that information is the cost-causer.

195 Even though the burden of proof is on the Office as the party seeking a
196 change in the allocation of distribution costs, I decided to review the current
197 process used by Company engineers in making distribution investment decisions,
198 specifically for transformers and conductors. I reviewed the engineering
199 standards, process and data used by the Company to design the distribution
200 system to determine the importance of energy and demand in design decisions. I
201 also talked with some of the Company's distribution engineers. The purpose was
202 to learn if anything has changed that would affect distribution cost classification
203 and allocation in the 20 years since the final Distribution Cost Allocation Study. I
204 will start with distribution substations in discussing what I learned about the
205 Company's distribution investment decisions.

206 **Distribution Substations**

207 **Q. Please describe how customer loads affect distribution substation design?**

208 A. Substations must be designed to handle the maximum simultaneous load of the
209 connected customers. The largest piece of equipment in a distribution substation
210 and also the most costly is the power transformer used to step down transmission
211 voltage to distribution primary line voltage. The Company's cost of a new typical
212 distribution substation transformer (18/24/30 MVA, 138,000 volts to 13,200
213 volts) in Utah is about \$900,000, not including installation. The other substation
214 equipment is then designed to coordinate with the load capability of the power
215 transformer.

216 The load capability of transformers is limited by the temperature of
217 insulating oil and the hottest spot within the windings, which are a function of the
218 load and ambient temperature. Transformer nameplate capacity (MVA) is based
219 on an average ambient temperature of 30 degrees Celsius (86 degrees Fahrenheit)
220 and represents the continuous load that the transformer can carry and last a
221 normal life of about 40 years. Since transformers rely on air as a heat dissipation
222 medium, higher altitudes with less air density result in reduced thermal capability.
223 So in summation, the load-carrying capability of a transformer is a thermal
224 capability and is primarily dependent on the electrical load, the ambient
225 temperature, and the altitude.

226 Power transformers are a large mass of metal and oil. It can take a few
227 hours for this mass to reach a steady state temperature once a given load is
228 applied. Each transformer has its own set of characteristics (weight of the mass of

229 metal and oil; no load and load losses; and average winding temperature rise).
230 These characteristics are used, together with load data, in calculating the thermal
231 load capability of a specific transformer. The total energy in kilowatt-hours of the
232 applied load is not an input, because it does not provide the needed information
233 about the peak load or the off-peak load and the respective durations. For
234 calculating the thermal capability of a specific transformer, the key data is the
235 peak load and its duration. Transformer nameplate capacity is stated in either
236 KVA or MVA (measures of demand), not kilowatt-hours.

237 **Q. What did you learn about how the Company sizes distribution substation**
238 **power transformers and how does it relate to cost allocation?**

239 A. PacifiCorp's Distribution System Planning Study Guide 1E.3.1 under "Substation
240 Transformers" and "New transformer sizing", states "Transformer sizing is
241 subject to an economic evaluation. Often the economic evaluation will result in a
242 transformer at least two standard ratings larger than the projected peak load." The
243 economic evaluation takes into account the expected load growth which may
244 justify a larger transformer size initially rather than replacement a short time later.
245 In this case, even with a load cycle that likely would be projected to be the same,
246 a transformer two sizes larger is selected due to projected peak load growth.
247 Although altitude, average ambient temperature and load cycle are taken into
248 account, it is clear that the projected peak load (including growth) is the key
249 driver in sizing substation transformers and therefore the key cost-driver of
250 substation equipment. Peak load is demand and therefore the current demand
251 classification of distribution substations is reasonable.

252 In making distribution substation investment decisions, engineers use
253 peak-loading on individual substations that is not available by rate schedule so
254 surrogate data must be used in the allocation step.

255 The Company has over 300 distribution substations and many more
256 primary lines in Utah with each having its own unique mix of customer types and
257 loads. The substations are geographically diverse with varying ambient
258 temperatures (like Park City and St. George). This means that the loads on
259 individual substations may peak in different seasons, months, days of the week or
260 hours of the day. The substations may have varying load cycles (differing
261 durations and load levels for peak and off-peak periods). The cost of these
262 substations is aggregated in distribution accounts for allocation to rate schedules.
263 The wide variation in the nature of the large number of distribution substations
264 makes developing the ideal cost allocator very difficult.

265 The Distribution Cost Allocation Study found after evaluating many
266 possible allocators, that a factor based on the 12 monthly distribution coincident
267 peaks, weighted by the number of substations peaking each month, was the best
268 allocator. The 12 monthly coincident distribution peaks are developed from load
269 research data since actual coincident distribution peaks are not measured. The
270 coincident distribution peaks are not used by engineers in substation design,
271 because each substation is a unique subset of the whole distribution system and
272 must be designed to handle the peak loads connected to it. The sum of the 12
273 coincident distribution peaks developed from load research data is merely an
274 information surrogate that captures the relative peak loads of the different

275 distribution level rate schedules for the aggregated distribution system. The
276 statistical analysis used in the Distribution Cost Allocation Study provided
277 evidence of a strong relationship between the allocator and the simulated
278 equipment peaks in the study. It was this strong relationship together with
279 evidence of good accuracy in matching shares of equipment peaks for each rate
280 schedule that resulted in the allocator's recommendation. The substation
281 weighting factor is based on recent actual measured substation monthly peak
282 loads, like those used by distribution design engineers.

283 **Distribution Primary Lines**

284 **Q. What did you learn about the design of distribution primary lines and how**
285 **does it relate to cost allocation?**

286 A. PacifiCorp's Engineering Handbook, section 1B.10, "Line and Feeder Design
287 Criteria" states on page 3 under the heading "Conductor Sizing", "Main line
288 distribution circuit conductors shall be of adequate size to serve the normal circuit
289 load and shall have a limited reserve capacity margin above the expected peak
290 loading requirements." Also, "Circuit main line conductors shall be scheduled for
291 replacement when normal peak loading, based on forecasts from actual field
292 measurements, exceeds 85 percent of the conductors thermal rating as specified in
293 PacifiCorp's Distribution Construction Standards."

294 I learned from PacifiCorp's Engineering department that primary line
295 conductor size selection is based on an economic analysis over the estimated 30
296 year life of the line. I learned the key determinants are the estimated initial peak
297 load (load current in amperes) and the forecast load growth rate. The initial

298 conductor size selection is important because the Distribution System Planning
299 Study Guide 1E.3.1 states, “Costs for reconductoring often are much higher than
300 for constructing a new pole line.” “Reconductoring may involve significant
301 reconstruction of the pole line including replacement, and in some cases
302 relocation of many of the poles.” “When selecting a new conductor, use the
303 economic size, not the minimum size to carry the load. Once the work is
304 required, the lowest total ownership cost for the new line should be the important
305 factor, not the lowest first cost.”

306 The reduction of load losses may affect the conductor size selection, but
307 forecast high load growth may more likely justify a larger conductor size because
308 of the high cost of future reconductoring. Estimates of costs of new line
309 construction and reconductoring are included in PacifiCorp’s Engineering
310 Handbook, sections 2P.3 and 2P.4. For example, the estimated total (material &
311 labor) installed cost per mile of new three-phase overhead 4/0 lines under difficult
312 urban circumstances is \$265,427. The comparable reconductoring cost per mile is
313 \$336,703.

314 The conclusion is that the sizing of primary lines is likely to be determined
315 by the forecasted initial peak load and the forecasted growth in peak load.
316 Therefore the current demand classification of primary lines is reasonable. The
317 key load data engineers use for sizing primary lines is peak load in amperes on
318 feeders measured at substations. This data is not available by rate schedule so
319 surrogate data must be used in the allocation step. As discussed under
320 Distribution Substations, there are many more primary lines than substations and

321 they too possess a wide variation in the mix of types of customers and loads. The
322 cost of these primary lines is aggregated in distribution accounts for allocation to
323 rate schedules. The wide variation in the nature of the large number of
324 distribution primary lines makes developing the ideal cost allocator very difficult.
325 The Distribution Cost Allocation Study found after analyzing several possible
326 allocators, that a factor based on the 12 distribution coincident peaks, weighted by
327 the number of substations peaking each month, was the best allocator.

328 **Distribution Line Transformers**

329 **Q. What did you learn about the design of distribution line transformers and**
330 **how does it relate to cost allocation?**

331 A. Line transformers step primary voltage down to secondary levels for use by
332 customers. The residential class has an average of about 6 customers per line
333 transformer while most other classes (except small commercial with an average of
334 2) normally have a single customer connected to a line transformer. Like
335 substation power transformers, line transformers are thermally limited in load
336 carrying capacity, which is affected by the ambient temperature, the electrical
337 load, and the altitude.

338 PacifiCorp has three engineering standards used in sizing line
339 transformers: General Residential Electrical Demand DA411, Padmounted
340 Transformers-Sizing Criteria GH011, and Overhead Transformers-Sizing Criteria
341 EL021.

342 Standard DA411 is used to determine the peak demand (in kilowatts) for
343 single family and multiple family dwelling units based on connected electric

344 appliances. Standard DA411 also contains the summer and winter design
345 coincidence factors that account for the diversity of loads when multiple
346 customers are connected to a single line transformer. The coincident peak
347 demand is then used to determine the transformer size using a table with different
348 KVA sizes and respective load capability based on summer and winter ambient
349 temperatures.

350 Standard GH011 for padmounted transformers refers to Standard DA411
351 for determination of the peak demand for residential customers and uses the same
352 transformer sizing table. For non-residential loads this standard refers to standard
353 EL021 for overhead transformers for specific sizing guidelines.

354 Standard EL021 for overhead transformers refers to DA 411 for
355 determination of the peak demand for residential customers and uses the same
356 transformer sizing table. For non-residential, a table is provided with three sets of
357 transformer load capability data for three different preloads (50 percent, 75
358 percent & 90 percent of nameplate) with each set including load capabilities for
359 different ambient temperatures and peak load periods. These preload levels
360 represent continuous loading exclusive of peak load. Exhibit RMP___(LEA-1R)
361 shows that for a 50 KVA transformer and an 8 hour peak period, increases in the
362 preload have a small effect on the load capability while increases in the ambient
363 temperature have a much larger impact. The difference in average ambient
364 temperature and even altitude for different customers has not been taken into
365 account in allocation of transformer costs even though these parameters affect
366 transformer sizing. I believe the reason is that the key cost driver is peak demand.

367 When sizing a transformer for a bigger preload, a larger size may not be needed
368 depending on the customer's peak load. Further, the exhibit shows that even if
369 the next size line transformer is required, the incremental cost is small. The
370 conclusion is that the key cost driver for line transformer investment is customer
371 peak demand. Therefore the current demand classification of line transformers is
372 reasonable. The Distribution Cost Allocation Study's recommended allocation
373 factor for line transformers of the annual schedule non-coincident peak times the
374 design coincidence factor is very close to the type of data engineers use and was
375 found by the study to be the best allocator. Therefore the current allocation
376 method is reasonable.

377 **Distribution Secondary Lines**

378 **Q. What did you learn about the design of distribution secondary lines and how**
379 **does it relate to cost allocation?**

380 A. Secondary lines are used primarily to serve residential customers since frequently
381 several residential customers are served from the same line transformer (currently
382 an average of 6 per transformer). The secondary lines eliminate the need for the
383 very long service drops that would be needed to connect each customer directly to
384 the shared line transformer. So in essence the secondary lines are an extension of
385 the secondary voltage side of the line transformer and should be classified and
386 allocated the same.

387 Standard DA411, for determining residential demand, provides several
388 examples of sizing distribution line transformers to serve residential loads. Each
389 example uses common residential appliance demands together with a table of load

390 capabilities for various transformer sizes and ambient temperatures. The standard
391 states that these calculated coincident peak demands are used in determining the
392 transformer “and secondary sizes”. So the load data engineers use to size
393 secondary lines is the same as that used to size line transformers, and therefore,
394 using the same classification and allocator is reasonable.

395 Standard ES001, Overhead Secondary-General Information, states
396 “Overhead single phase secondaries shall be installed when service requirements
397 to one or more customers will require more than one span of low voltage
398 conductors (service drop) or when the maximum allowable length of the service
399 conductors will be exceeded.” (Due to voltage drop) And “When constructing
400 new lines in urban areas where many homes are served from the line, this cable
401 can be an economical method of providing service. Because the economical
402 choice between using secondary cable or using multiple transformers varies in
403 each situation, cost comparisons should be made between the two alternatives
404 before finalizing a cost estimate.” The standard lists several situations that favor
405 the economics of using secondary aerial cable instead of installing additional
406 transformers.

407 Standard ES001, under the heading, “Conductor Size Selection for
408 Overhead Secondary” lists the first rule as, “Determine customers total peak
409 demands and calculate load current with a possible load growth rate for the next 5
410 to 10 years.” Then it says to use Table 2 in Standard ES011 (which lists physical
411 characteristics and ampacity for 1/0 and 4/0 conductors) to “...select a secondary
412 conductor to carry this amount of load current.” Expected peak load current is the

413 key cost driver here.

414 Standard GS001, Underground Secondary and Service-General
415 Information lists steps in selection of cable size. For residential the first step is to
416 use Standard DA411 to determine customer's peak demand and load factor and
417 then use a graph in Underground Secondary and Service-Residential Economical
418 Service Cable Selection Standard GS041 to determine the economical cable size.
419 A typical residential load with A/C might have 10 to 13 kilowatts of peak demand
420 and an annual load factor of about 40 percent per Standard DA411. For a demand
421 of 10-13 kilowatts, using the graph in Standard GS041, load factor has no impact
422 on the cable size selection. In fact, for a peak demand of 13 kilowatts, the same
423 underground cable size would be selected for the complete range of load factors
424 of 20 to 80 percent. Again the conclusion is that peak demand is the key cost
425 driver for secondary lines, and therefore, the current demand classification for
426 secondary lines is reasonable.

427 In conclusion, the current approved demand classification for secondary
428 lines is reasonable and also the current approved allocation method is reasonable
429 as it is the same as that for line transformers.

430 **Distribution Service Drops**

431 **Q. What about service drops?**

432 A. Service drops connect customers either directly to a line transformer or to
433 secondary lines that are connected to a line transformer. Service drops are
434 classified as customer related (even though they are sized based on demands
435 similar to secondary lines) since every customer needs one (although as Mr.

436 Chernick has pointed out some are shared) and allocated using average service
437 drop cost (for each rate schedule) times the number of customers. I believe the
438 current customer classification for service drops is reasonable. The current
439 allocation factor may need to be modified as new information becomes available.

440 **Distribution Classification and Allocation Issues**

441 **Q. What are Mr. Chernick's issues regarding the allocation of distribution**
442 **costs?**

443 A. He says the monthly weighting factors used in deriving the allocation factor for
444 substations and primary feeders are not cost-based and that the current approved
445 allocation method overlooks many of the ways that periods of high energy use
446 drive distribution investment.

447 **Q. Mr. Chernick, on page 25 of his direct testimony, cites your rebuttal**
448 **testimony in Docket No. 07-035-93. Has he correctly characterized your**
449 **testimony?**

450 A. No. He states "Lowell Alt acknowledged that duration of peak, load cycle, and
451 on-peak energy are all cost-causal factors." First, I did not use the phrase "on-
452 peak energy" in my testimony, nor did I use the phrase "cost-causal factors"
453 together with "duration of peak" or "load cycle". Second, my use of "duration of
454 peak" on page 11 referred specifically to information needed in the calculation of
455 the thermal capability of a specific power transformer.

456 He further quoted my testimony (on page 11) stating "The key data are the
457 peak load and its duration" and said that it was with regard to substation sizing.
458 This is incorrect. This quote specifically related only to the data needed to

459 calculate the thermal capability of a specific power transformer. The relevant
460 statement from my testimony is on page 12 where I draw my conclusions
461 regarding distribution substation investment decisions, “Although altitude,
462 average ambient temperature and load cycle are taken into account, it is clear that
463 the projected peak load (including growth) is the key driver in sizing substation
464 transformers and therefore the key cost-driver of substation equipment”.

465 **Q. Does the Distribution Cost Allocation Study discuss how the current**
466 **substation weighting factors method came about?**

467 A. Yes. The October 21, 1989 Distribution Cost Allocation Study report states on
468 page 39:

469 A suggestion was made by a consultant for Committee of Consumer
470 Services that the number of equipment peaks by season be used to
471 weight the CDP’s (Coincident Distribution Peaks) to capture seasonal
472 variation. The only equipment peaks available from normal records
473 were the substation peaks shown in Table No. 5. These figures show
474 considerable variation by location as well as by season. The use of
475 the substation peaks produce a very practical weighting which
476 accounts for both geographic variance and seasonal factors. In
477 addition, since the weighting factor can be measured easily each year,
478 shifts in loading patterns are captured. Finally, they offer a good
479 surrogate for the equipment peaks which approximate the “ideal
480 allocator.

481 The report went on to say that ten formulations of the CDP were ranked using the
482 r^2 statistic, the percent error, and the allocation fraction measures and that the
483 monthly substation weighted formulation was best over all.

484 **Q. When you were the Division witness in the 1989 case, what were your reasons**
485 **for supporting the substation weighted 12 coincident distribution peaks**
486 **allocator for substations and primary lines?**

487 A. Following is my October 23, 1989 filed testimony in Case No. 89-035-10 on that
488 question:

489 Cost causation is the guiding principle in selecting allocators. In this
490 Case we met with some of the Company's distribution engineers and
491 discussed the key information used by them in making distribution plant
492 capacity decisions. We learned that coincident demands on distribution
493 circuits (as measured at distribution substations) are the key data used in
494 making capacity change decisions. We also learned that distribution
495 circuits and substations may peak in any month. Since actual load data is
496 not available by rate schedule, load research data has been used by the
497 Company to develop coincident distribution demands by rate schedule.
498 The next step in selecting an allocator is determining which form of the
499 available load data best matches the load data used by the design
500 engineers. This is where the Company's Distribution Study is important.
501 The Distribution Study basically used actual data from a previous
502 transformer study to simulate with a computer the peak loads on
503 distribution substations, circuits and line transformers. In Case No. 85-
504 035-06, the Company presented testimony and exhibits that used three
505 criteria for selecting the allocator that best matched the computer
506 simulated equipment peaks in the Distribution Study. These criteria
507 were the R^2 (coefficient of determination), the absolute error and the
508 percentage error. I selected the monthly substation weighted 12
509 coincident distribution peaks method for four reasons. First because I
510 believed it was similar to the load data used by distribution design
511 engineers. Second, it had a high R^2 value when regressed against the
512 Distribution Study equipment peaks. Using the Company's Exhibit
513 SLW-1R.2 in Case No. 85-035-06, the range of R^2 values for the ten
514 distribution allocators developed by Mr. Walton was 0.9729 to .9997
515 (maximum=1.0). The R^2 value indicates the significance of an
516 independent variable in explaining variations in the dependent variable.
517 These values are all quite high and nearly equal and suggest that another
518 method be used to select the best allocator. Third and more important,
519 the highest average ranking based on the percentage error criterion was
520 for the monthly substation weighted 12 coincident distribution peaks.
521 Fourth the monthly substation weighted 12 coincident distribution peaks
522 includes both the summer and winter seasons as well as the remaining
523 off season months. I believe the use of the number of monthly substation
524 peaks as weights is reasonable as it decreases the weight given the off-
525 season months while still including them.

526 **Q. Do you agree with Mr. Chernick's concern about the weights used in the**
527 **allocation factor for substations and primary lines?**

528 A. No. The approved allocation factor uses the 12 monthly coincident distribution
529 peaks multiplied by a weighting factor based on the number of distribution

530 substations that peak in each of the twelve months. The substation weighting
531 factor is based on recent actual measured substation monthly peak loads.

532 With over 300 distribution substations in Utah, small changes would not
533 impact the overall weighting. The sum of the 12 monthly coincident distribution
534 peaks basically weights each of the 12 months the same. By using the substation
535 weights, peak months get additional weighting and off-peak months less. The
536 month of the coincident distribution peak is really not relevant in substation
537 investment decisions, because each substation must be considered on its own.
538 The relevant task is to select an allocator that is reasonably accurate, using
539 surrogate data (since actual data by rate schedule does not exist) to allocate the
540 aggregated costs. As I explained earlier, developing an ideal allocator for the
541 aggregated costs of over 300 unique substations and far more primary lines is
542 difficult. This is one of the reasons as a Division witness I originally
543 recommended that the issue be studied. I think the comprehensive analysis done
544 in the Distribution Cost Allocation Study, and the related review and refinement
545 over a 6 year period, accomplished that.

546 **Q. Mr. Chernick states that the substation weighting method can produce**
547 **illogical results. Do you agree with his example?**

548 A. No. He cites data from Docket No. 07-035-93 saying June and July had higher
549 weights than August even though August was the month of the coincident
550 distribution peak. I addressed this same issue in that docket with an exhibit which
551 I have included here as Exhibit RMP___(LEA-2R). In this exhibit, I used Mr.
552 Chernick's spreadsheet from that docket (Attachment CCS 10.28) as a starting

553 point to examine the actual substation monthly peak loads for the months of June,
554 July and August. I eliminated all substations for which loads were not available
555 for all twelve months. I sorted all data by peak month. Then I calculated the
556 difference between the load in the peak month and each of the other two months
557 and summed the columns of differences. The results show that the substations
558 that peaked in July had a total load of 159,299 kilowatts in July more than the
559 same substations did in August. The July peaking substations had a total load of
560 223,675 kilowatts in July more than the same substations did in June.

561 Next the results for the August peaking substations showed that they had a
562 total load of 12,584 kilowatts more than the same substations did in July and
563 33,109 kilowatts more than the same substations did in June.

564 Lastly the results for the June peaking substations showed that they had a
565 total load of 51,976 kilowatts more than the same substations did in July and
566 76,580 kilowatts more than the same substations did in August.

567 The conclusions drawn from this actual data mean that July was far more
568 important in terms of cost causing peak load than either June or August. The total
569 numbers are not close. It also means that June is more important than August as
570 its total kilowatts load difference over August was 76,580 kilowatts compared to
571 only 33,109 kilowatts for August over June (a net difference of 43,471 kilowatts).

572 **Q. Do you agree with Mr. Chernick's concerns that the current approved**
573 **allocation method overlooks many of the ways that periods of high energy**
574 **use drive distribution investment?**

575 A. No. In my review of the Company's distribution engineering standards, process

576 and data used, I found, as discussed earlier, that all distribution plant, except
577 meters and service drops, should be classified as demand and that the key driver
578 in the investment decisions was peak demand. He says the number of high load
579 hours drives investment in redundant equipment, but provides no evidence. I
580 found no evidence of this in my review of the engineering standards. He says all
581 energy in high-load hours adds to heat buildup and results in a reduction of the
582 ability of transformers to survive brief load spikes on the same day. As I
583 discussed earlier, substation power transformers are a huge mass of metal and oil
584 that results in a time lag of hours before the effect of “brief load spikes” even take
585 effect. He says that distribution investments, such as increases in the sizing of
586 transformers, are made to reduce energy load losses. I found no evidence to
587 support this statement in the Company’s current engineering standards. The cost
588 of load and no-load losses in transformers are taken into account in the evaluation
589 of bids during purchase decisions.

590 **Summary**

591 **Q. What do you conclude from your analysis of Mr. Chernick’s distribution cost**
592 **classification and allocation issues?**

593 A. The bottom line here is that the Distribution Cost Allocation Study was a
594 comprehensive study that extensively analyzed numerous possible distribution
595 allocation factors before settling on the recommended allocators as the best. It
596 was reviewed by many parties, including the Committee (Office), and refined
597 over several years before being approved by the Commission. Mr. Chernick has
598 completed no such comprehensive analysis, but only suggests there is a better

599 way. The Distribution Cost Allocation Study Report contains 42 pages plus
600 extensive exhibits. Mr. Chernick presents about 3 pages of discussion of why the
601 current allocation methods should be changed. He offers no alternative
602 comprehensive study, no specific recommendations regarding alternative
603 allocation methods and very little evidence to support his claim that the current
604 methods do not reasonably reflect cost causation. My review of the Company's
605 use of engineering standards and load data in making distribution transformer and
606 conductor investment decisions indicates that peak demands are clearly the key
607 driver in those decisions. This establishes a cost-causal link between customer
608 peak demands and distribution costs. Therefore I conclude that the current
609 Commission approved classification and allocation of distribution costs is
610 reasonable and need not be changed. The Commission decided the classification
611 of distribution plant over 29 years ago with all distribution costs as demand-
612 related except for meters and service drops. The Commission decided the
613 allocation of distribution plant over 19 years ago. The Commission has not
614 changed those decisions. The burden of proof is on any party seeking a change. I
615 do not believe the Office has met that burden and based on my research of
616 PacifiCorp's distribution investment decision process, I believe the current
617 Commission approved distribution classifications and allocation methods are
618 reasonable.

619 **Q. Does this conclude your rebuttal testimony?**

620 A. Yes.