

D. Matthew Moscon (#6947)
Richard R. Hall (#9856)
Stoel Rives LLP
201 South Main Street, Suite 1100
Salt Lake City, Utah 84111-4904
Telephone: (801) 328-3131

R. Jeff Richards (#7294)
Rocky Mountain Power
201 South Main Street, Suite 2200
Salt Lake City, Utah 84111
Telephone: (801) 220-4734

Attorneys for Petitioner
Rocky Mountain Power

BEFORE THE UTILITY FACILITY REVIEW BOARD

ROCKY MOUNTAIN POWER,

Petitioner,

vs.

TOOELE COUNTY,

Respondent.

**DIRECT TESTIMONY OF
DARRELL T. GERRARD**

1 **BACKGROUND OF WITNESS**

2
3 **Q. Please state your name, business address, and present position.**

4 A. My name is Darrell T. Gerrard. My business address is 825 NE Multnomah Boulevard,
5 Portland, Oregon 97242. I am currently employed as Vice President—Transmission
6 System Planning for PacifiCorp. I have held my present position since May 2007.

7
8 **Q. What are the primary duties of your present position?**

9 A. The primary duties of my present position include management and oversight of all Main
10 Grid Transmission System Planning requirements for both Rocky Mountain Power and
11 Pacific Power, which are operating units of PacifiCorp. (PacifiCorp and Rocky Mountain
12 Power are referred to herein as the “Company.”) My responsibilities include ensuring
13 that proper planning activities are performed as necessary for the Company’s large
14 transmission system. I am also responsible for the conceptual design and ongoing
15 electrical transmission system planning required to support the Company’s Energy
16 Gateway Program.

17
18 **Q. Please describe your education and business experience.**

19 A. I have a Bachelor of Science degree in Electrical Engineering from the University of
20 Utah. My experience spans more than 30 years in the electric utility business and electric
21 industry in general. I have experience in and have been responsible for a number of
22 functional organizations at the Company, including Area Engineering, Area Planning,
23 Region Engineering, Transmission & Distribution Facilities Management, Transmission,
24 Substation and Distribution Engineering, System Protection and Control, Transmission &
25 Distribution Project Management and Delivery, Asset Management, Electronic
26 Communications, Hydro System Engineering, Transmission Grid Operations, and most
27 recently Transmission System Planning.

28

1 **PURPOSE AND SUMMARY OF TESTIMONY**

2

3 **Q. What is the purpose of your testimony?**

4 A. My testimony will demonstrate the need in the immediate future for the construction of a
5 new transmission line from the existing Mona substation west of Mona to the existing
6 Oquirrh substation located in West Jordan, with an additional proposed substation
7 (Limber) in the southwest portion of the Tooele Valley and an additional transmission
8 line extending from the future Limber substation to the existing Terminal substation near
9 the Salt Lake International Airport (the “Transmission Project” or the “Project”) to ensure
10 safe, reliable, adequate, and efficient delivery of electricity to the Company’s
11 Customers.¹

12

13 The overall Project was developed to minimize transmission line length and maximize
14 reliability. Mr. Brandon Smith’s testimony, filed concurrently herewith, will demonstrate
15 how these criteria have been applied to minimize the Project costs and impacts on
16 communities.

17

18 **Q. Please summarize your testimony.**

19 A. In summary, the Transmission Project is needed to support both short- and long-term
20 energy demands and will strengthen the overall reliability of the Company’s existing
21 transmission system. Currently, the existing transmission system, of which the Project
22 will be a part, has limited capability to deliver energy into the largest load center in Utah,
23 which is identified in this testimony as the “Critical Load Area,” and which includes all
24 or portions of Salt Lake, Tooele, Utah, Davis, Weber, Cache, and Box Elder Counties.
25 See Exhibit DTG-1 (Critical Load Area).

26

27 Electricity used within the Critical Load Area is generated primarily from power plants
28 located in central and southeastern Utah and transmitted to the Critical Load Area via

¹ “Customers” as used in this Testimony shall be defined to include all retail and network customers of the Company.

1 high voltage transmission lines. Due to current and expected growth within the Critical
2 Load Area, the existing transmission capacity north of the Mona substation (located in
3 Juab County) is fully subscribed and is expected to be operating near or at its design
4 capacities in the near future. By 2013, the Company will be unable to serve its existing
5 Customers in Tooele County in the Critical Load Area, including Tooele County, meet
6 load service obligations under its FERC tariff and will not be able to maintain compliance
7 with North American Electric Reliability Corporation (“NERC”) Reliability Standards.
8 Additional transmission capacity is required to meet the Company’s load service and
9 contract obligations to its Customers, as well as third party point-to-point customers, for
10 the long term.

11
12 By constructing the Transmission Project, overall reliability of the transmission system
13 will be improved by adding incremental new transmission capacity northbound and
14 southbound between the Company’s power plants in Utah and other sources of energy in
15 the Four Corners Region and the Desert Southwest. Because the Project increases the
16 existing transmission capability from the Mona area to the Critical Load Area, the system
17 will have improved capability to integrate new generation resources from central and
18 southern Utah, and will provide improved connection to markets in the Desert Southwest
19 and Four Corners Region, and other markets available through interconnections at Mona.
20 *See Exhibit DTG-2 (Major Transmission Paths Serving Utah).*

21
22 Utah is currently one of the fastest growing states, and projections indicate that it will
23 continue to grow rapidly for decades. Staying ahead of future electric demand is
24 therefore critical in meeting the electric demand of the Company’s Customers. In
25 addition to meeting the Company’s Customers’ future energy requirements, the
26 Transmission Project is key to maintaining the Company’s compliance with mandated
27 NERC and Western Electricity Coordinating Council (“WECC”) Bulk Electric System
28 reliability and performance standards.

29 Due to the long lead times associated with planning, siting, permitting, design and
30 construction associated with major electric system infrastructure projects like this one, as
31 an essential service provider, the Company must permit and construct the Project now.

1
2 **OVERALL TRANSMISSION SYSTEM PLAN**
3

4 **Q. Please provide an overview of PacifiCorp’s current transmission system and future**
5 **transmission expansion plans.**

6 A. PacifiCorp owns and operates approximately 15,800 miles of transmission lines ranging
7 from 46 kV to 500 kV across the western states. As of December 31, 2008, PacifiCorp’s
8 current total Company net transmission assets have a book value of approximately \$1.8
9 billion. PacifiCorp is interconnected with more than 80 generation plants and 15 adjacent
10 control areas at approximately 124 points of interconnection. To provide electric service
11 to its retail and wholesale customers, PacifiCorp owns or has interest in generation
12 resources directly interconnected to its transmission system with a system peak capacity
13 of approximately 12,131 megawatts (“MW”). This generation capacity includes a
14 diverse mix of resources including coal, hydro, wind power, natural gas simple cycle and
15 combined cycle combustion turbines, and geothermal. The Company’s transmission
16 system’s performance and operation is an integral part of the WECC electric system and
17 has a significant influence throughout the West. That is, if the Company’s system fails, it
18 will have a broad reaching effect not only on Utah Customers but also on the electrical
19 system across the West.

20 Energy Gateway is the Company’s comprehensive transmission plan. Energy Gateway
21 will improve reliability, reduce transmission system constraints and improve the flow of
22 electricity to Rocky Mountain Power’s Customers. The Energy Gateway plan is
23 comprised of eight interrelated and interdependent transmission segments with an
24 estimated investment of \$6 billion, as outlined in Exhibit DTG-3 (Energy Gateway
25 Transmission Expansion Plan). The eight line segments within Energy Gateway have
26 been grouped and labeled as Gateway Central, Gateway West, Gateway South and the
27 Westside. Energy Gateway, when fully implemented, will traverse six states, numerous
28 communities and counties, and significant areas of federally-administered lands. Energy
29 Gateway will add approximately 2,000 miles of new transmission lines to PacifiCorp’s
30 transmission system over the next ten to twelve years. For Energy Gateway, the eight
31 identified transmission segments provide specific capabilities to the Company’s system,

1 while providing the benefits of Energy Gateway to other regional transmission lines. The
2 primary objectives required of Energy Gateway are to:

- 3
- 4 • Add significant levels of new incremental transmission capacity necessary to
5 adequately provide energy services to Customer's long term and comply with
6 the Company's Federal Energy Regulatory Commission ("FERC") approved
7 Open Access Transmission Tariff ("OATT")² and other regulatory
8 requirements.
- 9
- 10 • Improve system reliability and ensure ongoing compliance with FERC/NERC
11 mandatory Bulk Electric System Reliability Standards and WECC Regional
12 Criteria.
- 13
- 14 • Provide necessary transmission system capacity to deliver current 2008
15 Integrated Resource Plan ("IRP")³ requirements and to provide necessary

² PacifiCorp's most recent OATT dated July 13, 2007 (PacifiCorp OV11 Tariff) is available online at:
<http://www.oasis.pacificorp.com/oasis/ppw/PACRestatedOATT20100219.pdf>

³ PacifiCorp's 2008 IRP dated May 28, 2009, along with the subsequent update dated March 31, 2010, are available online at:

2008 IRP, Volume I:

http://www.pacificorp.com/content/dam/pacificorp/doc/Environment/Environmental_Concerns/Integrated_Resource_Planning_3.pdf

2008 IRP, Volume II:

http://www.pacificorp.com/content/dam/pacificorp/doc/Environment/Environmental_Concerns/Integrated_Resource_Planning_6.pdf

2008 IRP Update:

http://www.pacificorp.com/content/dam/pacificorp/doc/Energy_Sources/Integrated_Resource_Plan/2008IRPUpdate/PacifiCorp-2008IRPUpdate_3-31-10.pdf

IRP Web Page:

<http://www.pacificorp.com/es/irp.html>

1 options to future IRPs enabling continued access to low cost energy sources,
2 including renewables.

- 3
4 • Improve interconnections with existing market hubs and resource hubs, and
5 improve the capability and reliability of the transmission system generally in
6 the western states region.

7
8 Gateway Central is being completed first as it provides urgent and necessary capacity
9 and reliability improvements for Utah. Gateway Central is comprised of three
10 transmission segments: (1) Populus to Terminal, (2) Mona to Oquirrh, including the
11 Limber to Oquirrh 345 kV transmission line, the future Limber Substation, and the
12 future Limber to Terminal 345 kV transmission line; and (3) future Oquirrh to
13 Terminal 345 kV transmission line. These transmission segments will improve
14 reliability and transfer capability to the existing system within Utah, and also
15 establish the necessary electrical interconnection between Gateway West and
16 Gateway South. The Gateway West, Gateway Central and Gateway South line
17 segments, when complete, will be the first 500 kV alternating current (“AC”) lines to
18 be installed in Wyoming, southeast Idaho and Utah. Gateway Central will provide an
19 essential reliability backbone allowing Gateway West and Gateway South to operate
20 at a higher reliability and at an overall higher capacity than would otherwise be
21 possible without the Gateway Central interconnection. When viewed in the context
22 of the Energy Gateway plan, this Project will not only add incremental transmission
23 capacity to the Critical Load Area, but will also strengthen PacifiCorp’s overall
24 system while supporting future generation resource development to benefit all of the
25 Company’s Customers.

26
27 As described earlier in my testimony, the Mona to Oquirrh transmission segment is
28 comprised of three sections, which in total extend 141 miles from the Mona
29 substation to the proposed Limber substation, and two separate and geographically
30 diverse 345 kV double-circuit segments from the future Limber substation, one
31 connected to the existing Oquirrh substation and the other connected to the existing

1 Terminal substation. See Exhibit DTG-4 (Mona to Oquirrh 500/345 kV Transmission
2 Project).

3
4 **Q. What is the current status of the implementation of Energy Gateway?**

5 A. As noted, the Energy Gateway transmission expansion plan consists of eight individual
6 segment additions to the Company's transmission system. The Mona to Oquirrh
7 transmission segment, designated as "Segment C" within Gateway Central in the Exhibit
8 DTG-3 (Energy Gateway Transmission Expansion Plan), is an essential component of the
9 overall Energy Gateway plan. The size and complexity of Energy Gateway requires the
10 transmission expansion to be completed in a phased approach spanning approximately 10
11 to 12 years for obtaining all federal, state, and local permitting, and construction of the
12 transmission segments. A general description of each segment is set out below. The
13 Company is fully engaged in Energy Gateway, which is scheduled to be completed by
14 2019.

15
16 Segment A (Walla Walla to McNary) is 56 miles of 230 kV transmission line that
17 completed permitting in 2009, and the first 30 mile segment, Walla Walla to McNary,
18 began right-of-way acquisition in 2010, with construction to commence in 2011.

19
20 Segment B (Populus to Terminal) is 136 miles of 345 kV double-circuit transmission
21 line that completed permitting and right-of-way acquisition in 2009, started
22 construction in early 2009 and is scheduled to be completed in late 2010.

23
24 Segment C (Mona to Oquirrh and Oquirrh to Terminal) consists of Mona to Oquirrh
25 and Limber to Terminal transmission lines, making up 67 miles of 500 kV
26 transmission line and 74 miles of 345 kV double-circuit transmission line. The
27 National Environmental Policy Act ("NEPA") process for this Project was initiated in
28 2007 and the Environmental Impact Statement ("EIS") and record of decision from
29 the Bureau of Land Management ("BLM") is scheduled to be completed in the fourth
30 quarter of 2010. The Oquirrh to Terminal Project is scheduled for construction to
31 begin in early 2011 and is expected to be completed by mid 2013. The Oquirrh to

1 Terminal project is a 15 mile double-circuit 345 kV transmission line that is also part
2 of Segment C. The Project is in the final stages of permitting and right-of-way
3 acquisition is scheduled for completion in 2011 and construction scheduled from
4 2011 to 2013.

5
6 Segments D and E (Windstar to Populus and Populus to Hemingway) make up the
7 Gateway West project and consist of 1,100 miles of 500 kV transmission line and 150
8 miles of 230 kV transmission line. PacifiCorp initiated the NEPA process in 2008,
9 and is scheduled to have a final EIS and record of decision in 2012, with construction
10 scheduled for completion in phases from 2014 through 2018.

11
12 Segments F and G (Aeolus to Mona and Mona to Crystal) form the 800 miles of 500
13 kV transmission line that comprises the Gateway South project. The NEPA process
14 was initiated in late 2008 and is scheduled for a final EIS and record of decision in
15 2015, with the Project scheduled for completion between 2017 and 2019. The Sigurd
16 to Red Butte project is a 161 mile 345 kV line that is part of Segment G. It is
17 undergoing its own NEPA process which is scheduled to receive a final EIS and
18 record of decision in the first quarter 2011. Construction is scheduled to begin in
19 2012 and the project is scheduled for completion in 2014.

20
21 Segment H (Hemingway to Captain Jack) is 375 miles of 500 kV transmission line
22 that is in the early regional planning stages.

23
24 **Q. What analysis did the Company perform to develop its master transmission plan?**

25 A. The Company's analysis has been extensive and has been conducted and completed over
26 a number of years. PacifiCorp's FERC-approved Open Access Transmission Tariff
27 provides details regarding PacifiCorp's planning requirements and contractual obligations
28 to provide safe, reliable, adequate and efficient transmission service. Section 28.2
29 defines PacifiCorp's responsibilities, which include the requirement to "plan, construct,
30 operate and maintain the system in accordance with good utility practice." Section 31.6
31 defines the requirement for network customers to supply annual load and resource

1 updates for inclusion in planning studies. Through its OATT, the Company solicits this
2 data annually in order to determine future load and resource requirements for all network
3 customers, including PacifiCorp's network customers and customers of third parties
4 under the Company's FERC-approved OATT and other FERC-approved agreements.
5 The Company's retail loads comprise the bulk of the transmission network customer
6 needs, including those in Utah. Section 28.3 includes the requirement for PacifiCorp to
7 provide "firm service over the system so that designated resources can be delivered to
8 designated loads." These future requirements and needs will be met via Energy Gateway
9 and its segments, including the Mona to Oquirrh segment, which is an essential part of
10 PacifiCorp's overall transmission plan for Utah and the region. In addition to the OATT
11 requirements stated above, the analysis incorporated compliance requirements associated
12 with mandatory national and regional reliability standards and criteria which I discuss in
13 detail later in my testimony.

14
15 **Q. What customers provided load and resource data in PacifiCorp's 2009 annual load**
16 **and resource forecast?**

17 A. PacifiCorp's network customers provided their annual 10-year load and resource forecast
18 for the years 2009-2018. These customers from all states include: Utah Associated
19 Municipal Systems ("UAMPS"), Utah Municipal Power Agency ("UMPA"), Deseret
20 Generation & Transmission Co-operative ("DG&T"), Bonneville Power Administration
21 ("BPA"), Basin Electric Power Cooperative ("Basin Electric"), Moon Lake Electric
22 Association, and PacifiCorp Commercial and Trading ("PacifiCorp C&T"). PacifiCorp
23 C&T addresses the entire Critical Load Area, including Tooele County.

24
25 **Q. How does the Company's future energy resource planning benefit from Energy**
26 **Gateway, and in particular the current and future Integrated Resource Plans?**

27 A. The Company utilizes an integrated resource plan to establish future resources necessary
28 to serve its Customers. This is the resource plan and associated risk analysis framework
29 used to specify prudent future actions required to ensure that the Company continues to
30 provide reliable and efficient electric service to its Customers, while striking an expected
31 balance between cost and risk over the planning horizon and taking into consideration

1 environmental issues, along with the energy policies of the states served by the Company,
2 including Utah. As stated in Chapter 2 of the 2008 IRP, its purpose is to fulfill “the
3 Company’s commitment to develop a long-term resource plan that considers cost, risk,
4 uncertainty, and the long-run public interest. It was developed through a collaborative
5 public process with involvement from regulatory staff, advocacy groups, and other
6 interested parties.” (2008 IRP, at page 17.) Resource portfolio modeling conducted for
7 the Company’s recent IRPs has shown that additional transmission capacity is necessary
8 and cost-effective for supporting future generation resource needs. The 2008 IRP
9 includes the Mona-Oquirrh segment C as part of the modeled transmission topology for
10 the purpose of selecting the Company’s current preferred portfolio of future supply-side
11 and demand-side resources as shown on the 2008 IRP Uupdate March 31, 2010. Exhibit
12 DTG-5 (2008 IRP Resource Table).

13
14 **Q. Please describe the regional transmission studies and analysis that have been**
15 **conducted related to Energy Gateway and specifically the Gateway Central**
16 **segments and what have these studies found.**

17 A. Over the past decade, numerous studies have been issued that document the need for new
18 transmission in the western United States. As early as 2002, the Department of Energy
19 National Transmission Grid Study identified the Wyoming-Idaho interface as a major
20 constrained interface, and found that under optimal conditions the Wyoming-Northern
21 Utah interface is congested during 50 percent or more of the hours during the year.⁴ In
22 2004, the Rocky Mountain Area Transmission Study reached similar conclusions, the
23 result of which was a recommended expansion of the 345 kV transmission lines
24 connecting the Bridger substation to points south and west as critically needed
25 improvements.⁵ In addition, the Department of Energy’s 2006 National Electric
26 Transmission Congestion Study (“DOE Congestion Study”) identified several
27 constrained transmission paths in the West, including lines used to deliver electricity

⁴ National Transmission Grid Study at pp 15, 18. A full copy of this report is available at
<http://www.pi.energy.gov/documents/TransmissionGrid.pdf>.

⁵ RMATS at Chapter 3-2, which shows the Bridger expansion as a critical expansion area from Wyoming to
Northern Utah and Wyoming to Idaho. The full report is available at
<http://psc.state.wy.us/htdocs/subregional/Reports.htm>

1 from generation plants in Wyoming to loads in Utah and Oregon.⁶ Specifically, the DOE
2 Congestion Study illustrated that the expansion of the Bridger West facility serving Idaho
3 and Northern Utah is critical to relieve congestion from Wyoming to Northern Utah, and
4 Wyoming to Idaho.⁷ Similarly, the Western Interconnection 2006 Congestion
5 Assessment Study, which was issued by the DOE Western Congestion Analysis Task
6 Force, identified areas of congestion in the Rocky Mountain states, and projected that
7 based on 2005 load and resource forecasts and a production model, many of the paths
8 associated with the various segments of Energy Gateway were forecasted to be heavily
9 congested.⁸

10
11 Reports initiated by the Western Governor's Association ("WGA") also show certain
12 paths in PacifiCorp's service territory (such as the Populus to Terminal segment) to be
13 constrained.⁹ Lastly, the Department of Energy sponsored a study through Idaho
14 National Laboratories to assess the economic impact of not building transmission. While
15 the report focused on assessing economic impact on the Pacific Northwest, it also
16 provides discussion and support for the "hub and spoke" design which is similar to the
17 Energy Gateway model for connecting resource areas to load. The report also describes
18 the interconnected nature of transmission as being *geographically dispersed*, yet
19 interdependent.¹⁰

20
21 Existing Northern Tier Transmission Group ("NTTG") sub-regional transmission
22 planning studies, currently in draft and conducted in accordance with FERC Order 890-
23 A, show overall benefits to the region as a result of PacifiCorp's proposed Energy

⁶ The National Electric Transmission Congestion Study (August 2006) at pp 31-35). The transmission constraints identified in this study were identified by reviewing recent transmission studies such as those conducted by WECC and SSG-WI. The full report is available at http://nietc.anl.gov/documents/docs/Congestion_Study_2006-9MB.pdf.

⁷ Such expansion is addressed by the Segment E portion of the Project.

⁸ A full copy of this study is available at http://www.oe.energy.gov/DocumentsandMedia/DOE_Congestion_Study_2006_Western_Analysis.pdf.

⁹ The full report is available at <http://www.westgov.org/wga/initiatives/cdeac/TransmissionReportfinal.pdf>.

¹⁰ The Cost of Not Building Transmission: Economic Impact of Proposed Transmission Line Projects for the Pacific Northwest Economic Region. Full report is available at <http://www.pnwer.org/Portals/0/Presentations/2008%20summit/Cost%20of%20not%20building%20transmission.pdf> (emphasis added).

1 Gateway. Additionally, the Company filed for incentive rates with FERC on July 3,
2 2008. The incentive rate process at FERC is analogous to a need determination. The
3 Company was granted incentive rate treatment, but equally important FERC issued a 4-0
4 decision in which it stated:

5 *“...we find that PacifiCorp has adequately demonstrated that the Project (with*
6 *the exception of segment A [Walla Walla to McNary]) will ensure reliability and*
7 *reduce transmission congestion... We find that segments B through H of the*
8 *Project would establish for the first time a backbone of 500 kV transmission lines*
9 *in PacifiCorp’s Wyoming, Idaho and Utah regions. This would provide a platform*
10 *for integrating and coordinating future regional and sub-regional electric*
11 *transmission projects being considered in the Pacific Northwest and the*
12 *Intermountain West, connecting existing and potential generation to loads in an*
13 *efficient manner, thus reducing the cost of delivered power. Also, the Petition*
14 *cites the 2006 DOE National Electric Transmission Congestion Study and the*
15 *2004 Rocky Mountain Area Transmission Study in stating that that proposed*
16 *Project will reduce congestion or maintain reliability in the Western*
17 *Interconnection. Additionally, the project would establish a direct link between*
18 *PacifiCorp’s east and west control areas, providing numerous benefits including*
19 *increasing transfer capability, reducing the need for curtailments, and reducing*
20 *transmission congestion.” [¶39]*

21
22 Commissioner Suedeen G. Kelly echoes the petition stating that:

23 *“...while Segments B [Populus to Terminal] and C [Mona to Oquirrh] provide a*
24 *variety of benefits when considered in isolation, they also enable PacifiCorp to*
25 *achieve the planned transfer capability rating of subsequent segments.”*

26
27 Commissioner Kelly’s statement emphasizes the crucial nature of the Mona to
28 Oquirrh transmission expansion, not only to the state of Utah, but to Energy Gateway
29 overall.¹¹

¹¹ http://www.pacificorp.com/content/dam/pacificorp/doc/Transmission/Transmission_Services/EL08_75.pdf

1
2 **Q. Did Mid-American Energy Holding Co. make any transmission facilities**
3 **commitments when it acquired PacifiCorp?**

4 A. Yes. At the time of the acquisition of the Company by Mid-American Energy Holdings
5 Company (“MEHC”), many regulatory and intervening parties in the regulatory docket
6 referenced as *In the Matter of the Application of MidAmerican Energy Holdings*
7 *Company And PacifiCorp dba Utah Power & Light Company for an Order Authorizing*
8 *Proposed Transaction, Docket No. 05-035-54*, wanted the Company to make critical
9 transmission infrastructure investments to support the future demands and growth of its
10 Customers and their communities. As a result, the Company made specific commitments
11 and developed plans for a significant transmission expansion program across the
12 system.¹² One of the first components of the plan related to the transmission system that
13 will be completed in 2010 which is a new double circuit 345 kV transmission line from
14 the Populus substation near Downey, Idaho to the Terminal substation. The second
15 component of the plan is the Mona to Oquirrh transmission Project, which completes
16 Utah commitments regarding transmission lines.

17
18 **Q. What are the specific reliability requirements addressed in the Company’s**
19 **transmission plans?**

20 A. PacifiCorp plans, designs and operates its transmission system to meet or exceed NERC
21 Standards for Bulk Electric Systems and WECC Regional standards and criteria. The
22 NERC standards are federal law stated in 18 CFR Part 40 (Mandatory Reliability
23 Standards for Bulk-Power System). The WECC standards and criteria are deemed
24 necessary for the WECC Region to meet or exceed NERC standards. There are currently
25 more than 100 approved NERC standards to which the Company must comply. For all
26 Energy Gateway segments, including the Mona to Oquirrh Project, the following are
27 directly applicable to the planning, siting, permitting, design, construction and subsequent
28 operation:

29

¹² The MEHC transaction merger commitments can be found online at:
<http://www.psc.utah.gov/utilities/electric/06orders/Mar/0503554RptOrd.pdf>

- 1 • NERC TPL-001 [System Performance Under Normal Conditions](#)¹³
- 2 • NERC TPL-002 [System Performance Following Loss of a Single BES](#)
- 3 [Element](#)¹⁴
- 4 • NERC TPL-003 [System Performance Following Loss of Two or More BES](#)
- 5 [Elements](#)¹⁵
- 6 • NERC TPL-004 [System Performance Following Extreme BES Events](#)¹⁶
- 7 • TPL 001-WECC-1-CR System Performance Criteria Normal Conditions¹⁷
- 8 • TPL 002-WECC-1-CR System Performance Criteria Following Loss of a Single
- 9 BES Element¹⁸
- 10 • TPL 003-WECC-1-CR System Performance Criteria Following Loss of Two or
- 11 More BES¹⁹
- 12 • TPL 003-WECC-1-CR System Performance Criteria Following Extreme BES
- 13 Events²⁰
- 14 • NERC TOP-002 [Normal Operations Planning](#)²¹
- 15 • NERC TOP-004 [Transmission Operations](#)²²
- 16 • NERC TOP-007 [Reporting SOL and IROL Violations](#)²³
- 17

¹³ NERC TPL-001 can be found at: <http://www.nerc.com/files/TPL-001-0.pdf>

¹⁴ NERC TPL-002 can be found at: <http://www.nerc.com/files/TPL-002-0.pdf>

¹⁵ NERC TPL-003 can be found at: <http://www.nerc.com/files/TPL-003-0.pdf>

¹⁶ NERC TPL-004 can be found at: <http://www.nerc.com/files/TPL-004-0.pdf>

¹⁷ [http://www.wecc.biz/Standards/WECC%20Criteria/TPL%20-%20\(001%20thru%20004\)%20-%20WECC%20-%201%20-%20CR%20-%20System%20Performance%20Criteria.pdf](http://www.wecc.biz/Standards/WECC%20Criteria/TPL%20-%20(001%20thru%20004)%20-%20WECC%20-%201%20-%20CR%20-%20System%20Performance%20Criteria.pdf)

¹⁸ [http://www.wecc.biz/Standards/WECC%20Criteria/TPL%20-%20\(001%20thru%20004\)%20-%20WECC%20-%201%20-%20CR%20-%20System%20Performance%20Criteria.pdf](http://www.wecc.biz/Standards/WECC%20Criteria/TPL%20-%20(001%20thru%20004)%20-%20WECC%20-%201%20-%20CR%20-%20System%20Performance%20Criteria.pdf)

¹⁹ [http://www.wecc.biz/Standards/WECC%20Criteria/TPL%20-%20\(001%20thru%20004\)%20-%20WECC%20-%201%20-%20CR%20-%20System%20Performance%20Criteria.pdf](http://www.wecc.biz/Standards/WECC%20Criteria/TPL%20-%20(001%20thru%20004)%20-%20WECC%20-%201%20-%20CR%20-%20System%20Performance%20Criteria.pdf)

²⁰ [http://www.wecc.biz/Standards/WECC%20Criteria/TPL%20-%20\(001%20thru%20004\)%20-%20WECC%20-%201%20-%20CR%20-%20System%20Performance%20Criteria.pdf](http://www.wecc.biz/Standards/WECC%20Criteria/TPL%20-%20(001%20thru%20004)%20-%20WECC%20-%201%20-%20CR%20-%20System%20Performance%20Criteria.pdf)

²¹ NERC TOP-002 can be found at: <http://www.nerc.com/files/TOP-002-2.pdf>

²² NERC TOP-004 can be found at: <http://www.nerc.com/files/TOP-004-2.pdf>

²³ NERC TOP-007 can be found at: <http://www.nerc.com/files/TOP-007-0.pdf>

1 The above-referenced standards dictate the minimum levels of transmission system
2 reliability, redundancy and performance required for Energy Gateway to interconnect to
3 the larger western grid. These are performance based standards and criteria that among
4 other things, require utilities to consider the proximity of new and existing transmission
5 lines for reliability purposes during planning, determination of system capacity ratings
6 and establishing limits, both normal and emergency as necessary for daily operations.
7 The responsibility to comply with these mandatory reliability standards, along with the
8 method of implementation, is clearly imposed on the Company.

9
10 These mandatory standards require the Company to have a forward-looking transmission
11 plan of action to reliably serve current and anticipated future Customer demands under all
12 expected operating conditions, including normal system operations (all system elements
13 in service) and during system contingencies (where elements of the transmission system
14 are out of service) both planned or otherwise. NERC Transmission Planning Standard
15 TPL 002 states:

16
17 **A. Introduction**

18 **Purpose:** System simulations and associated assessments are needed periodically
19 to ensure that reliable systems are developed that *meet specified performance*
20 *requirements with sufficient lead time*, and continue to be modified or upgraded as
21 *necessary to meet present and future system needs.*

22
23 **B. Requirements**

24 **R1.** The Planning Authority and Transmission Planner shall each demonstrate
25 through valid assessment that its portion of the interconnected transmission
26 *system is planned such that the Network can be operated to supply projected*
27 *customer demands and projected Firm (nonrecallable reserved) Transmission*
28 *Services, at all demand levels over the range of forecast system demands, under*
29 *the contingency conditions* as defined in Category B of Table I. To be valid, the
30 Planning Authority and Transmission Planner assessments shall:

31
32 **R1.1.** Be made annually.

33 **R1.2.** Be conducted for near-term (years one through five) and longer-
34 term (years six through ten) planning horizons.

35
36 **R2.** When System simulations indicate an *inability of the systems to respond as*
37 *prescribed in Reliability Standard TPL-002-0_R1*, the Planning Authority and
38 Transmission Planner shall each:
39

1 **R2.1.** Provide a written summary of its plans to achieve the required
2 system performance as described above throughout the planning horizon:

3 **R2.1.1.** *Including a schedule for implementation.*

4 **R2.1.2.** *Including a discussion of expected required in-service dates of*
5 *facilities.*

6 **R2.1.3.** *Consider lead times necessary to implement plans.*

7
8 (Emphasis added)

9
10 In conclusion, the Company is required to have both short-term and long-term
11 transmission plans to reliably meet current and forecasted customer needs. This
12 requirement to have a plan and act on that plan is not optional.

13
14 **Q. What requirements are specified by the WECC and NERC documents that**
15 **PacifiCorp must consider in locating multiple transmission lines?**

16 A. The NERC TPL 003 requires the Company to plan for outages of two or more system
17 components, including transmission lines. Table 1 section C.5 of the NERC TPL 003
18 requires that *“for an event that results in loss of two or more elements specifically*
19 *addressing an outage of any two circuits of a multi circuit tower line (i.e. loss of a double*
20 *circuit structure or other common mode of failure that results in the simultaneous loss of*
21 *two circuits),”* there be no *“cascading”* of generation or uncontrolled outages to
22 Customers. In addition, the Company must comply with the WECC criteria. WECC
23 System Performance Criteria TPL 003-WECC-1-CR Requirement WRS1.1 states *“NERC*
24 *Category C.5 initiating event of a non-three phase fault with normal fault clearing time*
25 *shall also apply to the common mode contingency of two adjacent circuits on separate*
26 *towers unless the frequency is determined to be less than one in 30 years.”*

27
28 This means when two transmission lines are installed on common structures or
29 transmission lines are located adjacent to each other (less than a span length), the
30 Company, at a minimum, must plan for loss of both circuits simultaneously and must
31 build redundancy in the system to withstand this multiple line outage in order to meet all
32 applicable performance standards.

1 **Q. What are the consequences or impacts if PacifiCorp’s transmission system fails to**
2 **meet these performance standards because lines are too close together?**

3 A. Should the Company fail to meet NERC performance standards and criteria resulting in
4 widespread uncontrolled loss of generation or customer demand, WECC System
5 Performance Criteria TPL-004WECC-1-CR, Requirement WRS5 states:

6
7 *“For any event that has actually resulted in cascading, the Planning Authority or*
8 *Transmission Planner shall have documentation that it has taken action so that future*
9 *occurrences of the event will not result in cascading, or it must have documentation that*
10 *it has WECC PCC approval that the Mean Time Between Failure (MTBF) is greater than*
11 *300yrs (frequency less than .0033 outages/year).”*

12
13 In the event both Energy Gateway paths and other existing lines are constructed such that
14 a system outage occurs as a result of multiple line outages, PacifiCorp would be required
15 to provide mitigation steps stated above to prevent future occurrences. These mitigation
16 measures would likely result in lower overall Energy Gateway capacity (i.e., lower
17 ratings and operating limits) and reduced utilization of assets. To account for the reduced
18 utilization, the Company would be required to construct additional transmission lines.

19
20 The burden of proof of reliable performance and compliance with the National and
21 Regional Reliability Standards lies heavily on the shoulders of utilities like PacifiCorp
22 that own and operate transmission systems. In the event PacifiCorp’s new transmission
23 line fails to perform in accordance with the above planning requirements and standards
24 due to common mode outages of adjacent lines, the Company will be required by WECC
25 and NERC to limit the capacity and/or operation of the lines to levels that will not cause
26 major disturbances or disruptions to the grid. This reduction in system capacity limits the
27 Company’s ability to serve existing and new Customers. Additional transmission lines
28 and transmission line corridors would then be required to restore lost capacity and to add
29 back the additional level of system redundancy that the new transmission project was
30 ultimately expected to deliver. In addition, the Company could be subject to significant
31 fines and sanctions for lack of compliance with NERC standards if it was determined the

1 Company failed to plan and to construct properly. This determination, of course, is often
2 made “after the fact” in a significant outage and at that time mitigation measures required
3 from placing lines too close together are limited at best.
4

5 **Q. Has the Company experienced outages and/or system disturbances caused by**
6 **multiple lines located in close proximity?**

7 A. Yes, several significant outages have occurred on the Company’s extra high voltage
8 (“EHV”) ²⁴ lines. Occurrences have been experienced due to a wide number of causes
9 including; fire, smoke, high winds, flooding, ice and severe storms, landslides, aircraft as
10 well as other human interference or action. The following are just some examples:

- 11 • 1981 – Due to a human-caused fire, two 345 kV lines north of Camp Williams
12 were forced out of service and a third 345 kV line cascaded, resulting in a
13 state wide blackout.
- 14 • 1982-83 - Landslides on the two Emery-Sigurd 345 kV lines destroyed
15 transmission towers.
- 16 • 1983 - Severe wind storms caused two 345 kV, two 230 kV and three 138 kV
17 lines between Salt Lake City and Ogden to go down.
- 18 • 1990 – An Air Force jet contacted transmission causing outages of double
19 circuit 345 kV and 230 kV lines between Terminal and Ben Lomond.
- 20 • 2000 - Fires in the corridor of Emery-Camp Williams and Huntington-Spanish
21 Fork 345 kV lines forced lines out of service.
- 22 • 2002-2003 - Multiple fires in the corridor between Mona and Camp Williams
23 forced lines out of service due to smoke and to protect fire fighters in the area.
- 24 • 2007 - A fire caused both the Mona to Huntington and the Mona to Bonanza
25 345 kV lines in Central Utah to be de-energized for fire crew safety.
- 26 • 2007 - Three 345 kV lines connecting Jim Bridger Wyoming to southeast
27 Idaho experienced a fire that forced multiple lines out of service.
28

²⁴ “EHV” means transmission lines of 345 kV or greater.

1 **Q. Have other utilities experienced outages and or system disturbances caused by**
2 **multiple EHV lines located in close proximity?**

3 A. Yes. The 1992 BLM Western Regional Corridor Study notes that on at least one
4 occasion, high winds caused the loss of two adjacent 500 kV line towers on the Pacific
5 Intertie and the resulting power outage left an estimated 5.2 million customers in several
6 states without power. This simultaneous loss of two major EHV lines serving Southern
7 Oregon and California resulted in a system reliability and capacity review. The result of
8 the review was the requirement in 1993 to build a new (third) 500 kV transmission line
9 across the Pacific Intertie to restore capacity and improve reliability. During the planning
10 of the subsequent third line of the Oregon/California AC Intertie, considerable efforts
11 were made to maintain a separation of at least five miles with one mile minimum if
12 absolutely no other alternative routes existed.

13
14 On August 6-8, 11-12, 1990, fires caused six simultaneous outages (along with 17 single
15 lines outages) of the two Round Mountain-Table Mountain 500 kV lines in northern
16 California. Fires burned randomly back and forth across the corridor for more than 12
17 miles. Customer load interruptions ranged from 90 MW to 1000 MW at times.

18
19 **Q. How has the Company's transmission plans addressed the reliability requirements?**

20 A. The conceptual planning and design of Energy Gateway has been engineered to meet all
21 reliability performance standards and criteria during normal and emergency operations.
22 The concept is based on regional interconnection of large resource hubs with load centers
23 through large scale, high capacity EHV transmission lines. Fundamental to meeting
24 those standards is the necessity of adequate redundancy provided through multiple
25 transmission lines and having those multiple lines located in wide, geographically diverse
26 corridors to significantly reduce the risk of common mode outages.

27
28 The Company has designed Energy Gateway in such a manner as to create a "Triangle of
29 Reliability." See Exhibit DTG-6 (Energy Gateway Separation and Design). Gateway
30 Central, Gateway West and Gateway South, each create a leg of this triangle. With the
31 loss of any one leg of the triangle, the other path (along with the existing underlying

1 transmission system in the area) would provide an acceptable level of backup that would
2 limit disruptions to the wider interconnected electric grid, continue to allow customers to
3 be served and keep generation connected to the system. However, with the simultaneous
4 loss of any two legs of the triangle, the transmission system could experience
5 uncontrolled system collapse resulting in the loss of generation and loss of significant
6 customer load for both the Company and other interconnected utilities in the region.

7
8 The Company must account for the real possibility that multiple lines (new and existing)
9 in the area could be forced out of service due to human caused physical interference,
10 sabotage, smoke and fire, microbursts, severe winds, blizzards, ice storms, salt or dust
11 storms, etc.

12
13 As a result, the Company continues to pursue to locate the Gateway South and Gateway
14 West lines in new corridors separated from one another by a wide distance are prudent in
15 order to maintain the Triangle of Reliability.

16
17 **Q. What is the minimum standard that specifically addresses the location of**
18 **transmission lines?**

19 A. The National Electrical Safety Code (“NESC”) (ANSI C2-2007) is the code that specifies
20 the minimum electrical clearances of electric supply lines from other obstacles such as
21 adjacent transmission lines, roads, highways, railroads, buildings and other structures,
22 etc. The NESC sets forth the minimum standards and requires the utility to apply
23 industry-accepted practices in the design and construction of its transmission systems.
24 PacifiCorp designs, constructs and operates its electric systems in such a manner to meet
25 or exceed these minimum NESC requirements.

26
27 **CURRENT TRANSMISSION SITUATION IN UTAH**

28
29 **Q. Describe the current transmission situation for bringing power into the Critical**
30 **Load Area from the south and how the Transmission Project fits into that situation.**

1 A. There are limited options for gaining new transmission capacity into the Critical Load
2 Area. *See Exhibit No. DTG-2* (Major Transmission Paths Serving Utah). Further, new
3 resources identified to serve the Critical Load Area for the next four to five years will be
4 located in the southern part of Utah as shown in the Company's 2008 IRP. Currently, a
5 majority of the electricity serving the Critical Load Area and further north is generated at
6 the Company's facilities in Carbon, Juab, and Emery Counties, or is imported over
7 multiple lines connected to the Desert Southwest. This energy must be transported and
8 delivered from the south on existing transmission lines to the Critical Load Area. These
9 central and southern Utah generating facilities include the Carbon, Hunter, Huntington,
10 and Currant Creek power plants. The Company's transmission system that provides
11 electrical service to the Critical Load Area from central and southern Utah presently
12 consists of eight lines: two 345 kV lines from the Huntington and Castle Dale (Emery
13 substation) areas to the Spanish Fork and Camp Williams Substations, four 345 kV lines
14 from the Mona area to the Camp Williams Substation, and two smaller 138 kV lines from
15 the Helper area (Carbon substation) to the Spanish Fork substation. These transmission
16 lines along with other interconnected lines are also used to import power into Utah from
17 Nevada, the Four Corners Region, and other energy providers connected to the existing
18 Mona substation. It is necessary to then move this energy north to the Company's
19 Customers in the Critical Load Area, including Tooele County. Similarly, the Company's
20 municipal and other customers rely on generation located south of or connected to Mona
21 to serve their loads and expect to rely on increased capacity of existing facilities to serve
22 their load growth needs north of Mona. As stated earlier, without Energy Gateway,
23 including the Mona to Oquirrh Project, the increase in Customer demand could not be
24 reliably served. The new transmission capacity provided by the Mona to Oquirrh project
25 is required.

26
27 As northern Utah's electrical usage continues to grow, particularly in the Critical Load
28 Area, existing transmission lines have diminished capacity to serve projected customer
29 energy demand and still continue to ensure a safe, reliable, adequate and efficient supply
30 of electricity. Transmission studies and analysis show that the existing capacity of the
31 transmission system from Mona north into the Critical Load Area will have to

1 subsequently be reduced, in proportion to any future increase in customer demand, in
2 order to maintain system reliability and maintain compliance with the performance
3 standards discussed above. The system is currently fully subscribed for firm transmission
4 service and is operating at or near its full capability. These studies show future electrical
5 demand of the Critical Load Area will exceed the capacity of existing transmission lines
6 near term. The Company must prudently plan in advance of this event. Due to the long
7 lead times associated with planning, siting, permitting, design and construction associated
8 with major electric system infrastructure projects like this one, as an essential service
9 provider, the Company must permit and construct the Project now.

10
11 **Q. Is the Mona to Oquirrh segment a requirement in the Company's latest IRP?**

12 A. Yes. The 2008 IRP includes the Mona to Oquirrh segment. Energy Gateway is designed
13 to use a "hub and spoke" concept in which the Mona to Oquirrh Project is an integral
14 "spoke."

15
16 **Q. Are there other justifications driving the need to execute and complete the
17 transmission project other than stated above?**

18 A. Yes. Nearly 70% of the electrical load in the state of Utah is located within the Critical
19 Load Area. *See* Exhibit DTG-1 (Critical Load Area). Currently the system has limited
20 capacity to deliver energy north of Mona, Utah and into the Critical Load Area. Demand
21 increases in the Critical Load Area reduce the capability of the transmission import path
22 and reduce the ability to use existing generation resources in southern Utah, connections
23 at Mona and other connections in the southern part of the state to serve the Critical Load
24 Area. The Mona to Oquirrh transmission line is needed to provide an additional and
25 separate transmission path around this existing limitation. The Project, when completed,
26 significantly improves the Critical Load Area import capability limit.

27
28 **Q. Please explain how the Energy Gateway "Triangle of Reliability" criteria have been
29 applied locally to the Mona to Oquirrh Project.**

1 A. The same “Triangle of Reliability” strategy applied to the overall Energy Gateway
2 project has been applied twice in designing the Mona to Oquirrh Project, as set forth
3 below. *See Exhibit DTG-4* (Mona to Oquirrh 500/345/138kV Transmission Project).

4
5 Mona/Oquirrh/Limber Triangle - The first leg of the triangle is the existing Mona to
6 Camp Williams to Oquirrh lines, the second leg is the proposed Oquirrh to Limber line
7 located in Tooele County, and the third leg is the proposed Limber to Mona line. As
8 described in Mr. Smith’s testimony, in order to ensure the reliability of this triangle, the
9 BLM, Juab County and Utah County have worked with the Company to site the proposed
10 Mona to Limber transmission line route in such a manner as to maintain adequate
11 separation from existing EHV transmission lines.

12
13 Limber/Oquirrh/Terminal Triangle - The first leg of the triangle is the proposed Limber
14 to Oquirrh line, the second leg is the future Oquirrh to Terminal line, and the third leg is
15 the future Limber to Terminal line. In order to ensure the reliability, separation of each
16 leg of this triangle is required.

17
18 **Q. In the past, the Company has located more than one transmission line in a common**
19 **corridor. Why is this no longer an acceptable practice?**

20 A. Industry standards applicable to the reliability of electric supply have become stronger
21 and more stringent as the United States’ dependence on electricity has increased.
22 FERC’s approval of more than 100 national reliability standards have also been
23 established to increase reliability margins and reduce significant impacts resulting from
24 large scale outages and blackouts of the electric system. In addition, many of
25 PacifiCorp’s existing transmission lines were built over 15 years ago and their capacity
26 has been used up. These transmission lines can no longer provide adequate margins of
27 redundancy. In particular, the increased utilization of the existing lines between Mona
28 and the Critical Load Area has eliminated the ability to use those lines to back up any
29 new EHV lines within the same transmission corridor.

30

1 There are conditions that would allow more than one transmission line to be located in a
2 common corridor, however, current performance standards dictate that system reliability
3 and redundancy requirements must be met in that event. There are two primary reasons
4 why this practice would be considered acceptable:
5

6 First, instances where there are physically no practicable or viable options available to
7 locate new lines away from existing lines, for example physical pinch points created by
8 large bodies of water, geography or terrain. In this event, line route alternatives become
9 impractical due to extremely long routes that become electrically limited (project no
10 longer meets needs of customers) or the cost of the alternative is exorbitant and would
11 not be seen as prudent. However, the NERC reliability standards still apply, and the
12 Company would have to meet those standards with additional generation sources or more
13 transmission lines.
14

15 Second, where there is deemed to be sufficient redundancy and other backup
16 transmission lines in the interconnected system to maintain reliable service to customers,
17 transmission lines may be located in proximity because outages of multiple lines do not
18 cause undue disruption to the local area or to the grid as a whole.
19

20 The capacity of the new line, its functional impact to the local transmission system, and
21 interconnection to the wider transmission grid (inside and outside of PacifiCorp's system)
22 must be evaluated. In short, not all transmission lines are alike in their voltages, capacity
23 requirements, electrical function and redundancy levels. EHV lines like those proposed
24 for Energy Gateway have significant impacts to local and wider interconnected
25 transmission grids, and require special consideration.
26

27 **ADDITIONAL BENEFITS RESULTING FROM THE PROJECT**

28

29 **Q. Will the Mona to Oquirrh transmission project provide other benefits to the**
30 **Company's existing and future transmission system?**

1 A. Yes. While the Project specifically provides additional transmission capacity in Utah, it is
2 also a critical segment of the Company’s overall Energy Gateway transmission plan. The
3 Project positions the Company to be strongly interconnected to the current and future
4 electric grid in the region and provides necessary options for access to additional
5 resources necessary to control future energy costs. It also supports and is in concert with
6 the development of other transmission projects being planned throughout the western
7 region.

8
9 **Q. Will the Transmission Project provide increased reliability for the Company’s**
10 **wholesale transmission customers?**

11 A. Yes. Utah Associated Municipal Power Systems, Utah Municipal Power Association,
12 and Deseret Generation & Transmission rely on Utah-based generation or imports into
13 Utah to serve their loads. Increased capacity in the northbound direction from the Mona
14 substation provides required reliability for long-term load service in northern Utah.
15 Without increased northbound transmission capacity from the Company, these entities
16 would be required to find alternative resource energy supplies to serve load growth which
17 would potentially increase their power costs. Increasing capacity across this path will
18 significantly improve a point of constraint on the system that currently affects several
19 transmission customers.

20
21 **Q. How is this Project critical to Tooele County, and how will its citizens benefit?**

22 A. The Project is critical to short-term and long-term electric service to Tooele County.
23 Currently, energy supplies for Tooele County are provided by three existing 138 kV
24 transmission lines extending from the Oquirrh and Terminal substations. One of these
25 138 kV transmission lines brings energy from the existing Oquirrh substation to Tooele
26 County. Two additional 138 kV transmission lines bring energy from Terminal
27 substation to Tooele County. Tooele County has historically benefited and prospered,
28 through a 44% increase in electrical energy consumption since 2002, based on electric
29 supply from these existing substations located in the Salt Lake Valley and from the
30 electric transmission system interconnected therein.

31

1 The capacity on the existing 138 kV transmission lines has been exhausted by load
2 growth in Tooele County. By 2013, it is anticipated that the Company will be unable to
3 serve its existing Customers in Tooele County reliably with the existing 138 kV
4 transmission system served from Terminal and Oquirrh substations and will not be able
5 to maintain compliance with NERC Reliability Standards. Equally important is the fact
6 that the Company is presently unable to provide new service to any new large economic
7 development customers requesting service for new facilities or the expansion of their
8 existing facilities attempting to locate or expand within Tooele County. As a result, the
9 Company will be unable to serve the future load required for any further economic
10 development in the Tooele Valley prior to the completion of the Project and future
11 Limber substation. Based on 2009 network Customer loads and resource submittals, the
12 Critical Load Area, including Tooele County, is anticipated to grow from a peak of 4709
13 MW in 2009 to 6,586 MW in 2018, nearly an 1800 MW increase by 2018. Significant
14 load growth is expected to continue in Tooele County which is consistent with the views
15 expressed by the Tooele County economic development staff during the conditional use
16 permitting process for the Project. In the future, the Limber substation and the 500 kV
17 line from the Mona substation will provide new long term load service capacity and
18 increased reliability to Tooele County. Without Energy Gateway, including the 2013
19 Mona to Oquirrh Project, this load increase could not be served with the existing and
20 future planned energy resources.

21 22 **CONCLUSIONS AND RECOMMENDATIONS**

23
24 **Q. Please explain why the Company is approaching the Utility Facility Review Board
25 now for a project that is not scheduled for completion until 2013.**

26 A. Time is of the essence. Large transmission projects such as the Mona to Oquirrh Project
27 are complex, and require long lead times to complete the siting and permitting processes,
28 which includes the NEPA permitting process in addition to other federal, state and local
29 regulation and permitting compliance. With this in mind, the Company has been
30 proceeding with the Project siting and permitting processes since 2005. However, in
31 addition to the years required to site and permit the Project, several additional years are

1 necessary to complete the specific Project design work, order and acquire materials, and
2 construct the Project. At this point, the Company has only three years to complete these
3 tasks. Any further delay in obtaining a conditional use permit from Tooele County will
4 jeopardize the Company's ability to provide safe, reliable, adequate and efficient electric
5 service to its Customers within the Critical Load Area, including the Tooele Valley.

6
7 The Company is an essential service provider of electric services and as such must
8 implement long-range planning strategies in order to meet the anticipated energy needs of
9 its Customers. Failure to proactively and prudently plan for future growth would put the
10 Company in a reactive posture, requiring it to operate its systems at or above design
11 parameters, increasing the likelihood of system damage and diminishing backup capacity,
12 and in the end, leading to increased system down time and Customer power outages.
13 Increasing the risk of potential breach of national reliability standards of which the
14 Company may be sanctioned if it failed to plan and act. Long-term scheduling, planning
15 and implementation of transmission projects such as the Mona to Oquirrh Project
16 increase the adequacy and reliability of the Company's electric service to its Customers,
17 and significantly reduce overall project costs, thereby saving the Company's Customers
18 money.

19
20 **Q. What do you recommend?**

21 **A.** The Company requests the Board:

22
23 (1) Find that the Project and the Company's proposed route as identified in the
24 conditional use permit application, which was denied by Tooele County on March 30,
25 2010, is necessary in order for the Company to provide safe, reliable, adequate and
26 efficient service to its Customers;

27
28 (2) Require Tooele County to approve a conditional use permit for the Mona to Oquirrh
29 transmission line to be located within the Company's proposed transmission corridor
30 as specified in Mr. Smith's testimony. See Exhibit BDS-9.1 (Company's Approved
31 Transmission Line Corridor – Limber South) and Exhibit BDS-9.2 (Company's

1 Approved Transmission Line Corridor – Limber East); and require the County, in
2 defining the transmission centerline within the corridor, minimize the number of
3 angles or corners by using straight lines wherever possible in order to reduce the
4 number of large corner structures and foundations, mitigate construction and
5 environmental impacts, and assure a cost efficient solution for the Company's
6 Customers; and

7
8 (3) Require the County approve a conditional use permit consistent with the Board's
9 findings within 60 days following the decision of the Board.

10
11 **Q: Does this conclude your direct testimony?**

12 **A: Yes.**

EXHIBITS TO DIRECT TESTIMONY OF DARRELL T. GERRARD

EXHIBIT DTG-1: Critical Load Area

EXHIBIT DTG-2: Major Transmission Paths Serving Utah

EXHIBIT DTG-3: Energy Gateway Transmission Expansion Plan

EXHIBIT DTG-4: Mona to Oquirrh 500/345 kV Transmission Project

EXHIBIT DTG-5: 2008 IRP Resource Table

EXHIBIT DTG-6.1: Energy Gateway Separation and Design - Introduction to Project Scale

EXHIBIT DTG-6.2: Energy Gateway Separation and Design – Scenario (1)

EXHIBIT DTG-6.3: Energy Gateway Separation and Design – Scenario (2)

EXHIBIT DTG-6.4: Energy Gateway Separation and Design – Scenario (3)