

ELECTRIC SERVICE SCHEDULE NO. 115 - Continued
Table 2b – Other Motor Incentives

Equipment Type	Size Category	Sub-Category	Minimum Efficiency Requirement	Customer Incentive
Electronically Commutated Motor (ECM)	≤ 1 horsepower	Refrigeration application	--	\$0.50/watt
		HVAC application	--	\$50/horsepower
Variable-Frequency Drives (HVAC fans and pumps)	≤ 100 horsepower	HVAC fans and pumps	See Note 3	\$65/horsepower
Green Motor Rewinds	≥ 15 and ≤ 500 hp	--	Must meet GMPG Standards	\$1/horsepower Refer to Note 4

Notes for Table 2b:

1. For retrofits of existing equipment, incentives are for one-for-one same size equipment replacements.
2. Equipment that meets or exceeds the efficiency requirements listed for the equipment category in the above table may qualify for an incentive.
3. Throttling or bypass devices, such as inlet vanes, bypass dampers, three-way valves, or throttling valves must be removed or permanently disabled to qualify for HVAC fan or pump VFD incentives. VFDs required by energy code are not eligible for incentives. Savings will only be realized for installations where a variable load is present.
4. For Green Motor Rewinds, the participating electric motor service center is paid \$2/horsepower for eligible Green Motor Rewinds. A minimum of \$1/horsepower is paid by the service center to the customer as a credit on the motor rewind invoice. The balance is retained by the service center.
5. Green Motor Rewinds > 500 horsepower may be eligible for a custom Energy Efficiency Incentive (see page 3).

HVAC = Heating, Ventilating and Air Conditioning

GMPG = Green Motors Practices Group

VFD = Variable Frequency Drive

ECM = Electronically Commutated Motor