

ELECTRIC SERVICE SCHEDULE NO. 115 - Continued
Table 3a – HVAC Equipment Incentive Table

Equipment Type	Size Category	Sub-Category	Minimum Efficiency Requirement & Customer Incentive		
			\$50/ton	\$75/ton	\$100/ton
Unitary Commercial Air Conditioners, Air-Cooled (Cooling Mode)	< 65, 000 Btu/hr (single phase)	Split system and single package	15.0 SEER and 12.5 EER	--	
	< 65, 000 Btu/hr (three phase)	Split system and single package	--	14.0 SEER and 11.6 EER	15.0 SEER and 12.0 EER
	≥ 65,000 Btu/hr and < 135,000 Btu/hr	Split system and single package	--	11.5 EER and either 11.9 IPLV or 11.7 IEER	12.0 EER and either 12.4 IPLV or 12.2 IEER
	≥ 135,000 Btu/hr and < 240,000 Btu/hr	Split system and single package	--	11.5 EER and either 11.9 IPLV or 11.7 IEER	12.0 EER and either 12.4 IPLV or 12.2 IEER
	≥ 240,000 Btu/hr and < 760,000 Btu/hr	Split system and single package	--	10.5 EER and either 10.9 IPLV or 10.7 IEER	10.8 EER and either 12.0 IPLV or 11.0 IEER
	≥ 760,000 Btu/hr	Split system and single package	--	9.7 EER and either 11.0 IPLV or 9.9 IEER	10.2 EER and either 11.0 IPLV or 10.4 IEER
Unitary Commercial Air Conditioners, Water and Evaporatively Cooled	< 135,000 Btu/hr	Split system and single package	14.0 EER	--	
	≥ 135,000 Btu/hr	Split system and single package	14.0 EER	--	
Package Terminal Air Conditioners and Heat Pumps (PTAC/PTHP) (Heating & Cooling Mode)	≤ 8,000 Btu/hr	Single package	11.8 EER and 3.3 COP	--	
	> 8,000 Btu/hr and < 10,500 Btu/hr	Single package	11.4 EER and 3.2 COP	--	
	≥ 10,500 Btu/hr and ≤ 13,500 Btu/hr	Single package	10.7 EER and 3.1 COP	--	
	> 13,500 Btu/hr	Single package	10.0 EER and 3.0 COP	--	
Heat Pumps, Air-Cooled (Cooling Mode)	< 65, 000 Btu/hr (single phase)	Split system and single package	15.0 SEER and 12.5 EER	--	
	< 65, 000 Btu/hr (three phase)	Split system and single package	--	14.0 SEER and 11.6 EER	15.0 SEER and 12.0 EER
	≥ 65,000 Btu/hr and < 135,000 Btu/hr	Split system and single package	--	11.5 EER and either 11.9 IPLV or 11.7 IEER	12.0 EER and either 12.4 IPLV or 12.2 IEER
	≥ 135,000 Btu/hr and < 240,000 Btu/hr	Split system and single package	--	11.5 EER and either 11.9 IPLV or 11.7 IEER	12.0 EER and either 12.4 IPLV or 12.2 IEER
	≥ 240,000 Btu/hr	Split system and single package	--	10.5 EER and either 10.9 IPLV or 10.7 IEER	10.8 EER and either 12.0 IPLV or 11.0 IEER

(Continued)

(C)

(C)