

**ELECTRIC SERVICE SCHEDULE NO. 115 - Continued**
**Table 3b – Mechanical and Other Energy Efficiency Measures**

(C)

Equipment Type	Size Category	Sub-Category	Minimum Efficiency Requirement	Customer Incentive
Evaporative Cooling Chillers	All sizes All except chillers intended for backup service only	Direct or Indirect Serving primarily occupant comfort cooling loads (no more than 20% of process cooling loads)	Industry Standard Rating (ISR) Must exceed minimum efficiencies required by energy code	\$0.02/ISR CFM \$0.12/kWh annual energy savings + \$50/kW See note 3
Occupancy Based PTHP/PTAC control	All sizes with no prior occupancy based control		See Note 4	\$50/controller
Vertical Solid Door Refrigerator	0 < V < 15		ENERGY STAR®	\$100
	15 ≤ V < 30		ENERGY STAR®	\$125
	30 ≤ V < 50		ENERGY STAR®	\$150
	50 ≤ V		ENERGY STAR®	\$175
Vertical Solid Door Freezer	0 < V < 15		ENERGY STAR®	\$125
	15 ≤ V < 30		ENERGY STAR®	\$150
	30 ≤ V < 50		ENERGY STAR®	\$175
	50 ≤ V		ENERGY STAR®	\$200
Cool Roof	Roofing over spaces with mechanical cooling		Energy Star ® Reflective Roof Products label	\$0.10/square foot
Plug Load Occupancy Sensor				\$15/qualifying unit
Beverage or refrigerated display machine occupancy sensor	No occupancy sensor control	Beverage vending or refrigerated display machine occupancy sensor	See Note 5	\$75/sensor

## Notes for Table 3b

- For retrofits of existing equipment, incentives are for one-for-one same size equipment replacements.
- Equipment that meets or exceeds the efficiency requirements listed for the equipment category in the above table may qualify for an incentive.
- Chiller energy and demand savings subject to approval by the Company.
- Controller units must include an occupancy sensor and include the capability to set back the zone temperature during extended unoccupied periods and set up the temperature once the zone is occupied.
- Intended for refrigerated vending machines and display cases containing only non-perishable bottled and canned beverages. Refurbished equipment that includes occupancy control is eligible.

**PTHP** = Package Terminal Heat Pump  
**PTAC** = Package Terminal Air Conditioner  
**V** = Association of Home Appliance Manufacturers (AHAM)  
 volume in cubic feet

**HVAC** = Heating, Ventilating and Air Conditioning  
**CEE** = Consortium for Energy Efficiency

(C)