

Technical Analysis of Prospective Photovoltaic Systems in Utah





Exceptional service in the national

interest

Jimmy Quiroz and Chris Cameron Photovoltaics and Distributed Systems Integration Sandia National Laboratories





Sandia National Laboratories is a multi-program laboratory managed and operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000.

Introduction



- Collaboration with Rocky Mountain Power
- 2 MW_{AC} nominal central plant PV systems (prospective)
- Three feeder locations
 - Toquerville 11, southwestern Utah
 - Delta 11, central Utah
 - Terminal 19, northern Utah
- Technical and performance analyses
- PLEASE NOTE: Not intended to be a complete interconnection analysis
 - PV type, size, and location specific; changing any of these would change the results
 - No system protection impacts were studied, a necessary aspect
 - Other load periods and using local irradiance may reveal other impacts
 - *IEC 61000-4-15 flicker standards would differ from IEEE Std 141-1993*

Technical Analysis Approach



- Time-series analysis
 - OpenDSS analysis software
 - Feeder models converted from utility software models
 - Source and transformer impedances
 - Other feeders on substation
- Load periods one week, one second resolution
 - Peak penetration period
 - Peak load period
- PV profiles
 - High variability from actual system in Colorado
 - Duplicated for entire week
 - Unity PF output
 - Sunrise/sunset adjustments

Load Profile Example – Toquerville 11 Peak Penetration Period

Sandia





PV Output Profile



Integration Impact Analysis



- Maximum and Minimum Voltages (ANSI C84.1)
- Feeder demand reduction
- Voltage regulation equipment operations (LTC)
- Voltage flicker (IEEE Std 141-1993)



Toquerville 11





- PV system 1.3 miles from substation
- 2 MW system is 63% of annual feeder peak load
- One fixed 600 kVAr capacitor bank
- LTC settings 123 V, 2 V bandwidth, 60 second delay

Toquerville 11 – Peak Penetration Period - Maximum Voltages



Toquerville 11 - Peak Penetration Period - Minimum Voltages



Toquerville 11 - Peak Penetration Period – Demand Without PV





Toquerville 11 - Peak Penetration Period – Demand With PV

Sandia Nationa



Toquerville 11 - Peak Penetration Period – PV Percent Penetration





Toquerville Substation - PeakPenetration Period – Demand With PV





Toquerville 11 – Peak Penetration Period - LTC Operations and Flicker

• LTC operations:

	Without PV	With PV
Operations	6	5

- PV offset of load reduces voltage drop
- Flicker (100% to 0% PV output)
 - 1.00% voltage change would only cause an irritation if it occurred 15 times a minute or more, per IEEE Std 141-1993
 - Worst ramp found in PV output profile was approximately 71.9% over 8.2 minutes
 - No problems anticipated

Toquerville 11 – Peak Load Period – Voltages and Demand



	Without PV	With PV
Maximum	124	124
Minimum	118.1	118.6

Feeder demand (kW):

	Without PV	With PV
Peak demand	3167	2783 (-384 kW)

No reverse power through substation transformer

Toquerville 11 – Peak Load Period - LTC Operations and Flicker

• LTC operations:

	With PV	Without PV
Operations	61	61

- Flicker (100% to 0% PV output)
 - 1.04% voltage change would only cause an irritation if it occurred 15 times a minute or more, per IEEE Std 141-1993
 - Worst ramp found in PV output profile was approximately 71.9% over 8.2 minutes
 - No problems anticipated

Delta 11





- PV system 0.6 miles from substation
- 2 MW system is 116% of annual feeder peak load
- Two fixed 300 kVAr capacitor banks
- LTC settings 123 V, 2 V BW, 30s delay, 4+j3 V LDC

Delta 11 – Peak Penetration Period 🖻 🖿 – Voltages and Demand

Maximum and minimum voltages (120 V base):

	Without PV	With PV
Maximum	124.9	124.7
Minimum	122.4	122.4

• Feeder demand (kW):

	Without PV	With PV
Peak demand	1246	-1291 (+45 kW)

No reverse power through substation transformer

Delta 11 – Peak Penetration Period 🖻

Sandia National Laboratories

- LTC Operations and Flicker
- LTC operations:

	Without PV	With PV
Operations	10	8

- PV offset of load reduces voltage drop
- Flicker (100% to 0% PV output)
 - 1.31% voltage change would only cause an irritation if it occurred 5 times a minute or more, per IEEE Std 141-1993
 - Worst ramp found in PV output profile was approximately 71.9% over 8.2 minutes
 - No problems anticipated

Delta 11 – Peak Load Period – Voltages and Demand



Maximum and minimum voltages (120 V base):

	Without PV	With PV
Maximum	125.2	125.2
Minimum	122.4	122.3

• Feeder demand (kW):

	Without PV	With PV
Peak demand	1725	1538(-187 kW)

No reverse power through substation transformer

Delta 11 – Peak Load Period - LTC Operations and Flicker

LTC operations:

	Without PV	With PV
Operations	35	31

- PV offset of load reduces voltage drop
- Flicker (100% to 0% PV output)
 - 1.36% voltage change would only cause an irritation if it occurred 5 times a minute or more, per IEEE Std 141-1993
 - Worst ramp found in PV output profile was approximately 71.9% over 8.2 minutes
 - No problems anticipated

Terminal 19





- PV system is just north of substation
- 2 MW system is 67% of annual feeder peak load
- No capacitor banks
- LTC settings 123 V, 2 V bandwidth, 60 second delay

Terminal 19 – Peak Penetration Period – Voltages and Demand



Maximum and minimum voltages (120 V base):

	Without PV	With PV
Maximum	123.2	123.2
Minimum	121.5	121.5

• Feeder demand (kW):

	Without PV	With PV
Peak demand	1889	1603 (-286 kW)

No reverse power through substation transformer

Terminal 19 – Peak Penetration Period - LTC Operations and Flicker

LTC operations:

	Without PV	With PV
Operations	1	1

- Flicker (100% to 0% PV output)
 - 0.08% voltage change would never cause an irritation, regardless of frequency, per IEEE Std 141-1993
 - Worst ramp found in PV output profile was approximately 71.9% over 8.2 minutes
 - No problems anticipated

Terminal 19 – Peak Load Period – Voltages and Demand



Maximum and minimum voltages (120 V base):

	Without PV	With PV
Maximum	123.9	123.9
Minimum	121.3	121.3

• Feeder demand (kW):

	Without PV	With PV
Peak demand	2703	2087 (-616 kW)

No reverse power through substation transformer

Terminal 19 – Peak Load Period -LTC Operations and Flicker



LTC operations:

	Without PV	With PV
Operations	2	2

Flicker (100% to 0% PV output)

- 0.09% voltage change would never cause an irritation, regardless of frequency, per IEEE Std 141-1993
- Worst ramp found in PV output profile was approximately 71.9% over 8.2 minutes
- No problems anticipated

Performance Modeling



- System designs
 - 2 MW_{AC} nominal systems
 - Fixed-tilt multicrystalline silicon
 - Fixed-tilt thin-film
 - One-axis tracking (east to west) multicrystalline
- PVsyst tool used for production estimation
 - Ability to model shading and tracking
- TMY-2 weather data from Solar Prospector site

Fixed-tilt Multicrystalline System



Sandia

National Laboratories

Fixed-tilt thin-film system





Eight subarrays, two power blocks

Racks at 30° Tilt and 32 ft spacing

One-axis tracking multicrystalline



Sandia

National Laboratories

System Output by Month -Toquerville





Average Hourly Output by Month - Toquerville





Conclusions



- PLEASE NOTE: Not intended to be a complete interconnection analysis
 - PV type, size, and location specific; changing any of these would change the results
 - No system protection impacts were studied, a necessary aspect
 - Other load periods and using local irradiance may reveal other impacts
 - IEC 61000-4-15 flicker standards would differ from IEEE Std 141-1993
- Utility planning value
 - Snapshot periods Peak penetration and peak load periods
 - LTC operations time-series dependent
 - Flicker 100% to 20% PV output
- Not a question of whether integration is possible, just a question of what it takes!



Jimmy E. Quiroz jequiro@sandia.gov (505)284-5391