

Exhibit RMP___(DMR-7R)

DPU Data Request 26.1

Regarding Response to DPU 2.29: Please provide the file name and folder location of all documents provided responsive to DPU 2.29 that apply to project “Currant Crk U2 CSA Variable fee 24k - CTB MI” (APR#10001485). If no such documents were provided, please explain why not.

Response to DPU Data Request 26.1

The documentation for this project is in the process of being prepared and has not yet been finalized. In lieu of the approved authorization, the Company provides the following information to support the capital addition.

Please refer to Confidential Attachment DPU 26.1, which includes relevant portions of the Contractual Services Agreement (CSA) between GE and PacifiCorp. Confidential information is provided subject to Utah PSC Rule 746-100-16.

Please note that when the contractor uses the term “Inspect” in section “B,” in most cases it results in the replacement of the program parts that are removed. In accordance with the CSA, the contractor warrants that each unit will operate another 24,000 hours between Hot Gas Path overhauls and 48,000 hours between each Major Inspection overhaul. The maintenance plan outlines the equipment that will be replaced during the MI overhaul.