

ELECTRIC SERVICE SCHEDULE NO. 110 - Continued

Table 2. Builder Incentive Levels and Qualifying Equipment for Multi-Family Residences

Utah Multi-Family		
Tier/Measure	Equipment	Incentive
Multi-Family Tier 1	For 5-12 contiguous units: Meet ENERGY STAR v 2.0 specifications including performance-based duct sealing, air conditioner equipment minimum standard of SEER 13**, A/C equipment commissioning, performance testing, correct sizing, best practices installation and the thermal bypass checklist; plus installation of CFLs in 50% of all light sockets, ENERGY STAR appliance package (dishwasher, washer, refrigerator where permanently installed)	\$300
Multi-Family Tier 2	For 13 or more contiguous units: Meet ENERGY STAR v 2.0 specifications including performance-based duct sealing, air conditioner equipment minimum standard of SEER 13**, A/C equipment commissioning, performance testing, correct sizing, best practices installation and the thermal bypass checklist; plus installation of CFLs in 50% of all light sockets, ENERGY STAR appliance package (dishwasher, washer, refrigerator where permanently installed)	\$200
Plus Measure*	Lighting Upgrade to 90% ENERGY STAR CFLs (from base of 50% CFLs)	\$35
Plus Measure*	14 SEER*** HVAC equipment with correct sizing and best practices installation	\$100

Notes for Table 2

1. *Plus measures must be installed in conjunction with the Multi-Family Tiers package to be eligible for incentives.
2. **Packaged Terminal Air Conditioning (PTAC) units which exceed federal minimum standards of 10.0 may be substituted for SEER 13 AC units in Tiers 1 and 2.
3. ***Packaged Terminal Air Conditioning (PTAC) units which exceed federal minimum standards of 11.5 may be substituted for SEER 14 A/C units.
4. All compact fluorescent lamps (CFLs) must be ENERGY STAR qualified to be eligible for incentives.

(C)

(C)

(D)

(L)

To
pg.5

(continued)