

REVISED ACTION REQUEST

Date: March 21, 2012

FROM: Public Service Commission

Due: April 19, 2012

SUBJECT Rocky Mountain Power Major Event Report – January 18-21, 2012 12-035-70
(Company Name, Case Number, etc.)

This is a request for the Division to conduct:

_____ Review Tariff Compliance

_____ Analysis of Complaint

_____ Investigation

X Other

EXPLANATION AND STATEMENT OF ISSUES TO BE ADDRESSED:

3/19/2012

12-035-70

(11) ROCKY MOUNTAIN POWER MAJOR EVENT REPORT In the Matter of the Request of Rocky Mountain Power for Major Event Exclusion for the Weather-Related Events that Occurred on January 18-21, 2012

In addition to the normal major event analysis for this request, please address the following other issues:

- 1) Does this request for a major event determination (i.e., the entire period between January 18 – January 21) comply with the requirements of IEEE-1366 for the determination of one major event or should the request be considered as two separate major events? The Company has provided one analysis for January 18 – January 19 and a separate analysis for January 21. How is January 20th being considered by the Company? Please provide an explanation of the Division’s conclusion based upon the requirements of IEEE-1366.
- 2) What is the Company doing to prevent/minimize pole fires?
- 3) In the Company’s use of IEEE-1366, please identify how the Company defines the term “day,” i.e., calendar day, a twenty-four hour period, etc. Is this definition consistently applied in the Company’s service quality calculations?