

OCS Data Request 1.30

Please explain the basis for the must run assumptions for gas-fired units (including existing and “IRP” units) used in the GRID Model study provided by the Company. Provide supporting documents, if any.

Response to OCS Data Request 1.30

The Carrant Creek and Gadsby CTs are the only gas plants with must run settings in the GRID model. The must run setting for these plants is based on the results of the 2010 Wind Integration Study and the modeled results reasonably correspond with historical operations. Please refer to Confidential Attachment OCS 1.30 for details.

Confidential information is provided subject to Utah PSC Rule 746-100-16.