

ELECTRIC SERVICE SCHEDULE NO. 115 - Continued
Table 3b –Other HVAC Incentives

Equipment Type	Size Category	Sub-Category	Minimum Efficiency Requirement	Customer Incentive
Evaporative Cooling	All sizes	Direct or Indirect		\$0.06/ CFM
Indirect-Direct Evaporative Cooling (IDEC)	All sizes	--	Applicable system components must exceed minimum efficiencies required by energy code	\$0.12/kWh annual energy savings + \$50/kW See Note 2
Chillers	All except chillers intended for backup service only	Serving primarily occupant comfort cooling loads (no more than 20% of process cooling loads)	Must exceed minimum efficiencies required by energy code	\$0.12/kWh annual energy savings + \$50/kW See Note 3
Room Air Conditioner	Residential (used in a business)	See Home Energy Savings program	See Home Energy Savings program	See Note 4
365/366 day Programmable Thermostat	All sizes in portable classrooms with mechanical cooling	Must be installed in portable classroom unoccupied during summer months	365/366 day thermostatic setback capability	\$150/thermostat
Occupancy Based PTHP/PTAC control	All sizes with no prior occupancy based control		See Note 5	\$50/controller

Notes for Table 3b

1. Equipment that meets or exceeds the efficiency requirements listed for the equipment category in the above table may qualify for the listed incentive.
2. Incentives paid at \$0.12/kWh annual energy savings and \$50/ kW average monthly demand savings. IDEC energy and demand savings subject to approval by the Company.
3. Incentives paid at \$0.12/kWh annual energy savings and \$50/ kW average monthly demand savings. Chiller energy and demand savings subject to approval by the Company.
4. Refer to Company's Home Energy Savings program for efficiency requirements and incentives for listed residential equipment used in a business.
5. Controller units must include an occupancy sensor and include the capability to set back the zone temperature during extended unoccupied periods and set up the temperature once the zone is occupied.

CFM = Cubic Feet per Minute

HVAC = Heating, Ventilating and Air Conditioning

IDEC = Indirect Direct Evaporative Cooling

ISR = Industry Standard Rating

PTAC = Packaged Terminal Air Conditioner

PTHP = Packaged Terminal Heat Pump