

1 **Summary of Alternate Compliance Technology Studies**

2 The Company completed eight noteworthy technical studies to evaluate
3 NO_x, PM and SO₂ emission control alternative technologies for Naughton Unit 3,
4 the first of which also apply to the Hunter Unit 1 projects included in this docket
5 for review. In October 2002, Sargent and Lundy (“SL”) completed a fleet-wide
6 *Multi-Pollutant Control Report* as an attorney-client privileged work product; in
7 January 2005, SL completed a NO_x emissions reduction technologies study; in
8 March 2006, SL completed a *Conceptual Design of Replacement Baghouse*
9 *PacifiCorp Naughton 3* study; in February 2007, CH2M Hill completed the *BART*
10 *Analysis for the Naughton Unit 3*; in December 2009, SL completed the *SCR and*
11 *Baghouse Study Report*; in October 2012, Alstom completed the *Naughton Unit 3*
12 *Engineering Study to Evaluate 100% Gas Firing Fuel Heat Input*; in November
13 2012, SL completed the *Naughton Station Conversion of Unit 3 to 100% Natural*
14 *Gas Firing* study; and in March 2013, Alstom completed the *Naughton Unit 3*
15 *Engineering Study to Evaluate 100% Gas Fuel Input Including Evaluation of Flue*
16 *Gas Recirculation and Low Load Operation*.

- 17 1. The *Multi-Pollutant Control Report* provided an early investigation of the cost
18 and necessity of NO_x, particulate matter (“PM”) and sulfur dioxide (“SO₂”)
19 emission controls on the units.
- 20 2. The 2005 NO_x emission reduction technologies study compared sixteen
21 emission control technologies, status of the technology development,
22 predicted performance, approximate initial capital costs, and approximate
23 incremental fixed and variable operational and maintenance (“O&M”) costs.

- 24 3. The *Conceptual Design of Replacement Baghouse PacifiCorp Naughton 3*
25 study established initial capital costs for PM emissions control alternatives.
- 26 4. The *BART Analysis for the Naughton Unit 3* was conducted for criteria
27 pollutants NO_x, PM₁₀ and SO₂. The Company conducted the BART analysis
28 and determination to analyze the effects on visibility in nearby Class I areas
29 (Bridger, Fitzpatrick and Mt. Zirkel Wilderness Areas). A BART analysis is a
30 comprehensive evaluation of potential NO_x, PM and SO₂ retrofit
31 technologies, and a BART determination is an emissions limit established by
32 the application of potential retrofit technologies for each unit. The specific
33 steps in a BART analysis are established in 40 CFR 51 Appendix Y, Section
34 IV. The analysis must include: (1) the identification of available and
35 technically feasible retrofit alternatives; (2) consideration of any pollution
36 control equipment in use at the source (which affects the availability of
37 alternatives and their effects); (3) the costs of compliance with control
38 alternatives; (4) the remaining useful life of the facility; (5) the energy and
39 non-air quality environmental impacts of compliance; and (6) the degree of
40 visibility improvement that reasonably may be anticipated from installation of
41 the BART alternative.
- 42 5. The *SCR and Baghouse Study Report* evaluated and established design criteria
43 and specified critical equipment features to mitigate design risks for a SCR
44 and baghouse technology alternative.
- 45 6. The *Naughton Unit 3 Engineering Study to Evaluate 100% Gas Firing Fuel*
46 *Heat Input* assessed the boiler thermal performance impacts; firing system

47 performance and emissions impacts; controls impacts; and potential boiler
48 pressure part and firing system component modifications that may be required
49 to add natural gas firing capability to the unit based on operation with 100%
50 fuel heat input at full load.

51 7. The *Naughton Station Conversion of Unit 3 to 100% Natural Gas Firing*
52 study investigated the scope of work and estimated costs for converting the
53 unit from a base loaded coal unit to a natural gas fueled peaking unit while
54 leaving coal firing capability intact to the greatest extent practicable.

55 8. The *Naughton Unit 3 Engineering Study to Evaluate 100% Gas Fuel Input*
56 *Including Evaluation of Flue Gas Recirculation and Low Load Operation*
57 assessed thermal performance of the unit at low load and provided an
58 evaluation of NOx emissions control using a FGR alternative at both high and
59 low loads.

60 **Key Study Points**

61 Salient points from these eight studies, and related information from other
62 sources, are presented with following statements:

63 The *Multi-Pollutant Control Report* indicated that combination “in-
64 combustion” (Low NOx Burners with Over Fire Air) and “post combustion”
65 (Selective Catalytic Reduction) would need to be installed on Hunter Unit 1 to
66 achieve a presumptive NOx emission rate of less and 0.10 pounds per million
67 British thermal units (lb/mmBtu)

68 The *Multi-Pollutant Control Report* indicated that a combination of “in-
69 combustion” and “post-combustion” controls (namely a SCR) would need to be

70 installed on Naughton Unit 3 to achieve a presumptive NO_x emissions limit of
71 less than 0.10 pounds per million British thermal units (“lb/mmBtu”).

72 The *Multi-Pollutant Control Report* indicated that the Hunter Unit 1 ESP
73 could achieve a particulate emission level of 0.030 lb/mmBtu with reasonable
74 modifications and upgrades, and it further indicated that that maintenance costs
75 would need to increase over time to facilitate the rebuilds necessary to keep the
76 current equipment operational at historic levels. In order to achieve an emission
77 level below 0.020 lb/mmBtu, the *Multi-Pollutant Control Report* indicated a
78 polishing baghouses retrofit would need to be completed.

79 The *Multi-Pollutant Control Report* indicated that Naughton Unit 3 would
80 require extensive modifications to the existing ESP or a “polishing baghouse
81 retrofit” must be completed to meet a presumptive PM emissions limit of less than
82 0.030 lb/mmBtu. The Naughton Unit 3 ESP is the smallest in the Company’s coal
83 fleet, is about 40 years old, and is in poor condition. It does have a flue gas
84 conditioning system to improve its performance. Historical operating data
85 establishes that the existing ESP’s best PM emissions rate is only approximately
86 0.04 lb/mmBtu.

87 The *Multi-Pollutant Control Report* indicated that the Hunter Units 1 FGD
88 system could achieve a removal efficiency of 90% with the following system
89 upgrades: (1) close the scrubber bypass damper (2) upgrade the existing mist
90 eliminators (3) add vertical flow mist eliminators (4) improve inlet gas
91 distribution (5) upgrade existing reheat system (6) upgrade spray header and

92 nozzle system (7) replace existing spray pumps (8) convert to a forced oxidation
93 system (9) restore and upgrade dewatering equipment.

94 The *Multi-Pollutant Control Report*, and other sources, indicated that a
95 FGD upgrade SO₂ removal efficiency of 90% would be achieved on the existing
96 Naughton Unit 3 FGD with only minor changes including: (1) improvements to
97 the inlet gas distribution; (2) the liquid to gas contact point would need to be
98 reviewed; (3) reagent and waste delivery systems needed to be upgraded; (4) a
99 reagent adjustment; and (5) consideration of a conversion to an open spray type
100 absorber.

101 At units with high baseline NO_x emissions (high is defined here as being
102 greater than 0.40 lb/mmBtu), it is common utility industry practice to initially
103 obtain a NO_x emissions reduction through the installation in-combustion
104 modifications, similar to the LNBS installed on the units, and then control the
105 remainder of any required NO_x emissions reduction with post-combustion control
106 systems, typically either SCR or a selective non-catalytic reduction system
107 (“SNCR”).


108 NO_x control technologies are grouped as either *in-combustion* control,
109 *post-combustion* control or *emerging* types:

- 110 • In-Combustion Controls include: (1) LNBS with overfire air (“OFA”); (2)
111 more precise combustion control of fuel and air; (3) combustion optimization
112 using a Neural Network system; and (4) Nalco Mobotec rotating opposed fire
113 air (“ROFA” or “rotating opposed fire air”) which is a next generation OFA
114 system.

- 115 • Post-Combustion Controls include: (1) SNCR, typically limited to only 10 to
116 40 percent NOx emissions reduction and have higher ammonia slip rates; and
117 (2) SCR with 80 to 90 percent NOx emissions reduction and a low ammonia
118 slip rate.
- 119 • Other emerging NOx reduction technologies (and that might become
120 commercially available, or more commercially feasible, within the next
121 decade) with the capability to achieve required NOx removal percentages
122 include: (1) Regenerative Activated Coke Technology; (2) Powerspan Electro-
123 Catalytic Oxidation; (3) BOC LoTOx System; (4) Airborne Process; (5)
124 Consolv Technologies Absorption Process; (6) Lean Gas Reburning; (7) Rich
125 Reagent Injection; (8) SNCR plus SCR hybrid systems; (9) Aptech CST
126 SNCR type systems; and (10) other reagent injection developments.

127 Of the technology alternatives mentioned herein, only LNB with OFA,
128 ROFA, SNCR with LNB, and SCR with LNB were considered BART analysis
129 feasible alternatives for NOx reduction across the fleet.

130 In a SCR, ammonia (“NH₃”) reacts with NOx contained in the flue gas
131 exiting the boiler as either nitrogen oxide (“NO”) or nitrogen dioxide (“NO₂”) in
132 the presence of catalyst to form molecular nitrogen (“N₂”) and water (“H₂O”).
133 Catalyst enhances the reaction between ammonia and NOx. The injected air-
134 diluted ammonia is adsorbed on the catalyst surfaces in the SCR reactors and
135 reacts with oxygen and NOx present in the flue gas according to the following
136 chemical reaction equations:



139 SNCR technology is similar to SCR because it involves injection of an
140 amine reducing agent like urea solution. The reduction chemistry, however, takes
141 place in the boiler without the aid of any catalyst. SNCR relies on appropriate
142 injection temperatures, proper mixing of the reagent and flue gas, reagent
143 injection kinematics, and prolonged boiler detention time in place of the catalyst.
144 SNCR operate at higher temperatures than SCR. The effective temperature range
145 for SNCR is 1,600 to 2,100 degrees F. SNCR is sensitive to temperature changes.

146 Table NT3-5-1 summarizes a comparison of NO_x emissions control
147 technologies results adapted from the *BART Analysis for the Naughton Unit 3* on
148 a 2007 cost year basis: Other environmental project costs not included in the
149 BART estimates include: boiler and air preheater casing structural reinforcements,
150 flue gas path structural reinforcement, a high and low temperature EEGT control
151 system, demolition, auxiliary power system upgrades, Owner's project costs and a
152 contingency allowance.

**Table NT3-5-1: Oxides of Nitrogen Emissions Control Technologies Comparison
(Adapted From CH2M Hill BART Analysis)**

Technology	Projected Emission Rate (lb/mmBtu)	Projected Emission % Reduction (%) (b)	Capital Cost (\$ x million)	O&M Cost Fixed + Variable (\$ x million)	Annual Power Usage (1,000 MWh/yr)	First Year Avg. Cost For NO _x Removal (\$/ton)
Baseline	0.50 (a)	0%	0.0	0.0	0.0	0
LNBs with OFA	0.35	22.2%	0.0 (c)	0.1	0.0	0
ROFA	0.28	37.8%	14.7	1.9	35.3	1,326
Selective Non-Catalytic Reduction and LNBs with OFA	0.28	37.8%	15.8	0.9	2.6	984
Selective Catalytic Reduction and LNBs with OFA	0.07	84.4%	92.0	2.6	15.7	2,049

(a) Emissions from PI data in table below; prior to LNB and OFA installations on Unit 3, the uncontrolled emissions rate was approximately 0.50 lb/mmBtu

(b) Technology reduction rates from the CH2M Hill BART analysis shown

(c) Currently installed on Naughton Unit 3

153 The baseline NO_x concentration of 0.50 lb/mmBtu was established from
 154 Naughton Unit 3 performance historian (“PI”) data and confirmed with
 155 continuous emissions data and flue gas testing.

156 PM emissions control technologies evaluated for Naughton Unit 3 include:
 157 (1) install a stand-alone baghouse to replace the existing ESP; (2) install a
 158 polishing fabric filter (Compact Hybrid Particulate Collector or (“COHPAC”)) to
 159 operate in series with the existing ESP; (3) rebuild the existing ESP; and (4)
 160 replace the existing ESP with a Reversing Gas Fabric Filter (“RGFF”), which is a
 161 PM cleaning device currently not often selected for use in steam electric plants.

162 Feasible technical alternatives to meet a PM emissions compliance limit of
 163 0.015 lb/mmBtu are: (1) install a polishing baghouse and operate it in series with

164 a rebuilt ESP; and (2) install a stand-alone baghouse. The *Design of Replacement*
165 *Baghouse PacifiCorp Naughton 3* study established initial capital costs in 2006
166 dollars for these two alternatives.

167 The *Naughton Unit 3 Engineering Study to Evaluate 100% Gas Firing*
168 *Fuel Heat Input* reported that the unit can be converted from the current coal
169 firing configuration and made capable to operate at full load on 100% natural gas
170 without significant boiler equipment or pressure part modifications. NOx
171 emissions of approximately 0.09 to 0.12 lb/mmBtu were predicted with natural
172 gas firing, consequently indicating it would be necessary to install a post-
173 combustion SNCR process or other post-combustion NOx control process if a
174 NOx emissions limit of approximately 0.08 lb/mmBtu is required. An alternative
175 FGR was proposed instead of adding a post-combustion NOx control system. The
176 FGR can simultaneously achieve the desired NOx emissions limit at 0.08
177 lb/mmBtu while also achieving design steam temperatures more easily and over a
178 broader load range. Alstom offered an opinion that potential furnace
179 modifications that include FGR and or waterwall refractory alternatives would
180 provide greater flexibility for NOx and carbon monoxide (“CO”) control when
181 firing 100% natural gas, and would be necessary from a performance standpoint if
182 the boiler were to be operated at low loads.

183 The *Naughton Unit 3 Engineering Study to Evaluate 100% Gas Fuel Input*
184 *Including Evaluation of Flue Gas Recirculation and Low Load Operation*
185 reported that Naughton Unit 3 can be converted from the current coal firing
186 configuration and made capable to operate at full load on 100% natural gas

187 without significant boiler or pressure part modifications. The addition of a FGR is
188 required to mitigate steam temperature reductions when attempting to attain
189 required NO_x emissions at full load. A FGR is also required to maintain high final
190 reheat steam temperatures at a low load of approximately 85 MW. Alstom
191 reported an FGR operated at about 20% FGR at full load, operated in conjunction
192 with Alstom's recommended natural gas firing system and the existing SOFA
193 system, is predicted to result in a NO_x emissions range of 0.06 to 0.09 lb/mmBtu
194 and a CO emissions rate at less than 0.15 lb/mmBtu.

195 Beyond the eight studies discussed above, The EPSCO International, Inc.,
196 *Phase III Recommendations* study of the Hunter and Huntington electrostatic
197 precipitators (ESP) was used as the basis for the decision to convert the Hunter
198 Unit 1 ESP to a baghouse. The decision making process began when the same
199 type of conversion was made at Huntington Unit 2 (2004-2006). The ESP at
200 Hunter Unit 1 and Unit 2 and Huntington Unit 1 and Unit 2 are identical and in
201 2003 it had become apparent that the ESP's were having operational difficulties.
202 EPSCO International, Inc. was hired to study the situation, identify options and
203 make recommendations for the Huntington and Hunter units. The EPSCO report
204 titled *Phase III Recommendations* was published in November 2003.