

ELECTRIC SERVICE SCHEDULE NO. 140 - Continued
Table 3a – HVAC Incentives

Equipment Type	Size Category	Sub-Category	Minimum Efficiency Requirement & Customer Incentive		
			\$25/ton	\$50/ton	\$75/ton
Unitary Commercial Air Conditioners, Air-Cooled (Cooling Mode)	< 65,000 Btu/hr (single phase)	Split system and single package	--	CEE Tier 1	CEE Tier 2
	All equipment sizes (three phase)	Split system and single package	--		
Unitary Commercial Air Conditioners, Water and Evaporatively Cooled	All equipment sizes	Split system and single package	--	CEE Tier 1	--
Packaged Terminal Air Conditioners (PTAC) (Cooling Mode)	≤ 8,000 Btu/hr	Single package	12.2 EER	--	--
	> 8,000 Btu/hr and < 10,500 Btu/hr	Single package	11.9 EER	--	--
	≥ 10,500 Btu/hr and ≤ 13,500 Btu/hr	Single package	10.7 EER	--	--
	> 13,500 Btu/hr	Single package	9.9 EER	--	--
Packaged Terminal Heat Pumps (PTHP) (Heating & Cooling Mode)	≤ 8,000 Btu/hr	Single package	--	12.2 EER and 3.4 COP	--
	> 8,000 Btu/hr and < 10,500 Btu/hr	Single package	--	11.5 EER and 3.3 COP	--
	≥ 10,500 Btu/hr and ≤ 13,500 Btu/hr	Single package	--	10.7 EER and 3.1 COP	--
	> 13,500 Btu/hr	Single package	--	9.8 EER and 3.0 COP	--
Heat Pumps, Air-Cooled (Cooling Mode)	< 65,000 Btu/hr (single phase)	Split system and single package	--	CEE Tier 1	CEE Tier 2
	< 65,000 Btu/hr (three phase)	Split system and single package	--		CEE Tier 2
	≥ 65,000 Btu/hr (three phase)	Split system and single package	--		--
Heat Pumps, Air-Cooled (Heating Mode) - See Note 3	< 65,000 Btu/hr (single phase)	Split system and single package	--	CEE Tier 1	CEE Tier 2
	< 65,000 Btu/hr (three phase)	Split system and single package	--		CEE Tier 2
	≥ 65,000 Btu/hr (three phase)	47°F db/43°F wb outdoor air	--		--
		17°F db/15°F wb outdoor air	--		--
Heat Pumps, Water-Source (Cooling Mode)	< 135,000 Btu/hr	86°F Entering Water	--	CEE Tier 1	--

(Continued)