

ELECTRIC SERVICE SCHEDULE NO. 140 - Continued
Table 10 – Compressed Air Incentives

Equipment Category	Replace	With	Limitations	Unit	Customer Incentive
Low-Pressure Drop Filters	Standard Coalescing Filter	Rated Low-Pressure Drop Filter where: 1. Pressure loss at rated flow is ≤ 1 psi when new and ≤ 3 psi at element change 2. Particulate filtration is 100% at ≥ 3.0 microns and 99.98% at 0.1 to 3.0 microns, with ≤ 5 ppm liquid carryover 3. Filter is deep-bed "mist eliminator" style, with element life ≥ 5 years 4. Rated capacity of filter is ≤ 500 scfm	1. Compressor system must be ≥ 25 HP and ≤ 75 HP	scfm	\$0.80/scfm
Receiver Capacity Addition	Limited or no Receiver Capacity (≤ 2 gallons per scfm of trim compressor capacity)	Total tank receiver capacity after addition must be > 2 gallons per scfm of trim compressor capacity	1. Compressor system size ≤ 75 horsepower 2. Trim compressor must use load/unload controls without inlet modulation or on/off control. 3. Systems with a VFD or using variable displacement control on trim compressor are not eligible.	gal	\$1.50/gal above 2 gal/scfm
Refrigerated Cycling Dryers	Non-Cycling Refrigerated Dryer	Cycling Refrigerated Dryer	1. Compressor system size ≤ 75 horsepower 2. Rated dryer capacity must be ≤ 500 scfm 3. Dryer must operate exclusively in cycling mode and cannot be equipped with the ability to select between cycling and non-cycling mode 4. Refrigeration compressor must cycle off during periods of reduced demand.	scfm	\$1.50/scfm

(Continued)