

Sophie Hayes (12546)
Utah Clean Energy
1014 2nd Ave.
Salt Lake City, UT 84103
801-363-4046
Attorney for Utah Clean Energy

BEFORE THE PUBLIC SERVICE COMMISSION OF UTAH

In the Matter of Review of Electric Service Schedule No. 38, Qualifying Facilities Procedures, and Other Related Procedural Issues	DOCKET NO. 14-035-140 Utah Clean Energy Exhibit 1.0 REDACTED
---------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------

DIRECT TESTIMONY OF KEN DRAGOON
ON BEHALF OF
UTAH CLEAN ENERGY

REDACTED

April 28, 2015

RESPECTFULLY SUBMITTED,
Utah Clean Energy



Sophie Hayes
Counsel for Utah Clean Energy

1 **INTRODUCTION**

2 **Q: Please state your name and business address.**

3 A: My name is Ken Dragoon. My business address is 3519 NE 15th Avenue, #227,
4 Portland, Oregon 97212.

5 **Q: By whom are you employed and in what capacity?**

6 A: I am the Director and proprietor of Flink Energy Consulting LLC, a private
7 consulting business whose mission is to advise a diverse clientele on matters relating to
8 electric power planning and analysis, specializing in issues relating to renewable energy
9 sources.

10 **Q: On whose behalf are you testifying?**

11 A: I am testifying on behalf of Utah Clean Energy (UCE).

12 **Q: Please provide your professional experience and qualifications.**

13 A: I am the Director and proprietor of Flink Energy Consulting LLC. I began Flink
14 Energy in October 2014; however my career in the power industry is in its fourth decade,
15 having started at the Bonneville Power Administration (BPA) in 1982. I worked at BPA
16 in a number of capacities until 1996, ranging from power system planner and hydro
17 modeling to risk management and runoff forecasting. After BPA, I worked for PacifiCorp,
18 also in a number of capacities that included contract pricing and structuring analysis, risk
19 management, power system modeling, and renewable resource acquisitions. I performed
20 PacifiCorp's first wind integration cost study for its 2003 IRP. After nine years at
21 PacifiCorp, I spent four years at Renewable Northwest Project (now Renewable
22 Northwest) as their Research Director, primarily working on wind integration and
23 integration cost issues. I spent two years each at the Northwest Power and Conservation

24 Council and at Ecofys, a sustainable energy consulting firm headquartered in The
25 Netherlands. I authored a book on wind integration cost methods in 2010¹ and was an
26 invited coauthor to a second book on renewable energy integration published in 2014². I
27 have authored or coauthored a number of articles relating to renewable resource
28 integration and capacity valuation methods, including two of the papers referenced in the
29 Company's direct testimony of witness Rick Link, Exhibit RTL-2³. One of the papers
30 was a survey of wind power capacity valuation methods⁴. I hold a master's degree in
31 physics from the University of New Hampshire, 1982.

32

33 **Q: Have you testified previously before this Commission?**

34 A: No.

35

36 **POSITION & RECOMMENDATIONS**

37 **Q: Please summarize your position in this matter.**

38 A: PacifiCorp's results from their Capacity Factor Approximation Method (CFAM)
39 analysis are significantly lower than the results presented in NREL's meta-study of
40 capacity values and methods⁵ as well as the results from a recent analysis reviewing the
41 Western Electricity Coordinating Council's (WECC) Transmission Expansion Planning

¹ *Valuing Wind Energy on Integrated Power Systems*, Elsevier, September 2010

² *Renewable Energy Integration: Practical management of variability, uncertainty, and flexibility in power grids*, edited by Lawrence E. Jones, Academic Press, 2014.

³ See references [2] and [20] on pages 28 and 29 respectively of RMP_(RTL-s): *Comparison of Capacity Value Methods for Photovoltaics in the Western United States*, NREL, 2012.

⁴ *Capacity Value of Wind Power*, IEEE Transactions on Power Systems, May 2011, Keane, Milligan, et al.

⁵ *Comparison of Capacity Value Methods for Photovoltaics in the Western United States*, NREL, 2012. This presentation shows capacity values for solar well above 40% in eight of ten analyses. The two exceptions were in Portland General Electric's system (~30%) and Toronto (~30-45%).

42 Policy Committee (TEPPC)⁶. Because of this, and because a model's results are only as
43 good as the inputs and assumptions that are used in the modeling, I thoroughly examined
44 the underlying inputs and assumptions used by PacifiCorp in their capacity contribution
45 analysis in order to verify the validity of their results. My testimony addresses two major
46 issues with PacifiCorp's inputs and assumptions, which significantly affect their
47 calculated capacity values for wind and solar resources. My testimony does not include a
48 review of the LOLP analysis that was a precursor to PacifiCorp's CFAM analysis. My
49 silence on any component of the LOLP or CFAM analysis should not be construed as
50 agreement with the Company's methods, assumptions or results.

51

52 The first issue has to do with applying the Capacity Factor methodology to the PacifiCorp
53 system *as a whole* instead of focusing on the capacity contribution of East side resources
54 to meeting East side loads. If PacifiCorp could freely transfer power across its system
55 during peak demand periods, their analysis would not have been problematic on this
56 point; however, PacifiCorp's system has practical transfer capability limitations at peak
57 periods—to transfer resources from the East side to the West side. This suggests that no
58 incremental east side resources, irrespective of their type or availability, would reduce
59 West-side winter-time outages.

60

⁶ Comparing Resource Adequacy Metrics (Conference paper preprint), Ibanez and Milligan, November 2014, NREL/CP-5D00-62847. The review found that TEPPC's assumed 60% capacity factor was applicable to the Arizona, New Mexico, and Nevada regions.

61 In other words, including West side winter time loss of load events in the calculation
62 unfairly dilutes meaningful capacity contributions of additional East-side renewable
63 resources. As I explain below, a more accurate estimate of the capacity value of resources
64 built on the East side (i.e., in the Rocky Mountain Power service territory) would be to
65 measure the ability of those incremental resources to reduce outages within the Rocky
66 Mountain Power territory, not within the combined system.

67

68 The second issue relates to PacifiCorp's planned maintenance schedule assumptions,
69 which are overly aggressive for [REDACTED] and place too much emphasis on renewable
70 resource performance in that month, further diluting their effective capacity contribution
71 values. The Company's maintenance schedule assumptions results in a disproportionate
72 number of calculated loss of load events [REDACTED]—nearly [REDACTED] of the Company's annual
73 loss of load events—due to a disproportionate amount of assumed thermal unit
74 maintenance in that month ([REDACTED] planned maintenance outages than in any
75 other month).

76

77 I recommend that PacifiCorp re-run the study to correct these two major shortcomings.
78 My analysis, based on the Company's data and calculations, estimates that the result of
79 correcting these shortcomings would have a very large effect on the capacity value of
80 renewable resources. It would slightly increase the capacity value for wind and also
81 increase the capacity value for solar to values that are more in line with the values found

82 in other analysis of solar capacity values in the arid west and the values found in NREL's
83 meta-analysis of different methods⁷.

84

85 **REVIEW OF PACIFICORP'S CAPACITY CONTRIBUTION STUDY**

86 **Q: Can you explain what the Capacity Factor Approximation Method is?**

87 A: Yes. The capacity factor approximation method is one of several methods used to
88 estimate the contribution of resources to meeting demand. Historically, when generation
89 was comprised mainly or entirely of dispatchable resources, utilities would simply add up
90 the nameplate capacities of their generating units and compare the total with peak
91 demand. Given that generating units break down and need maintenance, and because
92 peak demand is somewhat uncertain, utilities strove to maintain more generating
93 capability than expected peak demand. Maintaining power system adequacy requires
94 having more generating capability than expected demand by a buffer amount. This buffer
95 amount is often termed the "Planning Reserve Margin."

96

97 Variable resources, such as wind and solar, have operating characteristics significantly
98 different from conventional resources, so utilities recognized a need to calculate capacity
99 contribution values that were more consistent with and comparable to the capacity
100 contribution values of conventional resources in order to conduct accurate resource
101 adequacy analysis. The Capacity Factor Approximation Method is one method of
102 calculating equivalent capacity contribution figures for variable energy resources.

⁷ *ibid.*

103

104 **Q: Are you saying that methods to determine a capacity credit were devised to**
105 **calculate the contribution of renewable energy resources for the purposes of**
106 **computing resource adequacy?**

107 A: Yes. One megawatt of wind or solar generator nameplate capacity is not the same
108 as one megawatt of a conventional resource nameplate capacity when it comes to meeting
109 peak demand. Some means of taking account of the fact that these resources do
110 contribute to system adequacy, though in a lesser way than conventional resources, was
111 deemed necessary. The key here is coming up with a method to find a capacity value for
112 renewable resources that can make them consistently comparable to conventional
113 generation resources in meeting the planning reserve margin.

114

115 **Q: How does the Capacity Factor Approximation Method Work?**

116 A: In effect, the capacity factor approximation method looks at the expected
117 performance of variable resources at times when the utility would otherwise be short of
118 energy to serve load. If the variable resources are expected to produce their maximum
119 power capability at times when the utility would otherwise be short, they get a high
120 credit. Conversely, if the utility is likely to be short at times when the resource is
121 expected to produce very little power (e.g., solar power on winter nights), then the
122 capacity credit is very low—potentially zero.

123

124 The capacity factor approximation method takes a weighted average of expected resource
125 availability over hours that the utility is most likely to be short of meeting demand.

126 Weighting of resource availability is determined in relation to the likelihood that the
127 power system will experience an outage in each hour of the year. Likelihood of outages is
128 often determined, as the Company has done, by running a “stochastic” study in which a
129 number of scenarios are examined. Each scenario consists of selections of loads and
130 resource availability from some pre-determined probability distributions. In a reasonably
131 adequate power system (one that has sufficient resources to meet demand under most
132 circumstances), most hours will have zero outages. In only a few relatively extreme cases
133 (e.g., high loads and high unit outages) will there be any outages.

134

135 As an example, assume that a study shows only two hours of the year where the utility
136 was short. Say one of the hours is in the middle of the night when solar power is
137 unavailable, and that the other hour happens to be in the middle of a summer day when
138 the solar plant is expected to produce at 80% rated output. If the daytime outage is three
139 times more likely to occur than the nighttime outage the Capacity Factor method would
140 calculate the overall contribution as follows:

141 (Relative Likelihood in Hour 1) X (Resource Availability in Hour 1) +
142 (Relative Likelihood in Hour 2) X (Resource Availability in Hour 2) =
143 25% X 0% + 75% X 80% = 60%

144

145 **Q: What assumptions are critical to this calculation?**

146 A: There are two main components to the calculation—the weights established for
147 each hour of the year, representing relative potential for shortfalls in meeting load, and
148 the availability of resources in each of those hours. However, there is a less apparent

149 assumption the Company makes that calls into question the appropriateness of their
150 approach.

151

152 PacifiCorp's system is divided into a West-side balancing authority and an East-side
153 balancing authority. The Company's application of the Capacity Factor Approximation
154 Method implicitly treated the two sides of the system as though they were an integrated
155 whole. This is in my view a critically important assumption because the Capacity Factor
156 Approximation Method is not broadly applicable to systems with significant transmission
157 constraints. It calls to question the validity of the results of PacifiCorp's analysis.

158

159 **Q: Can you explain why applying the Capacity Factor Approximation Method**
160 **to PacifiCorp's combined system is not appropriate?**


161 A: The two sides of PacifiCorp's system are relatively loosely connected by its
162 transmission system. Because loads on the East side of the system (Rocky Mountain
163 Power) tend to peak in the summer, surplus resources on the West side fill the
164 transmission lines heading east. Generally there is more generating capability in the East
165 than is needed in the East during the winter because loads are lower there at that time of
166 year than in the summer; however, the practical effect of limited transfer capability going
167 from east to west in the winter means that not all of those East-side resources are able to
168 contribute to meeting West-side load.

169

170 What this suggests is that *incremental* resources on the Rocky Mountain Power side of
171 the system cannot affect resource adequacy in the West during the winter, just as resource

172 additions on the West side can't help meet Rocky Mountain Power's summer peak
 173 demand. The figure below from PacifiCorp's 2015 IRP shows the two transmission paths
 174 across southern Idaho (Borah to Midpoint and Borah to Hemingway) that limit
 175 PacifiCorp's East-West access⁸.

Figure 7.2 – Transmission System Model Topology



176

177

178 In effect, including West-side winter outages in the Capacity Factor Approximation
 179 Method computation incorrectly values the actual contribution of East-side renewable
 180 resources compared with East-side conventional resources—the original purpose of the

⁸ In the Company's response Confidential Attachment OCS 3.10-2 the Combined Borah Midpoint and Hemingway transfer capability [REDACTED]

181 Capacity Factor Approximation Method. RMP's Capacity Factor Calculation workbook
182 shows that [REDACTED] of all loss of load events occurring in the study happened in the
183 December through February period, when it is unlikely that any type of resource addition
184 on the East side would materially affect loads on the West side due to full transmission
185 capacity going from east to west.

186

187 **Example:**

188 Assume that a system consists of an East and West side that are connected by a
189 1,000 MW transmission line that allows power to flow in both directions. Say that
190 the West side peaks in the winter time when the East side has 1,500 MW of
191 surplus power—generating capability in excess of what is needed in the East in
192 that hour. During a peak hour in the West, once 1,000 MWs of power fill the
193 transmission capability from east to west, the remaining East side resources can
194 no longer provide assistance. If the West is still short, adding another power plant
195 in the East only has the effect of making the East more surplus. It is this situation
196 that makes PacifiCorp's broad application of the capacity factor approximation
197 method misleading.

198

199 The purpose of developing a capacity contribution method is to assess the contribution of
200 variable resources *relative to conventional generation*. Conventional generation located
201 on the west side would not significantly contribute to meeting West-side loads because of
202 the transmission constraints. A fair capacity valuation method seeks to set an equivalency
203 between variable and conventional resources. Basing the calculations on PacifiCorp's

204 entire system effectively compares variable resources to an impossible conventional
205 resource located simultaneously on both sides of PacifiCorp's system. The effect is most
206 prominent for solar resources, substantially understating them on the East side of the
207 system and overstating their capacity contribution to the West side. *If there is*
208 *transmission congestion during peak demand hours, new conventional generation*
209 *located on the East side can't contribute to West side winter demand any more than the*
210 *solar plants.*

211

212 **Q: Are you certain that PacifiCorp's system is transmission-constrained during**
213 **winter time loss of load events?**

214 A: I was not able to completely corroborate that conclusion from the available data
215 yet⁹, but this has been a long-standing issue with the Company I am aware of from the
216 time that I worked there.

217

218 **Q: Did you examine data supplied by the company that addresses this concern?**

219 A: Yes, although the transmission loadings are not yet available, I looked at the
220 Company's response to DR OCS 3.10 ("Attachment OCS 3.10-3"). That set of Excel
221 workbooks purports to contain energy not served for each area in the model, in each hour,
222 for each iteration.

223

⁹ UCE submitted the following data request to PacifiCorp, for which we are awaiting a response: "Please provide transmission path loadings over each of the loss of load event hours."

224 My expectation was to see west side outages dominating in winter, and east side outages
225 dominating in summer, with a separate significant grouping [REDACTED] due to the
226 maintenance effects previously discussed. However, the data was not as expected. The
227 most obvious anomaly was with the Colorado. There were more than 20,000 counts of
228 energy not served there, in contrast to just over a thousand in the rest of the areas
229 combined. These values are not consistent either in number or timing with the
230 Company's initial filing.

231

232 Discounting the anomalous Colorado numbers left just over 1,000 loss of load events.
233 Although there was a large percentage of them in April, the winter loss of load events are
234 shown occurring in Wyoming on the East side. It is unclear whether this finding, if I am
235 reading their data correctly, is reasonable. For example, if these loss of load events are
236 associated with assumptions around weather-driven uncertainties applicable to the energy
237 sector generally, they may not be applicable to the Wyoming area which consists
238 primarily of industrial loads of the oil and gas development sector.

239

240 We will need additional information from the Company to reconcile their response in
241 Attachment OCS 3.10-3 with their other analysis to fully understand their calculations.

242

243 **Q: Given the limited east to west transfer capabilities, did you calculate how the**
244 **capacity value for solar would change if the capacity value was calculated based on**
245 **an East-side solar project providing electricity to the East side of the PacifiCorp**
246 **system?**

247 A: I was not able to do a complete analysis, but I was able to observe the effect of
 248 removing winter month outages from the computation. This represents a rough
 249 approximation of the effects of running an East-side only study under the assumptions
 250 that winter-time loss of load events occurred on the West side at times of transmission
 251 congestion.

252

253 **Q: What is the effect on capacity contributions from removing winter-time loss**
 254 **of load events from RMP's calculation?**

255 A: The effect was greatest on Utah solar capacity values, increasing Milford Solar
 256 Fixed and Single Axis Tracking in the range of 10 to 13 percentage points to 44.4% and
 257 52%, respectively. Below is a table of the full results.

258

259 Results from RMP Capacity Factor Calculation Workbook as submitted:

	Wind			Solar PV					
	West	East	Weighted Average	Lakeview, OR Fixed Tilt	Milford, UT Fixed Tilt	Average Fixed Tilt	Lakeview, OR Single Axis Tracking	Milford, UT Single Axis Tracking	Average Single Axis Tracking
Peak Capacity Contribution (PacifiCorp)	25.4%	14.5%	18.1%	32.2%	34.1%	33.1%	36.7%	39.1%	37.9%
Interim Capacity Contribution (Utah Commission)			20.5%			68.0%			84.0%

260

261

262 Results from RMP Capacity Factor Calculation Workbook, after removing [REDACTED]

263 loss of load events:

	Wind			Solar PV					
	West	East	Weighted Average	Lakeview, OR Fixed Tilt	Milford, UT Fixed Tilt	Average Fixed Tilt	Lakeview, OR Single Axis Tracking	Milford, UT Single Axis Tracking	Average Single Axis Tracking
Peak Capacity Contribution (PacifiCorp)		16.4%			44.4%			52.0%	
Interim Capacity Contribution (Utah Commission)			20.5%			68.0%			84.0%

264

265

266 **Q: Please explain your methods and findings.**

267 A: The values computed above were derived by simply setting all loss of load events
268 to zero in the Company's workbook in the December through February period ("Hourly
269 LOLP" worksheet, cells B3:Y61, B337:Y367). The workbook automatically recomputed
270 the values above, found on the "Summary" worksheet in cells B1:K4. The result is an
271 increase in solar capacity credit to 44.4% for fixed tilt and 52% for single axis tracking
272 solar.

273

274 **Q: What do you conclude from your analysis?**

275 A: The analysis suggests that the Capacity Factor Approximation Method is
276 extremely sensitive to the assumptions used in the model and that consideration of the
277 balancing area that resources serve is critical in accurately calculating the capacity value.
278 Solar resources are very effective in meeting east side loads, providing much more
279 capacity value relative to conventional resources than they are at providing winter
280 capacity needs on the west side. If transmission is congested during peak demand
281 periods, solar provides much more value than the present study suggests. Transmission
282 congestion becomes a key question. The Company's application of the Capacity Factor
283 Approximation system is not accurate when there are significant transmission limitations.

284

285 East side resource capacity contribution should be evaluated relative to east side
286 conventional generation. That means *excluding* West side loss of load events from the
287 calculation that occur at the same time transmission is constrained. In my opinion, it is

288 inclusion of the West side loss of load events that accounts primarily for the Company's
289 method arriving at numbers far lower than other calculations of this nature. To
290 accurately characterize the capacity value of East-side renewable energy resources, the
291 capacity value should be calculated based on the East side balancing area.

292

293 **Q: If there were unlimited transfer capability between the East and West side of**
294 **the system, how might this change the capacity value of solar on the East side of the**
295 **system?**

296 A: That would be an interesting study, but I can't easily estimate what the effects
297 would be, because it would require rerunning the LOLP study with unlimited transfer
298 capabilities. The model would find fewer loss of load events, and it might be necessary to
299 run more than 500 iterations in order to get reliable LOLP statistics. How it affects a
300 summer peaking resource like solar depends on whether the majority of loss of load
301 events occur on the west side in the winter, or the east side in summer. The latter would
302 tend to increase the capacity value of solar, whereas the former would reduce it. That
303 said, unless there actually are unlimited transfer capabilities, the analysis would give
304 results for loss of load probability and capacity value that do not reflect PacifiCorp's
305 actual circumstances.

306

307 **Q: Are there other issues with study assumptions?**

308 A: There are a few other technical issues, but the one that has the largest effect after
309 the combined-system assumption above, is the undue effect of assumed maintenance
310 schedules on the results. Certain loss of load events in the Company's study are an

311 artifact of the company's overly-aggressive assumptions about the level of maintenance
312 outages [REDACTED].

313

314 **Q: How do maintenance schedules affect the results?**

315 A: Maintenance schedules are periods of time when generators are intentionally
316 taken out of service for routine or special maintenance needs. If at all possible, generators
317 are only taken out of service at times of the year when they are least needed (and loss of
318 load probability is lowest), and when market prices (e.g., for purchasing replacement
319 power) are lowest. From the Company's data request responses in OCS 2.3 and 2.7, it is
320 apparent that the maintenance schedules followed the usual pattern, concentrating
321 maintenance outages in [REDACTED]; three of the four lowest peak demand
322 months (a smaller amount of maintenance is also scheduled in [REDACTED]). Scheduling
323 maintenance in that way is designed to minimize potential shortfalls in the ability to meet
324 load.

325

326 However, there can also be too much of a good thing. If too much maintenance is
327 scheduled in a single month, it can result in additional loss of load events. In other words,
328 maintenance outages are normally set to have no effect on the ability to meet load, but it
329 can result in additional loss of load if too many generators are taken out of service at a
330 given time. In this case, it appears that PacifiCorp could have avoided loss of load events
331 by moving [REDACTED]
332 [REDACTED] (which I discuss further below).

333

334 **Q: How did the Company’s assumed maintenance schedule affect the results of**
335 **their study?**

336 A: Again, according to OCS 2.7, the company used an assumed maintenance
337 schedule with a disproportionate amount of outages in [REDACTED]
338 [REDACTED]. The effect of this is fairly dramatic. Again
339 from the Company’s Capacity Factor Calculation workbook, almost [REDACTED]
340 [REDACTED]. In contrast, even though the Company’s loads are [REDACTED]
341 [REDACTED] of loss of load events in that month. Moving just a [REDACTED]
342 [REDACTED]
343 [REDACTED]
344 [REDACTED]. Ideally, maintenance schedules should be informed by LOLP
345 studies to minimize the potential for loss of load.

346
347 The issue with this is that the loss of load events [REDACTED] affected the capacity
348 contribution calculation. In fact, NREL’s study on which the Company’s analysis is
349 based¹⁰ suggests excluding all but the highest load hours in the application of the
350 Capacity Factor Approximation Method in order to avoid such anomalous results.
351 Moreover, the loss of load events are entirely an artifact of assuming too much
352 maintenance [REDACTED]. If some [REDACTED]
353 [REDACTED]

¹⁰ See attachment Rick Link’s testimony Exhibit RMP (RTL-2) page 6: “A third technique uses the highest-load hours but normalizes the capacity factors by the LOLPs.” RMP appears to have used this method in normalizing LOLPs, but not applying them only to the “highest-Load” hours. The Company’s April loads are not particularly high and presumably would have been excluded in a literal application of the method.

354 [REDACTED]
355 [REDACTED]. There is no necessity for loading so
356 much maintenance [REDACTED], and clearly doing so at the expense of maintaining system
357 reliability is not something the Company would actually do if it could possibly help it. I
358 am not suggesting any changes to actual maintenance schedules—schedules that will not
359 be prepared for years to come—only the model assumption that so much of the needed
360 maintenance will occur [REDACTED].

361
362 The potential for maintenance schedule assumptions can be critical. For example, if all
363 the maintenance were scheduled for January and February, solar resources would have
364 nearly zero capacity value in the computation. If scheduled in June and July, the capacity
365 value would soar to near 100%. The maintenance schedules need to be carefully
366 considered.

367
368 **Q: Can the Company change maintenance schedules as easily as you imply?**
369 **A:** There are typically constraints on when maintenance can occur. It can be affected
370 by equipment warranties, availability of crews and equipment to perform maintenance,
371 and immediacy of the need for maintenance. That said, the study's maintenance
372 schedules are simply placeholders for what might be expected to occur many years from
373 now during the resource insufficiency period. In other words, there is plenty of time to
374 adjust the schedule if that were advisable. In this case, the Company simply appears to
375 have made an assumption about the schedule that was a little too aggressive. Moving just

376 a few hundred megawatts of maintenance from [REDACTED]
 377 [REDACTED].

378

379 **Q: Why do you recommend March?**

380 A: The study had zero maintenance [REDACTED] having the fourth
 381 lowest peak load. Given that the [REDACTED] than
 382 any other month, it is reasonable and appropriate to move some of these maintenance
 383 outage megawatts [REDACTED].

384

385 And again, I am not recommending that the Company make any changes to its actual
 386 maintenance schedules. The study’s maintenance schedules are merely placeholders for
 387 maintenance schedules many years down the road in the resource insufficiency period. It
 388 is reasonable to assume that a few hundred megawatts of maintenance can and will be
 389 moved [REDACTED], rather than assuming such extreme levels of maintenance outages [REDACTED]
 390 [REDACTED].

391 **Q. Can you estimate the impact of a more moderate maintenance schedule?**

392 A. I was able to see the effect of removing the [REDACTED] loss of load events on the
 393 capacity credit calculations. The table below illustrates the findings.

394

395 Results from RMP Capacity Factor Calculation Workbook as submitted:

	Wind			Solar PV					
	West	East	Weighted Average	Lakeview, OR Fixed Tilt	Milford, UT Fixed Tilt	Average Fixed Tilt	Lakeview, OR Single Axis Tracking	Milford, UT Single Axis Tracking	Average Single Axis Tracking
Peak Capacity Contribution (PacifiCorp)	25.4%	14.5%	18.1%	32.2%	34.1%	33.1%	36.7%	39.1%	37.9%
Interim Capacity Contribution (Utah Commission)			20.5%			68.0%			84.0%

396

397

398 Results from removing April loss of load events:

	Wind			Solar PV					
	West	East	Weighted Average	Lakeview, OR Fixed Tilt	Milford, UT Fixed Tilt	Average Fixed Tilt	Lakeview, OR Single Axis Tracking	Milford, UT Single Axis Tracking	Average Single Axis Tracking
Peak Capacity Contribution (PacifiCorp)		13.1%			37.0%			40.2%	
Interim Capacity Contribution (Utah Commission)			20.5%			68.0%			84.0%

399

400

401 **Q. Given that you recommend that both of these modeling assumptions should**
 402 **be corrected to fairly calculate the capacity value of renewable resources, did you**
 403 **examine the combined effects of a more moderate maintenance schedule and**
 404 **calculating capacity credit based on an East side examination?**

405 **A. Yes, I did. The combined effects are shown in comparison to PacifiCorp’s**
 406 **findings in the pair of tables below:**

407

408 Results from RMP Capacity Factor Calculation Workbook as submitted:

	Wind			Solar PV					
	West	East	Weighted Average	Lakeview, OR Fixed Tilt	Milford, UT Fixed Tilt	Average Fixed Tilt	Lakeview, OR Single Axis Tracking	Milford, UT Single Axis Tracking	Average Single Axis Tracking
Peak Capacity Contribution (PacifiCorp)	25.4%	14.5%	18.1%	32.2%	34.1%	33.1%	36.7%	39.1%	37.9%
Interim Capacity Contribution (Utah Commission)			20.5%			68.0%			84.0%

409

410

411 Results from removing [REDACTED] and [REDACTED] loss of load events:

	Wind			Solar PV					
	West	East	Weighted Average	Lakeview, OR Fixed Tilt	Milford, UT Fixed Tilt	Average Fixed Tilt	Lakeview, OR Single Axis Tracking	Milford, UT Single Axis Tracking	Average Single Axis Tracking
Peak Capacity Contribution (PacifiCorp)		15.3%			67.0%			73.4%	
Interim Capacity Contribution (Utah Commission)			20.5%			68.0%			84.0%

412

413

414 These results are more aligned with other reported capacity value analyses.

415

416 **Q: Can you summarize the changes you recommend?**

417 A: Yes. The company should either re-run the analysis with an East side scope or
418 else demonstrate that loss of load events during the winter time are not coincident in time
419 with transmission congestion. The Company should also either re-run the study with 200-
420 400 MW of maintenance moved from [REDACTED] to some other month ([REDACTED] is a good
421 candidate). Failing that, the weights for [REDACTED] ought to be excluded, either because it is
422 likely that a revised maintenance schedule would have that result or because their
423 inclusion is inconsistent with the NREL method, or both.

424

425 If winter loss of load events in Wyoming dominate wintertime loss of load, we need to
426 better understand the assumptions that resulted in the events and determine the
427 underlying causes and the applicability to the Capacity Factor Approximation Method.

428

429 **CONCLUSION**

430 **Q: Please summarize your conclusions and recommendations.**

431 A: I conclude that the Company's study finds a much lower capacity credit for
432 renewable resources than other such studies for two main reasons:

433 1) It dilutes the capacity value of solar by averaging its contribution across
434 PacifiCorp's system—this would make sense *but for* the fact that there is

435 insufficient transmission from east to west to make the capacity credit a sensible
436 comparison to conventional resources.

437 2) The Company's study assumed too much maintenance in [REDACTED], which ends up
438 overstating the effect of renewable resource availability in the spring.

439 3) In the loss of load analysis for the Capacity Factor Approximation Method
440 assumptions around load uncertainty need to be revisited.

441

442 The Company can remedy these issues by re-running the analysis including only East
443 side loss of load events, and moving some maintenance schedules from [REDACTED]
444 [REDACTED]. The practical effect of these changes would be to diminish or eliminate the
445 weights established in the present study in [REDACTED] and the winter months, resulting in a
446 capacity credit that more accurately reflects wind and solar capacity values.

447

448 **OTHER ISSUES**

449 **Q: Do you have any other comments on the study?**

450 A: Yes, one other issue bears mentioning. The Company used TMY data, or "Typical
451 Meteorological Year" data to produce its solar generation profiles. These profiles are
452 publicly available data sets based on historically "typical" weather, which are not time
453 correlated to the meteorological data underlying the Company's load forecasts.
454 Ultimately, this produces incorrect results.

455

456 Evaluations of capacity contribution, for example, for solar resources, such as those
457 based on LOLP, should be based on solar data that is time correlated with load rather

458 than based on “typical meteorological year” (TMY) data. If load is simulated based on
459 assumed temperatures, then the underlying meteorological data set should be the same for
460 both the solar profile and the load. For example, the underlying data might include solar
461 irradiance, temperature, and wind speed. In any given simulation hour, the same data
462 should be used to simulate solar production and simulate load. If load and solar output are
463 based on meteorological conditions for different times (such as taking “typical” data from
464 different years), then the relationship between solar production and load is lost and the
465 evaluation method will miss an important effect.

466

467 While I think this represents a significant issue, solutions to it remain relatively scarce at
468 this point. I raise it because it should be monitored and remedied going forward.

469

470 **Q: Does that conclude your testimony?**

471 **A: Yes.**