

1 **Q. Are you the same Rick T. Link that submitted direct testimony in this**
2 **proceeding?**

3 A. Yes.

4 **INTRODUCTION AND SUMMARY**

5 **Q. What is the purpose of your rebuttal testimony?**

6 A. The purpose of my rebuttal testimony is to respond to the direct testimony of Mr.
7 Ken Dragoon filed on behalf of Utah Clean Energy (“UCE”). UCE expressed
8 concern with the Company’s modeling and certain assumptions used when
9 calculating capacity contribution values for wind and solar resources. I also
10 comment on the direct testimony of Mr. Charles E. Peterson filed on behalf of the
11 Division of Public Utilities (“DPU”).

12 **Q. Please summarize your rebuttal testimony.**

13 A. My rebuttal testimony affirms that the capacity contribution values proposed by the
14 Company in this proceeding for wind and solar resources located in Utah are
15 accurately calculated and are reasonable. I specifically address concerns raised by
16 UCE related to the Company’s modeling and planned maintenance assumptions.
17 My rebuttal testimony demonstrates that:

- 18 • The Company’s capacity contribution study applies the capacity factor
19 approximation method (“CF Method”) as outlined by National Renewable
20 Energy Laboratory (“NREL”) and is consistent with the Commission’s
21 order in Docket No. 12-035-100 (“Phase II Order”).
- 22 • The Company’s capacity contribution study is appropriately based upon
23 system-wide reliability metrics and is consistent with long-term resource

24 planning processes and system operations.

- 25 • The Company's capacity contribution study appropriately applies
26 forecasted planned maintenance outage assumptions when calculating
27 capacity contribution values for wind and solar resources.

28 **METHODOLOGY**

29 **Q. Have you reviewed the direct testimony filed by the DPU?**

30 A. Yes. The DPU reviewed the Company's filing and calculations, and found that the
31 proposed wind and solar capacity contribution values are reasonable. The DPU
32 concluded that:

33 "...the Company has complied with the Commission order in Docket 12-
34 035-100. The Division believes that the Company has provided estimates
35 using the best information available to it and that it has used an appropriate
36 and accepted method to calculate those estimates."¹

37 **Q. Did the DPU consult with any external experts in its review of the Company's**
38 **calculations?**

39 A. Yes. As noted by the DPU, parties in Docket No. 12-035-100 believed that one of
40 the methods reviewed by NREL should be used to calculate capacity contribution
41 values for wind and solar resources.² In this docket, and in compliance with the
42 Phase II Order, the Company used the CF Method as outlined by NREL, to develop
43 its capacity contribution values for wind and solar resources. To aid in its review
44 of the Company's study, the DPU requested that NREL review the Company's
45 calculations.

¹ Direct Testimony of DPU witness Mr. Charles E. Peterson at lines 207 – 211.

² This NREL study was provided as Exhibit RMP____(RTL-2) to my Direct Testimony.

46 **Q. Did NREL review the Company's capacity contribution calculations as**
47 **requested by DPU?**

48 A. Yes. NREL determined "that [the Company] has exactly followed the equations,
49 methodology, and assumptions in the NREL report, 'Comparison of Capacity
50 Value Methods for Photovoltaics in the Western United States.'"³

51 **SYSTEM MODELING**

52 **Q. Please describe UCE's concern with the Company's approach to modeling its**
53 **entire system.**

54 A. UCE questions the Company's application of the CF Method, claiming that the east
55 and west side of PacifiCorp's system should not be modeled as a single system.
56 UCE believes that incremental resources added on the east side of PacifiCorp's
57 system cannot contribute to reliability on the west side of PacifiCorp's system
58 because of limited transfer limits from the east to the west, particularly during
59 winter months. UCE also claims that the CF Method is not applicable to a system
60 with transmission constraints.

61 **Q. Do you agree with UCE's claim that the CF Method is not applicable to a**
62 **system with transmission constraints?**

63 A. No. UCE's claim implies that the CF Method is only applicable to systems with no
64 transmission constraints. This assertion implies that the CF Method can only be
65 applied to the most simple of transmission systems (i.e., systems that can be
66 modeled without any transmission topology). The NREL study that the Company

³ DPU Exhibit 1.1 to the Direct Testimony of DPU witness Mr. Charles E. Peterson.

67 relied upon when applying the CF Method to calculate capacity contribution values
68 for wind and solar resources does not identify limitations of the method when
69 applied to a system with transmission constraints.⁴

70 **Q. Are UCE's claims consistent with how the Company develops its integrated**
71 **resource plan ("IRP")?**

72 A. No. The Company develops one resource plan for its entire system. This planning
73 approach is consistent with how PacifiCorp operates its system and captures load
74 diversification benefits, resource diversification benefits, renewable integration
75 cost benefits, and market access benefits. In its IRP, PacifiCorp's diverse system is
76 simulated using a transmission topology that captures major load centers,
77 generation resources, and market hubs interconnected via firm transmission paths.

78 These transmission paths limit the amount of energy that can flow not only
79 between the east and west side of PacifiCorp's system, but also within the east side
80 and within the west side of PacifiCorp's system, at any given point in time.
81 Transmission path limits used in IRP modeling are based upon the firm
82 transmission rights of PacifiCorp's merchant function, including transmission
83 rights from PacifiCorp's transmission function and other regional transmission
84 providers. This modeling framework used in the IRP is the same modeling
85 framework used in the Company's application of the CF Method to develop the
86 wind and solar capacity contribution values proposed in this proceeding.

87 **Q. Do transmission paths between the east and west side of the Company's system**
88 **contribute to reliability of the system as a whole?**

⁴ The NREL study was provided as Exhibit___(RTL-2) to my Direct Testimony.

89 A. Yes. The east and west side of PacifiCorp's system are not isolated and are
90 interconnected via firm transmission. As dictated by system conditions (i.e., loads
91 and resource availability), energy can flow from east side resources to serve load
92 in the west. As system conditions change, energy can similarly flow from west side
93 resources to serve load in the east. This same concept applies not only between the
94 east and the west side of PacifiCorp's system but within the east and within the
95 west side of the system. In short, the transmission network provides redundancy by
96 enabling resources from across the system to serve load as system conditions
97 change, thereby contributing to reliability of the system as a whole.

98 **Q. Do east side resources contribute to system reliability on the west at times**
99 **when firm transmission paths from the east to the west are fully loaded?**

100 A. Yes. Under these circumstances, the transmission paths from east to west are fully
101 loaded *because* east side resources are being used to maintain reliability on the west
102 side of the system.

103 **Q. Can you identify precisely which east side resources are flowing to the west**
104 **under such circumstances?**

105 A. No. PacifiCorp dispatches system resources to meet system load. When
106 transmission from the east to the west is fully loaded, generation from all of the
107 resources in the east is contributing to meeting east side load and to the energy
108 flowing from the east to the west.

109 **Q. Is it appropriate to eliminate the contribution of east side wind and solar**
110 **resources to west side system reliability when transmission flows east to west**
111 **are fully loaded?**

112 A. No. If east side wind and solar resources are operating at the time energy is flowing
113 from the east to the west, then those east side wind and solar resources are
114 contributing to system reliability in the west. As such, the east and west side solar
115 resources are contributing to the overall capacity on the system even when east to
116 west side transmission flows are fully loaded.

117 **Q. Did UCE attempt to approximate the impact of isolating the east side of**
118 **PacifiCorp’s system on the capacity contribution values for wind and solar**
119 **resources?**

120 A. Yes. UCE attempted to approximate the impact of isolating the east side of
121 PacifiCorp’s system by removing all loss of load probability (“LOLP”) hours
122 during the winter months (December through February).⁵ UCE’s calculation is
123 based on a series of oversimplified assumptions. UCE’s calculation assumes that
124 all winter-month loss of load events occur on the west side of the Company’s
125 system; that during all of these events, transmission flows from the east to west are
126 fully loaded; and that east side resources make no contribution to west side
127 reliability when transmission paths are assumed to be fully loaded. Based on these
128 assumptions, UCE calculates that east side wind capacity contribution values would
129 increase from 14.5 percent to 16.4 percent, east side single axis tracking capacity
130 contribution values would increase from 39.1 percent to 52.0 percent, and that east
131 side fixed tilt solar capacity contribution values would increase from 34.1 percent
132 to 44.4 percent.

133 **Q. Do you agree with UCE’s assumptions and conclusions?**

⁵ LOLP measures the probability of load exceeding available resources over a given time interval. In the context of my rebuttal testimony, a LOLP hour is any hour in which the LOLP is greater than zero.

134 No. Winter-month loss of load events are not limited to the west side of the
135 Company's system. UCE's approximation effectively assumes that there is zero
136 risk of a loss of load event during the winter months in the east side of PacifiCorp's
137 system, and ignores other factors, beyond load (i.e., unplanned thermal unit
138 outages), that contribute to conditions where load might exceed available resources.
139 Considering that loss of load events are not restricted to the west side of
140 PacifiCorp's system during the winter months, it is also not appropriate to assume
141 that all winter-month loss of load events are accompanied by system conditions in
142 which transmission flows from east to west are fully loaded. Finally, as discussed
143 above, east side resources that are operating during west side loss of load events
144 when east to west transmission is fully loaded are contributing to system reliability.

145 **Q. If one assumed that east side wind and solar resources should be restricted to**
146 **only providing capacity to the east side of the Company's system, would the**
147 **Company's proposed capacity contribution values be materially impacted?**

148 A. No. Using the same hourly LOLP data from the Company's capacity contribution
149 study, eliminating all LOLP hours in the *west side* of the system (as opposed to all
150 such winter hours across the entire system), yields capacity contribution values that
151 are reasonably comparable to those proposed by the Company in this proceeding.
152 Table 1 summarizes the capacity contribution value results proposed by the
153 Company in this proceeding alongside results isolated to LOLP hours on the east
154 side of the Company's system.

Table 1

	East Side Wind and Solar Capacity Contribution		
	Wind	Fixed Tilt Solar PV	Single Axis Tracking Solar PV
Company Filing	14.5%	34.1%	39.1%
East Only	13.7%	34.0%	38.5%
Difference	-0.8%	-0.1%	-0.6%

155 **Q. Are you suggesting that capacity contribution values for wind and solar**
 156 **resources located in Utah should be based solely upon east side LOLP hours?**

157 **A.** No. As discussed earlier in my testimony, it is appropriate to consider the entire
 158 system when calculating wind and solar capacity contribution values. I am simply
 159 highlighting that UCE’s calculations yield capacity contribution values that are not
 160 representative of capacity contribution values for east side resources when isolated
 161 to east side reliability events.

162 **Q. UCE also cited an anomaly in the energy not served (“ENS”) reported for the**
 163 **Colorado transmission area within the Company’s model topology. How do**
 164 **you respond?**

165 **A.** ENS is a model output that reports how much of the obligation in a given
 166 transmission area exceeds available resources for any given hour. The Company’s
 167 transmission topology includes transmission areas with different types of
 168 obligations. A load obligation is directly linked to system reliability—the focus of

169 capacity contribution values for wind and solar resources. A wholesale obligation,
170 representing a firm wholesale sale, is linked to economic risk, but is not a driver of
171 system reliability. The Colorado transmission area has a wholesale obligation, but
172 no load obligation. As such, the ENS data from the Colorado transmission area
173 cited by UCE was not used, and has no impact on, the wind and solar capacity
174 contribution values proposed by the Company in this proceeding.

175 **PLANNED MAINTENANCE**

176 **Q. Please describe UCE’s concern with the Company’s approach to modeling**
177 **planned maintenance outages.**

178 A. UCE raised concerns with the Company’s planned maintenance schedule
179 assumptions, claiming these assumptions are overly aggressive for the month of
180 April and “place too much emphasis on renewable resource performance in that
181 month, further diluting their effective capacity contribution values.”⁶

182 **Q. How does UCE propose to resolve the issue?**

183 A. UCE proposes to move a portion of planned maintenance outages from April to
184 March. UCE states that it does not recommend PacifiCorp change its actual
185 maintenance schedules, but believes that the maintenance schedules should be
186 changed for purposes of the capacity contribution study.

187 **Q. How do you respond?**

188 A. When determining hourly LOLP values used in the Company’s capacity
189 contribution study, the Company applied projected planned maintenance schedules
190 for specific generating units in its system that were available at the time the study

⁶ Direct Testimony of UCE witness Mr. Ken Dragoon at lines 69 – 71.

191 was being prepared. Arbitrarily moving planned maintenance to March is not
192 supported, and ignores the fact that March is at the tail end of the winter season
193 when there is a risk of higher loads and higher market prices, thereby ignoring the
194 risk of increased costs for PacifiCorp's customers. Moreover, it is inappropriate to
195 modify projected system operating assumptions as a means to alter capacity
196 contribution values for wind and solar resources.

197 **Q. What factors does the Company consider when scheduling planned**
198 **maintenance for its generating units?**

199 A. The Company considers a range of variables including but not limited to the
200 specific maintenance tasks, duration, permit obligations, weather, location,
201 availability of labor and/or contractors and materials, projected load and operating
202 reserve needs, generating capability, availability of other generation facilities
203 across the fleet, costs of replacement power, and availability of purchased power.

204 **Q. Did UCE attempt to approximate the impact of April planned maintenance**
205 **assumptions on the capacity contribution values for wind and solar resources?**

206 A. Yes. UCE approximated the impact of its proposal by completely eliminating all
207 LOLP hours from the month of April to estimate the impact of altering planned
208 maintenance assumptions on capacity contribution values for wind and solar
209 resources. Despite the fact that it is not reasonable to selectively exclude certain
210 periods from the calculation of capacity contribution values, UCE's calculations
211 show that under even the most extreme adjustment (eliminating *all* April LOLP
212 hours), the resulting capacity contribution values are reasonably comparable to
213 those proposed by the Company in this proceeding. Table 2 summarizes the

214 capacity contribution value results in the Company's filing alongside UCE's results
215 when all April LOLP hours are eliminated from capacity contribution calculations.

Table 2

	East Side Wind and Solar Capacity Contribution		
	Wind	Fixed Tilt Solar PV	Single Axis Tracking Solar PV
Company Filing	14.5%	34.1%	39.1%
UCE (No April)	13.1%	37.0%	40.2%
Difference	-1.4%	2.9%	1.1%

216 **Q. Have you calculated the number of LOLP hours eliminated by UCE in its**
217 **calculations when it combines its adjustment for winter loss of load events with**
218 **its adjustment for April planned maintenance?**

219 A. Yes. UCE's approximation of the impact of isolating the east side of the Company's
220 system and adjusting for April planned maintenance assumptions removes all
221 LOLP hours from the months of January, February, April, and December. After
222 eliminating these months from the calculation of wind and solar capacity
223 contribution values, UCE's calculation relies on just 114 LOLP hours, representing
224 only 1.3 percent of the hours in the year.

225 **OTHER CONSIDERATIONS**

226 **Q. Did the Company use the capacity contribution values proposed in this**
227 **proceeding in its 2015 IRP?**

228 A. Yes. The Company applied the same capacity contribution values that were filed in
229 this proceeding in its 2015 IRP. In the 2015 IRP, the proposed wind and solar

230 capacity contribution values are applied to new and existing wind and solar
231 resources. The 2015 IRP preferred portfolio includes 2,373 megawatt (“MW”) of
232 wind resources and 579 MW of solar resources. In aggregate, these wind and solar
233 resources have a capacity contribution value of 647 MW.⁷

234 **Q. Would higher capacity contribution values affect the Company’s need for new**
235 **resources?**

236 A. Yes. An increase to the capacity contribution values from those proposed by the
237 Company would reduce the need for new capacity. If the capacity contribution
238 values for wind and solar resources in the 2015 IRP were to increase by 10 percent,
239 these resources would contribute nearly 300 MW of incremental capacity to the
240 Company’s load and resource balance. An increase in the capacity contribution
241 value of 20 percent would contribute nearly 600 MW of incremental capacity to the
242 Company’s load and resource balance.

243 **Q. How might a change in capacity contribution values affect avoided cost prices**
244 **developed for Utah qualifying facility (“QF”) projects?**

245 A. The partial displacement differential revenue requirement (“PDDRR”) method
246 applies a capacity payment, taking into account the capacity contribution of a QF
247 resource, based on the fixed costs of a deferrable thermal resource during the
248 resource deficiency period. The determination of the resource deficiency period is
249 established by the timing of the Company’s next major generating resource as
250 identified in its IRP. As such, the capacity contribution value of wind and solar
251 resources not only influences the level of capacity payment, accounting for the

⁷ Volume I of PacifiCorp’s 2015 IRP, Chapter 5, Tables 5.5, 5.6, and 5.7.

252 relative difference between the capacity contribution value of the QF resource and
253 the next deferrable resource, but also the timing in which capacity payments are
254 applied. An increase in the capacity contribution value of wind and solar resources
255 might increase the capacity payment calculated using the PDDRR method;
256 however, a higher capacity contribution value might also delay when capacity
257 payments are applied if the need for new resources is deferred to a later date.

258 **CONCLUSION**

259 **Q. Please summarize the conclusions of your rebuttal testimony.**

260 A. The conclusions of my rebuttal testimony are as follows:

- 261 • The Company's capacity contribution study applies the CF Method as
262 outlined by NREL and is consistent with the Phase II Order.
- 263 • The Company's capacity contribution study is appropriately based upon
264 system-wide reliability metrics and is consistent with long-term resource
265 planning processes and system operations.
- 266 • The Company's capacity contribution study appropriately applies
267 forecasted unplanned maintenance outage assumptions when calculating
268 capacity contribution values for wind and solar resources.

269 **Q. What is your recommendation?**

270 A. The Company's proposed capacity contribution values for wind and solar resources
271 are reasonable and were calculated accurately. I recommend that the Commission
272 adopt the capacity contribution values proposed by the Company in this proceeding
273 for purposes of establishing capacity payments for wind and solar QF projects
274 under the PDDRR method.

275 Q. Does this conclude your rebuttal testimony?

276 A. Yes.