



State of Utah  
Department of Commerce  
Division of Public Utilities

FRANCINE GIANI  
*Executive Director*

CHRIS PARKER  
*Director, Division of Public Utilities*

GARY R. HERBERT  
*Governor*  
SPENCER J. COX  
*Lieutenant Governor*

## ACTION REQUEST RESPONSE

To: Utah Public Service Commission

From: Utah Division of Public Utilities  
Chris Parker, Director  
Energy Section  
Artie Powell, Manager  
Abdinasir Abdulle, Technical Consultant  
Charles Peterson, Technical Consultant

Date: July 31, 2014

Re: Docket No. 14-035-63. Rocky Mountain Power Major Event Report – April 22 – 24, 2014.

---

In its investigation of the Company's application for major event exclusion of the event that took place on April 22-24, 2014, the Division determined that the SAIDI threshold value (5.47 minutes) shown in the application did not exclude customer requested and pre-arranged outages. Based on data provided by the Company, the Division determined that the SAIDI threshold value is 6.48 minutes after the customer requested and pre-arranged outages were excluded. However, the Division inadvertently referred to the wrong cell. As shown in the attached spread sheet, the correct value should be 6.60 minutes.

Based on the Division's recommendation, the Commission directed the Company to file a corrected SAIDI threshold value (i.e., a corrected Page 2 of the major event) by July 31, 2014, or an explanation of why it is unnecessary to do so.

In compliance with the Commission's direction, on July 15, the Company filed a corrected page 2 of the major event application showing a SAIDI threshold value of 6.60 minutes. Based on the above discussion, the Division concludes that this filing satisfies the Commission's requirement.

CC: Dave Taylor, RMP  
Michel Beck, OCS