

**ROCKY MOUNTAIN POWER  
ELECTRIC SERVICE REGULATION NO. 5**

**STATE OF UTAH**

\_\_\_\_\_  
**Customer's Installation**  
\_\_\_\_\_

**1. SERVICE ENTRANCES AND CONNECTIONS**

**(a) Attachment to Company Facilities**

The Company will supply the exterior connection (service connection) between the Company's facilities and the point of delivery. The Customer shall provide a suitable service entrance to the premises to be served at the point specified by the Company. The Customer shall also provide a stationary and structurally sound support for the interconnection of the Company's and the Customer's facilities. The support shall be at a mutually agreeable location on the Customer's premises.

**(b) Metering Equipment**

All meter bases for meters required for measuring electric service (including kVar when specified by the Company) shall be provided and installed by the Customer at a location acceptable to the Company and shall conform to the Company's specifications. The Customer's wiring, meter bases and service entrance facilities must be installed and maintained by the Customer in accordance with applicable municipal or state requirements and to standards required by the National Electrical Safety Code and National Electrical Code. When, in the Company's judgment, profile data is required, the customer will provide the necessary communications links. The Company is not obligated to provide service when Customer's equipment and installation does not meet the required standards.

(continued)