

Rocky Mountain Power Reliability Management September 27, 2016



Let's turn the answers on.

Reliability Reporting - Today

- To provide transparency to the reliability process RMP annually selects five circuits based on Circuit Performance Index (CPI) score
 - CPI based on weighted values of sustained outages, momentary outages, and breaker operations
 - Develop and implement a proposed work plan to improve composite CPI score by 20% within five years
- Track and report annually on Worst Performing Circuits annually
- Part of the SQR


Reliability Today

- Parallel to the Worst Performing Circuit process RMP monitors reliability using near real time tools to identify and correct emerging reliability issues
- RMP proposes the existing WPC process be eliminated and implement an Open Reliability and Reporting (ORR) process
 - A summary of all reliability work is reported on a semi-annual basis
 - All reliability work is subject to audit

Reliability Management - ORR

1. Monthly Area Improvement Team (AIT) meetings are held to assess current reliability issues.
 - Participants include Operations management, Engineering, Substation Operations, and Capital Delivery
2. Close to real time
 - Close to real-time: Interruptions beyond threshold based on specific devices and numbers of customers served → FIRE Report
3. Periodic review of area reliability performance → GREAT Tool & other data
4. Implement plans that are developed and monitor their delivery
5. Review results & modify plan as needed



Reliability Management



1 Using FIRE and other tools
AIT look at emerging
reliability trends

2A Scope and develop
Reliability Work
Plans (RWP)


2B Develop first-cut costs and
forecast potential
improvements



4 Construct projects

3 Identify budget and
resources to
establish plan

5 Monitor and Report



1

Reliability Management - FIRE

FIRE

Frequent Interrupters Requiring Evaluation

[Back to History](#)

Report Date: 9/5/2016

[Previous Report](#) [Next Report](#)

Summary:

Select a device to see exceeded thresholds and outage details.

 There is a CAIDI investigation in this report

FIRE notification lets operations and engineering know when an interrupting device has experienced operations beyond expectable levels

	Op Area	Substation	Circuit	Device	FP	Thresholds Exceeded	Comments	Comments on other report dates	Reviews By AE	Reviews By NP	Reviews By OM
Select	BUFFALO	BUFFALO	4H425	OH_346000_492910201		1	2	0	2	0	0
Select	BUFFALO	BUFFALO	4H425	OH_346002_492910203		1	1	0	2	0	0
Select	CASPER	BAR NUNN	2G1	OH_178505_821990438		1	0	6	1	0	0
Select	REXBURG	SOUTH FORK	SFK13	SFK_CB13		2	2	2	2	0	2
Select	RIVERTON	LANDER	5H738	OH_079101_847940374		1	0	2	1	0	0
Select	ROCK SPRINGS	WESTVACO	9H300	WVA_CB9H300		2	1	7	2	1	0
Select	SLC METRO	OLYMPUS	OLY13	OH_367504_3486889		1	2	0	2	0	0
Select	TREMONTON	ROCKY POINT	RKP17	OH_088900_1711178518		1	0	1	2	0	2

Reliability Management -FIRE

Investigation into device performance can be performed by any FIRE user

This report has been reviewed by:

Area Engineer: **Yes** Area Engineering Manager: **Yes** Area Engineering Director: **No**
 Operations Manager: **No** Operations Director: **No** Operations Support Services: **No**
 Transmission Planning: **No** Reliability: **Yes** Executive: **No**

Outages:


[View Complete History for this Device](#) [View 12 Month Outage History for Circuit](#)

Outage #	Out Date Time	Cause Category	Direct Cause	Contributory Cause	Description	Customers Interrupted	Momentary Customers Interrupted	Customer Minutes Interrupted	Duration(mins)	Restoration Stages	Phase	Component	Safety Hold Flag	Begin Dev ID	End Dev ID
CWCC361522	9/4/2016 11:21:30 AM	OTHER	UNKNOWN		9H300 tripped open, patrolling, no cause found, closed & held. lightning suspected	48		10,119	211	1	ABC	NO DISTRIBUTION DAMAGE	N		
CWCC349978	2/21/2016 4:30:36 PM	PLANNED	INTENTIONAL TO CLEAR TROUBLE		opened to tie damaged CB 9H174 feeder to 9H300		36	106	3	1	ABC	PLANNED OUTAGE	N		
CWCC348971	2/6/2016 5:11:45 AM	OTHER	UNKNOWN		closed CB at sub on test held 1st responder will patrol line to 1st set of protection	39		621	16	1	ABC	NO DISTRIBUTION DAMAGE	N		
CWCC342351	10/9/2015 10:24:33 AM	OTHER	UNKNOWN		Circuit breaker locked open at substation	44		5,570	127	1	ABC	NO DISTRIBUTION DAMAGE	N		

1


Reliability Management - GREATER

Greater Thematics allow users to visually identify areas of greater concern and flexibility of viewing different levels of reliability from Area down to Customer Reliability




1

Reliability Management - GREATER



Reliability Management – Cost & Improvement

 ROCKY MOUNTAIN POWER <small>A DIVISION OF PACIFICORP</small>		Create Name	Reliability Work Plan	
AIT_16_07_20_Jordan Valley_Sandy_SDY16			Benefit of Plan Data	
Operations Manager Kim Felice	District Jordan Valley		Years of Data Represented	2
Prepared By Patricio Hernandez	Substation Sandy		Circuit Total Number of Incidents	157
Date Created 7/20/2016	Feeder Number/Name SDY16		Circuit Total Customer Minutes Lost	2,241,451
Program AIT	Investment Reason UR	Capital Cost \$130,000	O&M Cost \$5,500	Circuit Total Customer Interrupted 8,998
State Utah	Vegetation Management No	Construction Year 2017	Construction Year 2017	Annual Improved CML Total 140,053
Operations Manager:		Kim Felice	Approved Date	08/18/16
Field Engineering Manager:		Brian Oakeson	Approved Date	08/18/16
Field Engineering Director:		Ken Shortt	Approved Date	08/22/16
Recommendations:				
<i>Capital</i>				
1. Intercept existing 1000 AL cable and install one PME-9				
2. Remove 1-phase sectionalizing cabinets and install two 3-phase sectionalizing cabinets, FP# 187484, 186481.				
3. Replace 3 bituminous vaults with 1-phase sectionalizing cabinets, FP# 187613, 189608, 186906. (At existing vaults that serve as open points to loops)				
4. Install 500 ft of 3#2 AL from new PME-9 (FP# 187480 to 187484)				
5. Install 300 ft of 1#2 AL from new PME-9 (FP#187480 to 186481)				
<i>O&M</i>				
2. Repair 1-ph #2 AL cable from FP# 187480 to FP# 186705				
Summary:				
<i>This area has experienced 11 outages in the past 2 years due to a variety of causes: bad transformer, bad elbow, dig-in, bad cables. This will create an additional source into the area to serve customers, reducing the CML due to fewer customers affected.</i>				

2B Reliability Management – Cost and Improvement



Project Title:

AIT_16_07_20_Jordan Valley_Sandy_SDY16

Auto Isolation Point	Number of Downstream Customers	# of Incidents	Total CML	Total CI	Annual Benefit of Plan							Recommended Improvements		
					% of Total CML	% of Total CI	% Work Plan Fix?	CML Benefit of Plan	CI Benefit of Plan	Annual Improved CML	Annual Improved CI		Annual Improved RMP SAIDI	Annual Improved RMP SAIFI
JG184509_1518611699	261	11	373475	2872	16.66%	31.92%	75%	12.50%	23.94%	140,053	1,077	0.1280	0.0010	Adding new source to the area
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
					0.00%	0.00%		0.00%	0.00%	0	0			
Total Improvement Benefit					16.66%	31.92%		12.50%	23.94%	140,053	1,077	0.1280	0.0010	

Years of Data Represented	2
Circuit Total No of Incidents	157
Circuit Total Customer Minutes Lost	2241451
Circuit Total Customers Interrupted	8998
Annual Improved CML Total	140,053

Capital Cost	\$ 130,000	O&M Cost	\$ 5,500	Cost/CML or CI Saved	\$ 0.93	\$ 121
Total Capital and O&M Cost		\$130,000				

Manually populated
Auto-populated

Reliability Management – Budgeting

- Submit RWP for approval
 - Review committee consisting of:
 - Director, Area Planning and Field Engineering
 - Director of Operations
 - Director, Investment Delivery (Capital)
 - Manager, Wires Work Planning (O&M)
 - Four possible outcomes
 - Accepted and funded
 - Sent back for clarification
 - Held for future funding
 - Rejected

Reliability Management - Construction

- Project is detail estimated and constructed using standard processes
 - Tracking database updated with actual estimated cost
 - Tracking database updated with actual construction cost
 - Tracking begins when both capital and O&M work is completed

Reliability Management - Summary

- The company is diligent in delivering projects designed to improve system reliability.
- As better and more tactical approaches are devised the company evolves its processes to deliver better results at better costs.
- The company uses state of the art tools to support its improvement decisions.
- The company continually monitors performance to rapidly respond as conditions and facilities change.

Reliability Management - Summary

- The company proposes to eliminate the Worst Performing Circuit process and implement an Open Reliability and Reporting process

Reliability Management