

**ELECTRIC SERVICE SCHEDULE NO. 110 - Continued**
**Table 1. Builder Incentive Levels and Qualifying Equipment (continued)**

<u>Measure Type</u>	<u>Tier/Measure</u>	<u>Equipment</u>	<u>Single Family</u>	<u>Multi Family</u>
<u>Standalone Measure (additive to Whole Home Measures or prescriptive per home)</u>	<u>Premium Evaporative Equipment (non-whole house distribution system)</u>	<u>Premium evaporative equipment must be a permanently installed indirect, indirect/direct, or direct system utilizing rigid media. Premium Evaporative equipment is not required to deliver cooling through a whole-house distribution system to qualify for incentives.</u>	<u>\$500</u>	<u>\$150</u>
	<u>Premium Evaporative Equipment (whole-house distribution system)</u>	<u>Premium evaporative equipment must be a permanently installed indirect, indirect/direct, or direct system utilizing rigid media. A whole-house distribution system will be defined as a ducted system with a point of delivery, or register, in each occupied room within a dwelling.</u>	<u>\$750</u>	<u>\$300</u>
	<u>Geothermal Heat Pump</u>	<u>Geothermal heat pump, central ducted system, ENERGY STAR qualified</u>	<u>\$1,750</u>	<u>\$1,000</u>
	<u>Refrigerator</u>	<u>Refrigerator must be listed on CEE Tier 3. Requirements for CEE Tier 3 incentives are published on the Company's website at <a href="http://www.rockymountainpower.net/newhomes">www.rockymountainpower.net/newhomes</a></u>	<u>\$20</u>	<u>\$20</u>
	<u>HVAC-Quality Installation Contractor Certification</u>	<u>HVAC Quality Installation on matched CAC systems (Installer Certification). Requirements for Quality Installation incentives are published on the Company's website at <a href="http://www.rockymountainpower.net/newhomes">www.rockymountainpower.net/newhomes</a>.</u>	<u>\$50</u>	<u>\$25</u>
	<u>HVAC-Quality Installation Rater Certification</u>	<u>HVAC Quality Installation on matched CAC systems (HERS rater certification). Requirements for Quality Installation incentives are published on the Company's website at <a href="http://www.rockymountainpower.net/newhomes">www.rockymountainpower.net/newhomes</a>.</u>	<u>\$100</u>	<u>\$50</u>
<u>Whole Home (Select one or none per home)</u>	<u>Above Code Home</u>	<u>Meets builder checklists or HERS rater certified. Requirements for Above Code incentives are published on the Company's website at <a href="http://www.rockymountainpower.net/newhomes">www.rockymountainpower.net/newhomes</a>.</u>	<u>\$25</u>	<u>\$25</u>
	<u>ENERGY STAR Home</u>	<u>ENERGY STAR qualified home</u>	<u>\$250</u>	<u>\$150</u>
	<u>High Performance ENERGY STAR Home</u>	<u>ENERGY STAR qualified home and HERS rater documentation showing HERS index of 50 or less. Must achieve HERS index of 50 or less without solar photovoltaic system or other active solar technologies.</u>	<u>\$500</u>	<u>\$200</u>

**Table 2. Builder Incentive Levels and Qualifying Equipment for Multi-Family Residences**

Issued by authority of Report and Order of the Public Service Commission of Utah in Advice Docket No. 15-08033-035-184

**ELECTRIC SERVICE SCHEDULE NO. 110 - Continued**

<b>Utah Multi-Family</b>		
<b>Tier/Measure</b>	<b>Equipment</b>	<b>Incentive</b>
<b>Multi-Family Tier 1</b>	For 5-12 contiguous units: Meet ENERGY STAR v 2.0 specifications including performance based duct sealing, air conditioner equipment minimum standard of SEER 13**, A/C equipment commissioning, performance testing, correct sizing, best practices installation and the thermal bypass checklist; plus installation of CFLs in 50% of all light sockets, ENERGY STAR appliance package (dishwasher, washer, refrigerator where permanently installed)	<b>\$300</b>
<b>Multi-Family Tier 2</b>	For 13 or more contiguous units: Meet ENERGY STAR v 2.0 specifications including performance based duct sealing, air conditioner equipment minimum standard of SEER 13**, A/C equipment commissioning, performance testing, correct sizing, best practices installation and the thermal bypass checklist; plus installation of CFLs in 50% of all light sockets, ENERGY STAR appliance package (dishwasher, washer, refrigerator where permanently installed)	<b>\$200</b>
<b>Plus Measure*</b>	Lighting Upgrade to 90% ENERGY STAR CFLs (from base of 50% CFLs)	<b>\$35</b>
<b>Plus Measure*</b>	14 SEER*** HVAC equipment with correct sizing and best practices installation	<b>\$100</b>

Notes for Table 2

1. ~~\*Plus measures must be installed in conjunction with the Multi-Family Tiers package to be eligible for incentives.~~
2. ~~\*\*Packaged Terminal Air Conditioning (PTAC) units which exceed federal minimum standards of 10.0 EER may be substituted for SEER 13 AC units in Tiers 1 and 2.~~
3. ~~\*\*\*Packaged Terminal Air Conditioning (PTAC) units which exceed federal minimum standards of 11.5 EER may be substituted for SEER 14 A/C units.~~
4. ~~All compact fluorescent lamps (CFLs) must be ENERGY STAR qualified to be eligible for incentives.~~
5. ~~All qualifying homes must have a qualifying air conditioner or evaporative cooler.~~



P.S.C.U. No. 50

First Revision of Sheet No. 110.3  
Canceling Original Sheet No. 110.3

**ELECTRIC SERVICE SCHEDULE NO. 110 - Continued**

(continued)

---

Issued by authority of Report and Order of the Public Service Commission of Utah in Advice Docket No. 15-08033-035-184

**FILED:** ~~September 5, 2014~~ May 15, 2015  
~~2014 April~~ July 1, 2015

**EFFECTIVE:** ~~September 1,~~