



201 South Main, Suite 2300
Salt Lake City, Utah 84111

July 30, 2015

***VIA ELECTRONIC FILING
AND OVERNIGHT DELIVERY***

Public Service Commission of Utah
Heber M. Wells Building, 4th Floor
160 East 300 South
Salt lake City, UT 84114

Attention: Gary Widerburg
Commission Secretary

Re: Advice No. 15-13
Modify Rocky Mountain Power's Rule 6, Company's Installation, to Specify the
Secondary Service Voltage Options Available to Customers.

Rocky Mountain Power ("Company") hereby submits for approval to the Utah Public Service Commission Advice No. 15-13 -- Rule 6, Company's Installation. This tariff revision adds language to Rule 6 to specify the secondary service voltages available to customers.

The Company hereby submits a clean and legislative copy of the modified tariff sheet associated with Tariff P.S.C.U. No. 50 of Rocky Mountain Power applicable to electric service in the State of Utah. Pursuant to the requirements of Rule R746-405-2D, the Company states that the proposed tariff sheet does not constitute a violation of state law or commission rule. Below is the page being changed, a summary of the update and description of the changes.

First Revision of Sheet No. 6R.1 Rule 6 Company's Installation

The update to Rule 6 specifies the secondary voltages available to customers are:

- Single-phase, 120 volts, 2-wire, grounded
- Single-phase, 120/240 volts, 3-wire, grounded
- Three-phase, 208Y/120 volts, 4-wire, grounded, wye
- Three-phase, 480Y/277 volts, 4-wire, grounded, wye

The Company respectfully requests the changes proposed to Rule 6 become effective on September 1, 2015.

Questions regarding this filing may be directed to Bob Lively, Regulatory Manager, at (801) 220-4052.

Sincerely,

Jeffrey K. Larsen
Vice President, Regulation