

2.6 Baseline Performance

In compliance with Utah Reliability Reporting Rules, the Company developed performance baselines that it subsequently filed for approval (based on 2008-2012 history). These baselines were approved, but stakeholders advocated that periodically refreshing baseline levels would be beneficial. As a result this section of the report is updated using the methods that resulted in the approved baselines; refreshing through December 31, 2015 yields the values shown below. In spite of performing this recalculation the Company is not advocating modifications to these baselines.

The Company refreshed the dataset and calculated using the last six years of daily reliability data, which was selected to align with major event calculations, but required the addition of the prior 365 days in order to construct the daily rolling 365-days curves used for these calculations.

	SAIDI (Minutes)			SAIFI (Events)		
	Average	Lower Value Control Zone	Upper Value Control Zone	Average	Lower Value Control Zone	Upper Value Control Zone
As Filed	176	152	201	1.59	1.3	1.9
Recalculated through December 31, 2015	169	138	199	1.45	1.0	1.9
Current Period (January 1-December 31, 2015)	151	143	158	1.17	1.12	1.22