

ELECTRIC SERVICE SCHEDULE NO. 140 - Continued

Table 1b – Lighting Controls and Non-General Illuminance Incentives (Retrofit Only)

Measure	Category	Eligibility Requirements	Incentive “up to”
Interior Lighting Control	Occupancy Control	PIR, Dual Tech, or Integral Sensor	\$0.30/Watt controlled
	Daylighting Control	Must control interior fixtures with Continuous, Stepped, or Bi-level ballast or automated control that dims 50% or more of the fixture in response to daylight.	\$0.34/Watt controlled
	Advanced Daylighting Control	Must incorporate both an occupancy sensor and daylighting sensor operating as part of the same control sequence in the same interior space.	\$0.38/Watt controlled
Exterior Lighting Control	Exterior Dimming Control	Must control LED technology in an exterior lighting application. Control must be integral to LED fixture or fixture-mounted and reduce fixture power by 75% or more for a minimum of 6 hrs per night or when the space has been unoccupied for 15 minutes or less.	\$0.34/Watt controlled

(Continued)